

KELIBIA, Tunisia

WMO: 607200

Lat: 36.850N

Lon: 11.083E

Elev: 30

StdP: 100.97

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	6.1	7.1	0.7	4.0	9.4	2.1	4.4	9.9	10.0	12.3	8.6	12.5	1.7	300	0.352

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	7.6	33.0	23.6	31.8	23.7	30.6	23.7	26.4	29.7	25.8	28.9	25.2	28.4	3.1	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.4	20.7	28.4	24.9	20.0	27.9	24.1	19.1	27.4	82.5	29.9	79.6	29.0	77.1	28.4	28.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.8	6.8	6.0	4.0	36.0	1.3	2.3	3.1	37.7	2.3	39.0	1.5	40.4	0.6	42.0		
(5)			2.8	27.2	1.1	0.8	2.0	27.7	1.3	28.2	0.7	28.6	-0.2	29.1		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	18.9	12.4	12.4	13.9	16.0	19.3	23.3	26.2	27.0	24.3	21.3	16.9	13.8	(6)
(7)		DBStd	5.58	2.04	2.09	2.18	1.97	1.99	2.34	1.77	1.70	2.06	2.25	2.42	2.15	(7)
(8)		HDD10.0	11	4	4	1	0	0	0	0	0	0	0	0	1	(8)
(9)		HDD18.3	775	183	167	139	74	12	1	0	0	0	3	55	142	(9)
(10)		CDD10.0	3273	80	71	122	179	288	398	502	526	429	351	208	118	(10)
(11)		CDD18.3	996	0	0	1	3	42	149	243	268	179	96	13	1	(11)
(12)		CDH23.3	7516	0	0	12	21	117	936	2219	2669	1223	311	9	0	(12)
(13)	CDH26.7	2229	0	0	1	3	12	231	752	964	248	19	0	0	(13)	
(14)	Wind	WSAvg	2.7	2.7	2.8	2.9	3.0	3.0	2.8	2.9	2.6	2.5	2.3	2.5	2.6	(14)
(15)	Precipitation	PrecAvg	583	85	68	53	39	21	7	4	7	50	78	79	91	(15)
(16)		PrecMax	944	200	222	119	97	60	44	51	34	192	227	251	197	(16)
(17)		PrecMin	368	13	0	2	1	0	0	0	0	2	10	13	11	(17)
(18)		PrecStd	140	53	52	35	25	17	10	10	9	38	48	45	48	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	19.8	20.2	25.1	26.8	28.1	33.0	35.6	35.8	32.0	28.2	24.3	20.8	(19)
MCWB			14.9	14.9	19.6	21.1	19.5	21.4	22.7	23.1	24.7	22.6	19.5	16.0	(20)	
2%		DB	17.9	18.2	20.3	22.2	26.0	30.7	32.8	33.2	30.1	27.0	23.1	19.2	(21)	
		MCWB	14.2	13.7	14.8	16.7	18.7	22.0	23.3	24.1	24.0	22.6	19.0	15.7	(22)	
5%		DB	16.8	17.0	18.9	20.9	24.4	29.1	31.2	32.0	29.0	26.0	22.1	18.3	(23)	
		MCWB	13.7	13.5	14.5	16.1	18.6	21.6	23.1	24.4	23.5	21.9	18.2	15.1	(24)	
10%		DB	15.9	16.0	17.7	19.6	23.2	27.9	30.1	30.9	28.1	25.0	21.1	17.6	(25)	
		MCWB	13.1	12.9	14.0	15.5	18.1	21.2	23.2	24.6	23.0	21.3	17.8	14.6	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.7	15.7	20.6	21.5	22.0	24.7	26.9	27.2	26.6	24.6	21.3	17.8	(27)
MCD B			18.1	18.6	24.8	26.1	25.4	29.6	30.6	30.8	29.5	26.6	23.1	19.2	(28)	
2%		WB	15.0	14.7	15.9	17.8	20.4	23.6	25.8	26.6	25.8	23.7	19.9	16.7	(29)	
		MCD B	17.0	17.1	19.0	20.7	23.6	27.8	29.2	30.1	28.4	25.8	22.1	18.5	(30)	
5%		WB	14.2	14.0	15.1	16.9	19.6	22.9	25.1	26.1	25.1	23.0	19.1	15.6	(31)	
		MCD B	16.3	16.3	17.8	19.7	22.9	26.9	28.6	29.4	27.7	25.0	21.3	17.9	(32)	
10%		WB	13.5	13.2	14.4	16.1	18.8	22.2	24.5	25.6	24.3	22.2	18.2	14.9	(33)	
		MCD B	15.5	15.5	16.9	18.5	22.2	26.1	28.1	28.8	26.9	24.4	20.7	17.2	(34)	
(35)	Mean Daily Temperature Range	5% DB	MDBR	6.3	6.5	7.2	7.0	7.1	7.6	7.8	7.6	6.8	6.5	6.5	6.3	(35)
MCDBR			7.5	7.7	9.4	9.0	8.6	9.3	9.5	9.0	7.3	7.0	7.3	7.4	(36)	
MCWBR			4.9	4.8	5.6	4.9	3.8	4.1	3.8	3.9	3.8	3.9	4.5	4.8	(37)	
5% WB		MCDBR	6.7	7.0	8.2	7.8	7.4	8.2	7.9	7.4	6.2	6.2	6.3	6.3	(38)	
		MCWBR	4.8	4.5	5.3	4.9	4.0	4.0	3.9	3.8	4.0	4.0	4.5	4.6	(39)	
(40)	Clear-Sky Solar Irradiance	taub		0.353	0.373	0.423	0.464	0.477	0.446	0.465	0.459	0.459	0.431	0.389	0.359	(40)
taud		2.442	2.371	2.213	2.118	2.122	2.255	2.207	2.236	2.237	2.273	2.353	2.421	(41)		
Ebn at Noon		829	855	838	822	816	840	820	818	794	778	775	793	(42)		
Edh at Noon		87	104	133	154	156	137	143	136	129	114	94	83	(43)		
(44)	All-Sky Solar Radiation	RadAvg		2.35	3.19	4.46	5.67	6.70	7.47	7.53	6.63	4.99	3.77	2.62	2.11	(44)
(45)		RadStd		0.17	0.23	0.32	0.32	0.35	0.28	0.18	0.26	0.23	0.22	0.13	0.17	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	+0.38	N/A	N/A	+0.85	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page