

JENDOUBA, Tunisia

WMO: 607250

Lat: 36.483N

Lon: 8.800E

Elev: 144

StdP: 99.61

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	2.0	3.2	-0.1	3.8	7.5	1.1	4.2	7.4	9.1	10.7	8.2	11.3	1.2	200	0.411

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	15.8	41.5	23.3	39.7	23.2	37.8	22.7	25.9	36.8	24.9	35.3	24.1	34.2	3.7	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
23.0	18.0	31.2	22.0	16.9	29.5	21.0	16.0	28.9	80.4	37.2	76.3	35.1	72.8	34.4	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
8.1	7.1	6.2	-0.8	45.2	1.2	1.1	-1.6	46.0	-2.3	46.7	-3.0	47.3	-3.8	48.1		
			-0.9	27.1	1.2	1.5	-1.8	28.2	-2.6	29.0	-3.2	29.9	-4.1	30.9		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.0	10.6	10.9	13.1	16.0	20.7	25.6	28.8	28.7	24.9	20.7	15.2	11.6
	DBStd	7.19	2.33	2.43	2.66	2.66	3.39	3.58	2.78	2.70	3.14	3.07	2.66	2.46
	HDD10.0	55	20	16	6	1	0	0	0	0	0	0	1	12
	HDD18.3	1019	239	207	164	78	13	1	0	0	1	11	98	208
	CDD10.0	3327	39	42	101	182	332	469	583	581	448	331	158	62
	CDD18.3	1249	0	0	1	9	86	219	324	322	198	83	6	0
	CDH23.3	15237	1	2	32	169	1008	2673	4384	4192	1991	737	47	3
	CDH26.7	8457	0	0	5	43	453	1517	2691	2506	953	283	5	0
Wind	WSAvg	2.7	2.6	2.7	2.7	2.7	2.8	3.0	3.0	2.8	2.6	2.3	2.5	2.5
Precipitation	PrecAvg	473	61	56	53	42	32	17	5	14	35	46	50	60
	PrecMax	841	207	155	186	144	107	80	31	86	112	194	142	198
	PrecMin	245	6	0	2	3	1	0	0	0	1	3	2	7
	PrecStd	135	40	38	30	26	25	18	7	17	28	39	40	41
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.3	22.9	26.9	30.9	37.9	42.9	44.0	43.8	39.4	35.6	27.4	22.8
		MCWB	14.2	15.4	18.1	20.1	21.5	23.4	24.1	23.7	23.5	21.6	17.7	15.3
	2%	DB	18.8	20.3	23.7	27.5	34.0	39.9	41.6	41.1	36.8	32.2	24.7	19.8
		MCWB	13.1	14.6	16.8	18.6	20.8	22.9	23.7	23.3	22.8	20.7	17.1	13.8
	5%	DB	16.9	18.2	21.8	25.0	31.5	37.2	39.6	39.1	34.3	29.8	22.7	18.0
		MCWB	12.5	13.2	15.7	17.7	20.0	22.1	23.2	23.4	22.4	20.0	16.3	13.2
	10%	DB	15.2	16.3	19.8	22.9	29.0	34.6	37.4	37.0	32.0	27.2	20.9	16.4
		MCWB	11.8	12.3	14.7	16.6	19.1	21.6	22.7	23.1	21.8	19.4	15.6	12.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.4	16.8	20.0	21.5	23.5	25.5	27.4	27.2	25.9	23.9	19.7	16.1
		MCDB	19.7	20.9	25.1	28.1	33.6	37.8	39.1	38.0	34.4	30.9	23.9	20.7
	2%	WB	13.9	15.0	17.6	19.6	21.9	24.2	25.8	26.0	24.5	22.2	18.2	14.7
		MCDB	17.4	19.1	22.3	25.7	31.3	36.2	38.0	36.4	32.9	29.2	22.5	18.3
	5%	WB	12.9	13.6	16.2	18.2	20.8	23.2	24.6	25.0	23.5	21.1	17.2	13.9
		MCDB	16.1	17.6	20.6	23.9	29.7	34.4	36.0	34.9	31.6	27.4	21.5	17.1
	10%	WB	12.1	12.6	14.9	16.9	19.7	22.2	23.7	24.1	22.6	20.2	16.1	13.1
		MCDB	15.0	16.1	18.9	22.2	27.6	32.7	34.6	33.7	30.0	25.9	19.9	16.0
Mean Daily Temperature Range	5% DB	MDBR	9.6	10.5	11.8	12.7	14.2	15.2	15.8	15.3	12.9	12.3	10.5	9.6
		MCDBR	13.0	14.4	16.5	17.9	18.9	19.8	19.7	19.2	16.5	16.9	14.0	12.4
		MCWBR	8.3	9.1	10.2	10.0	8.0	7.6	7.4	7.6	6.4	7.4	7.8	7.7
	5% WB	MCDBR	11.6	13.5	15.2	15.8	17.3	17.7	17.2	16.0	14.2	14.3	12.2	10.7
		MCWBR	7.9	9.0	10.1	9.5	8.1	7.7	7.7	7.4	6.1	6.9	7.3	7.1
Clear-Sky Solar Irradiance	taub	0.347	0.370	0.432	0.481	0.507	0.475	0.506	0.493	0.480	0.438	0.385	0.354	
	taud	2.384	2.307	2.111	2.006	1.968	2.085	2.006	2.035	2.085	2.156	2.283	2.361	
	Ebn at Noon	835	858	828	808	791	815	786	787	774	768	777	797	
	Edh at Noon	92	111	148	173	183	162	174	166	150	128	101	88	
All-Sky Solar Radiation	RadAvg	2.35	3.10	4.34	5.43	6.41	7.45	7.54	6.61	4.94	3.77	2.63	2.10	
	RadStd	0.22	0.25	0.34	0.43	0.40	0.26	0.20	0.30	0.20	0.24	0.18	0.19	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (12 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page