

ENFIDHA, Tunisia

WMO: 607310

Lat: 36.083N

Lon: 10.433E

Elev: 20

StdP: 14.69

Time Zone: 1.00 (E01)

Period: 09-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	39.0	40.9	28.8	22.8	51.7	31.9	26.4	50.1	32.2	58.5	29.9	58.9	6.2	230	0.482

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.7	94.9	72.3	91.7	72.2	89.7	72.2	79.1	86.4	77.8	85.3	76.6	84.4	13.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
76.9	140.2	84.1	75.4	133.0	83.0	73.8	126.2	82.1	42.5	87.1	41.2	85.4	40.0	84.4	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	26.9	23.6	21.1	34.3	104.5	1.8	4.7	33.0	107.9	32.0	110.7	30.9	113.3	29.6	116.7	
(5)				32.3	81.2	2.8	1.4	30.3	82.2	28.6	83.0	27.1	83.8	25.0	84.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	66.4	53.6	53.6	57.7	62.5	67.6	74.4	80.4	80.4	77.2	70.8	62.4	55.9	(6)
(7)		DBStd	10.51	3.76	4.51	4.43	3.21	3.67	3.80	3.52	3.11	3.88	4.54	4.66	4.10	(7)
(8)		HDD50	26	8	13	1	0	0	0	0	0	0	0	0	4	(8)
(9)		HDD65	1399	354	320	230	86	14	0	0	0	0	8	103	284	(9)
(10)		CDD50	6030	119	114	240	376	547	732	943	941	815	645	372	186	(10)
(11)		CDD65	1925	0	0	4	12	96	282	478	476	365	187	24	1	(11)
(12)		CDH74	18338	3	13	41	76	496	2321	5466	5497	3213	1098	104	10	(12)
(13)		CDH80	6777	0	0	3	7	81	680	2392	2393	1016	195	10	0	(13)
(14)	Wind	WSAvg	9.9	10.0	10.3	10.7	10.4	11.3	10.4	10.1	9.3	9.3	8.5	9.1	9.6	(14)
(15)	Precipitation	PrecAvg	17.1	2.2	1.6	1.7	1.3	1.0	0.4	0.2	0.6	2.0	1.9	1.9	2.2	(15)
(16)		PrecMax	21.8	7.3	5.5	5.2	3.5	2.8	1.9	1.1	2.7	6.1	7.4	4.9	6.0	(16)
(17)		PrecMin	10.6	0.1	0.1	0.3	0.0	0.0	0.0	0.0	0.0	0.2	0.4	0.2	0.2	(17)
(18)		PrecStd	3.5	2.0	1.4	1.3	0.9	0.8	0.5	0.2	0.7	1.5	1.4	1.1	1.5	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.3	75.9	78.8	80.2	88.1	92.8	100.0	98.6	95.9	88.1	80.9	75.6	(19)
(20)		MCWB	58.1	58.0	58.3	60.9	65.0	69.3	72.1	72.3	71.1	69.0	64.2	58.2	(20)	
(21)		2%	DB	68.2	70.0	73.5	75.6	82.1	89.5	95.1	94.7	89.8	84.4	77.0	70.1	(21)
(22)		MCWB	54.9	56.1	57.5	59.2	63.6	68.4	72.3	72.6	72.5	70.5	63.6	56.0	(22)	
(23)		5%	DB	64.7	66.0	69.8	73.2	78.9	86.4	91.8	91.6	87.4	82.1	73.7	67.6	(23)
(24)		MCWB	53.6	54.7	57.2	59.6	63.3	68.4	72.0	73.4	73.6	70.6	63.4	56.1	(24)	
(25)		10%	DB	62.7	62.9	67.0	70.2	76.7	84.0	89.7	89.5	85.1	79.4	71.7	64.7	(25)
(26)		MCWB	53.1	53.3	56.3	59.6	62.9	68.2	72.2	73.6	73.1	70.0	62.2	55.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.2	60.7	62.6	64.7	69.3	75.5	79.8	81.0	79.9	76.2	69.9	61.6	(27)
(28)		MCDWB	68.0	70.6	69.8	71.8	79.0	84.2	89.2	89.0	84.9	81.0	74.8	68.7	(28)	
(29)		2%	WB	56.9	58.5	60.5	63.5	67.7	73.7	78.1	79.4	78.4	74.7	67.5	59.4	(29)
(30)		MCDWB	64.6	66.2	67.8	69.4	76.3	81.4	86.6	87.3	83.8	79.7	73.6	65.1	(30)	
(31)		5%	WB	55.4	56.5	59.4	62.6	66.6	72.3	77.0	78.1	77.1	73.5	65.6	57.9	(31)
(32)		MCDWB	62.9	64.0	65.8	68.1	74.2	80.3	85.2	86.1	83.3	78.6	71.1	64.3	(32)	
(33)		10%	WB	53.8	54.6	58.0	61.5	65.3	71.1	75.9	76.8	75.7	71.7	63.7	56.7	(33)
(34)		MCDWB	61.8	61.5	64.3	67.4	72.7	79.4	84.4	85.0	82.3	77.3	69.7	63.6	(34)	
(35)	Mean Daily Temperature Range	MDBR	18.2	18.2	17.9	16.6	17.4	18.1	18.9	18.7	16.4	16.3	17.3	18.1	(35)	
(36)		5% DB	MCDBR	22.5	23.9	22.9	22.3	22.0	22.3	23.0	22.4	19.5	19.1	20.3	22.1	(36)
(37)		MCWBR	13.0	13.0	12.0	11.1	10.7	10.7	11.7	12.3	9.6	9.8	10.5	12.1	(37)	
(38)		5% WB	MCDBR	21.3	20.7	19.4	16.5	18.8	18.6	19.7	19.1	15.7	16.0	16.4	18.2	(38)
(39)		MCWBR	13.6	12.3	11.8	9.7	10.4	10.8	11.2	12.0	9.4	9.6	10.3	11.2	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.349	0.374	0.436	0.483	0.502	0.469	0.494	0.485	0.483	0.444	0.392	0.357	(40)	
(41)		taud	2.402	2.319	2.128	2.023	2.005	2.129	2.075	2.099	2.113	2.177	2.289	2.378	(41)	
(42)		Ebn at Noon	266	272	262	256	252	260	253	252	245	243	245	253	(42)	
(43)		Edh at Noon	29	35	46	54	56	49	52	49	47	40	32	28	(43)	
(44)	All-Sky Solar Radiation	RadAvg	817	1065	1439	1788	2121	2361	2398	2110	1597	1232	887	726	(44)	
(45)		RadStd	55	67	88	110	104	95	46	81	72	70	43	54	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (11 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page