

MONASTIR, Tunisia

WMO: 607400

Lat: 35.758N

Lon: 10.755E

Elev: 7

StdP: 14.69

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	42.6	44.6	30.3	24.5	55.2	33.5	28.1	54.7	31.3	56.5	28.1	56.0	6.4	180	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.0	98.9	73.7	95.0	73.6	91.5	73.8	80.3	87.1	79.2	86.2	78.0	85.4	13.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.8	149.4	84.1	77.1	141.2	83.4	75.5	133.5	82.6	44.0	87.5	42.7	86.6	41.3	85.5	85.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
26.1	23.2	20.9	37.6	108.7	2.4	5.1	35.9	112.3	34.4	115.3	33.1	118.1	31.3	121.8		
			35.3	83.1	2.2	1.4	33.7	84.1	32.4	84.9	31.2	85.7	29.6	86.7		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	68.5	55.2	55.8	59.7	64.0	70.2	77.3	82.6	83.5	78.7	72.8	64.0	57.4	
	DBStd	10.88	3.73	4.31	4.73	4.03	4.46	4.73	3.72	3.60	4.21	4.56	4.64	4.03	
	HDD50	12	5	5	0	0	0	0	0	0	0	0	0	2	
	HDD65	1118	305	260	176	63	4	0	0	0	0	2	72	236	
	CDD50	6766	165	166	302	421	628	818	1010	1037	860	706	420	233	
	CDD65	2399	0	2	13	34	167	369	545	572	410	243	42	2	
	CDH74	22109	4	13	108	189	849	2961	6127	6765	3654	1298	130	11	
	CDH80	8586	0	1	31	49	283	1105	2673	2988	1154	286	15	1	
Wind	WSAvg	9.9	9.6	10.3	10.6	11.0	10.8	10.0	9.7	9.3	9.7	8.8	9.2	9.5	
Precipitation	PrecAvg	14.6	1.8	1.2	1.3	1.0	0.9	0.3	0.1	0.5	2.2	1.9	1.6	1.8	
	PrecMax	21.9	6.8	3.4	3.9	2.1	2.3	1.0	0.6	2.0	7.3	5.2	5.0	6.8	
	PrecMin	7.8	0.0	0.0	0.2	0.0	0.0	0.0	0.0	0.0	0.3	0.3	0.2	0.1	
	PrecStd	4.2	1.7	1.0	0.9	0.6	0.7	0.3	0.1	0.6	2.0	1.2	1.3	1.5	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.2	75.6	84.0	85.9	95.4	102.4	104.4	106.1	97.2	91.7	82.3	75.0	
		MCWB	56.4	58.3	59.6	61.2	68.0	73.2	73.4	74.0	73.3	70.7	63.0	57.4	
	2%	DB	68.0	70.1	75.6	79.0	86.4	93.6	98.6	98.5	91.8	86.1	77.3	69.9	
		MCWB	55.6	56.6	59.2	61.9	67.7	71.6	74.1	75.1	75.4	71.4	64.4	57.3	
	5%	DB	64.6	66.3	71.5	74.8	82.1	89.6	93.6	94.3	88.6	82.6	74.8	66.6	
		MCWB	54.6	55.3	58.4	61.2	66.3	70.6	73.2	75.0	75.5	71.4	64.2	57.4	
	10%	DB	62.5	62.9	67.8	71.4	78.4	86.0	91.0	91.2	85.9	80.4	71.9	64.7	
		MCWB	54.5	54.9	57.8	60.5	65.4	70.5	73.5	75.4	74.6	70.7	63.2	56.8	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.9	60.9	64.4	66.7	73.0	78.1	81.4	82.6	80.7	77.0	70.5	63.6
			MCDB	65.5	69.8	74.7	75.8	85.4	89.6	89.6	90.1	87.0	82.8	75.3	66.9
2%		WB	58.3	59.0	61.9	64.6	70.2	75.9	79.5	80.8	79.3	75.5	68.5	61.0	
		MCDB	63.6	65.3	70.1	72.6	79.9	84.8	86.9	87.6	85.4	80.6	73.4	65.5	
5%		WB	57.1	57.5	60.3	63.3	68.8	74.3	78.1	79.6	77.9	74.1	66.6	59.4	
		MCDB	62.2	63.6	67.3	70.2	77.3	82.6	85.9	86.6	84.2	79.2	71.5	64.3	
10%		WB	55.7	56.1	59.1	62.1	67.3	72.7	76.8	78.5	76.5	72.6	64.7	58.1	
		MCDB	60.9	61.9	65.0	68.2	74.7	81.0	84.7	85.8	83.2	77.9	70.0	63.6	
Mean Daily Temperature Range	5% DB	MDBR	14.2	14.0	14.4	13.9	14.5	15.3	15.9	15.0	13.0	12.9	14.1	14.4	
		MCDBR	19.2	20.3	22.5	21.8	22.8	23.0	22.7	22.0	17.7	17.1	18.1	17.9	
		MCWBR	10.8	10.4	10.2	9.1	9.1	9.4	9.6	9.8	8.2	8.1	9.4	10.2	
	5% WB	MCDBR	15.7	16.0	16.9	15.8	18.2	18.4	17.5	16.6	14.6	13.8	13.8	14.2	
		MCWBR	10.3	9.6	9.1	7.8	8.5	8.9	9.1	9.2	8.2	7.7	9.1	9.7	
Clear-Sky Solar Irradiance	taub	0.349	0.374	0.437	0.483	0.499	0.467	0.491	0.483	0.484	0.444	0.393	0.358		
	taud	2.405	2.321	2.125	2.021	2.012	2.134	2.085	2.108	2.112	2.179	2.286	2.376		
	Ebn at Noon	266	272	263	256	253	261	254	253	246	244	246	254		
	Edh at Noon	29	35	46	54	56	49	51	49	47	40	32	28		
All-Sky Solar Radiation	RadAvg	851	1110	1492	1846	2176	2406	2440	2152	1635	1255	922	754		
	RadStd	56	67	83	109	101	101	48	80	71	71	38	52		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.50	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+229	+139
(47) Regional (11 neighbors)	+0.38	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+140	N/A

Nomenclature: See separate page