

MONASTIR, Tunisia

WMO: 607400

Lat: 35.758N

Lon: 10.755E

Elev: 2

StdP: 101.30

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.9	7.0	-0.9	3.5	12.9	0.9	4.0	12.6	14.0	13.6	12.6	13.4	2.8	180	0.470

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.3	37.2	23.2	35.0	23.1	33.1	23.2	26.8	30.6	26.2	30.1	25.5	29.7	6.1	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.0	21.3	29.0	25.1	20.2	28.6	24.2	19.1	28.1	84.4	30.8	81.3	30.3	78.1	29.7	29.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
11.7	10.4	9.3	3.1	42.6	1.4	2.8	2.2	44.6	1.4	46.3	0.6	47.8	-0.4	49.9		
			1.8	28.4	1.2	0.8	0.9	29.0	0.2	29.4	-0.4	29.8	-1.3	30.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	20.3	12.9	13.2	15.4	17.8	21.2	25.2	28.1	28.6	25.9	22.6	17.8	14.1
	DBStd	6.04	2.07	2.40	2.63	2.24	2.48	2.63	2.07	2.00	2.34	2.53	2.58	2.24
	HDD10.0	7	3	3	0	0	0	0	0	0	0	0	0	1
	HDD18.3	621	169	144	98	35	2	0	0	0	1	40	131	
	CDD10.0	3759	92	92	168	234	349	454	561	576	478	392	233	129
	CDD18.3	1333	0	1	7	19	93	205	303	318	228	135	23	1
	CDH23.3	12283	2	7	60	105	472	1645	3404	3758	2030	721	72	6
	CDH26.7	4770	0	1	17	27	157	614	1485	1660	641	159	8	1
Wind	WSAvg	4.4	4.3	4.6	4.8	4.9	4.8	4.5	4.3	4.2	4.4	3.9	4.1	4.2
Precipitation	PrecAvg	371	45	31	33	25	22	7	3	13	57	49	41	46
	PrecMax	556	172	86	99	54	59	26	15	50	185	133	126	173
	PrecMin	198	1	1	5	1	0	0	0	0	8	7	5	2
	PrecStd	107	44	25	23	15	17	7	3	15	50	30	32	39
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.9	24.2	28.9	30.0	35.2	39.1	40.2	41.2	36.2	33.1	27.9	23.9
		MCWB	13.5	14.6	15.3	16.2	20.0	22.9	23.0	23.3	23.0	21.5	17.2	14.1
	2%	DB	20.0	21.1	24.2	26.1	30.2	34.2	37.0	36.9	33.2	30.1	25.2	21.1
		MCWB	13.1	13.6	15.1	16.6	19.8	22.0	23.4	23.9	24.1	21.9	18.0	14.0
	5%	DB	18.1	19.1	21.9	23.8	27.8	32.0	34.2	34.6	31.5	28.1	23.8	19.2
		MCWB	12.6	13.0	14.7	16.2	19.0	21.4	22.9	23.9	24.2	21.9	17.9	14.1
	10%	DB	16.9	17.2	19.9	21.9	25.8	30.0	32.8	32.9	30.0	26.9	22.1	18.2
		MCWB	12.5	12.7	14.3	15.8	18.6	21.4	23.0	24.1	23.7	21.5	17.3	13.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	15.5	16.1	18.0	19.3	22.8	25.6	27.5	28.1	27.1	25.0	21.4	17.6
		MCDB	18.6	21.0	23.7	24.3	29.7	32.0	32.0	32.3	30.6	28.2	24.1	19.4
	2%	WB	14.6	15.0	16.6	18.1	21.2	24.4	26.4	27.1	26.3	24.2	20.3	16.1
		MCDB	17.5	18.5	21.2	22.6	26.6	29.3	30.5	30.9	29.7	27.0	23.0	18.6
	5%	WB	13.9	14.1	15.7	17.4	20.4	23.5	25.6	26.5	25.5	23.4	19.2	15.2
		MCDB	16.8	17.5	19.6	21.2	25.1	28.1	29.9	30.3	29.0	26.2	21.9	17.9
	10%	WB	13.2	13.4	15.1	16.7	19.6	22.6	24.9	25.9	24.7	22.6	18.2	14.5
		MCDB	16.1	16.6	18.3	20.1	23.7	27.2	29.3	29.9	28.4	25.5	21.1	17.5
Mean Daily Temperature Range	5% DB	MDBR	7.9	7.8	8.0	7.7	8.1	8.5	8.9	8.3	7.2	7.2	7.8	8.0
		MCDBR	10.6	11.3	12.5	12.1	12.7	12.8	12.6	12.2	9.8	9.5	10.0	9.9
		MCWBR	6.0	5.8	5.7	5.1	5.1	5.2	5.4	5.5	4.5	4.5	5.2	5.7
	5% WB	MCDBR	8.7	8.9	9.4	8.8	10.1	10.2	9.7	9.2	8.1	7.7	7.7	7.9
		MCWBR	5.7	5.3	5.0	4.3	4.7	5.0	5.0	5.1	4.6	4.3	5.0	5.4
Clear-Sky Solar Irradiance	taub	0.349	0.374	0.437	0.483	0.499	0.467	0.491	0.483	0.484	0.444	0.393	0.358	
	taud	2.405	2.321	2.125	2.021	2.012	2.134	2.085	2.108	2.112	2.179	2.286	2.376	
	Ebn at Noon	840	858	828	808	799	823	800	798	774	768	775	800	
	Edh at Noon	91	111	146	171	175	155	161	155	147	126	102	89	
All-Sky Solar Radiation	RadAvg	2.68	3.50	4.71	5.82	6.86	7.59	7.69	6.79	5.15	3.96	2.91	2.38	
	RadStd	0.18	0.21	0.26	0.34	0.32	0.32	0.15	0.25	0.22	0.22	0.12	0.16	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(47)	Regional (11 neighbors)	+0.28	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+127	+77
		+0.21	N/A	N/A	N/A	N/A	N/A	N/A	N/A	+78	N/A

Nomenclature: See separate page