

GAUSA, Tunisia

WMO: 607450

Lat: 34.422N

Lon: 8.823E

Elev: 323

StdP: 97.50

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	1.9	3.2	-6.2	2.3	13.0	-4.8	2.6	12.1	11.2	11.8	10.0	12.8	2.8	60	0.500

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.4	42.0	20.3	40.1	20.1	38.3	20.0	23.1	33.0	22.4	32.5	21.8	32.1	4.7	230

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.6	15.9	26.3	19.8	15.1	25.8	18.9	14.3	25.8	69.8	32.9	67.2	32.4	65.0	32.1	27.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.7	9.5	8.4	DB	-1.3	44.5	1.3	1.0	-2.3	45.3	-3.0	45.9	-3.8	46.5	-4.8	47.2	(4)
(5)			WB	-2.5	24.5	1.3	1.1	-3.4	25.2	-4.2	25.8	-4.9	26.4	-5.9	27.2	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	20.3	10.2	11.5	15.0	18.8	23.4	28.0	30.9	30.6	26.5	21.8	15.4	11.2	(6)	
	DBStd	7.88	2.14	2.73	3.22	3.10	3.24	3.21	2.47	2.38	3.04	3.02	2.97	2.50	(7)	
	HDD10.0	56	24	13	2	0	0	0	0	0	0	0	1	16	(8)	
	HDD18.3	911	253	192	112	29	2	0	0	0	0	5	97	221	(9)	
	CDD10.0	3828	29	54	158	266	414	540	649	639	496	367	163	54	(10)	
	CDD18.3	1641	0	1	9	45	157	290	391	381	246	113	8	0	(11)	
	CDH23.3	20899	0	8	128	500	1725	3794	5714	5378	2673	926	53	1	(12)	
(13)	CDH26.7	11881	0	1	30	162	794	2239	3649	3333	1340	327	5	0	(13)	
(14)	Wind	WSAvg	4.2	3.7	4.1	4.5	4.9	4.8	4.4	4.2	4.2	3.8	3.6	3.5	(14)	
(15) Precipitation	PrecAvg	162	15	12	19	16	13	5	2	6	19	20	16	19	(15)	
	PrecMax	292	98	63	98	82	62	31	15	44	105	93	74	183	(16)	
	PrecMin	37	0	0	0	0	0	0	0	0	0	0	0	0	(17)	
	PrecStd	61	20	14	18	18	15	7	3	10	20	22	17	30	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	20.1	24.2	30.1	33.8	38.9	42.9	44.2	43.2	39.9	34.8	27.1	21.1	(19)	
		MCWB	11.3	12.5	14.3	16.3	18.5	19.5	20.4	20.8	20.1	18.1	16.2	12.3	(20)	
	2%	DB	18.2	21.4	26.6	30.7	35.2	40.2	42.2	41.2	37.1	32.3	24.9	19.2	(21)	
		MCWB	10.5	11.7	13.6	15.4	17.8	19.3	20.5	20.6	20.1	18.1	15.0	11.9	(22)	
	5%	DB	16.9	19.6	24.1	28.2	33.1	38.0	40.2	39.5	35.1	30.1	23.0	17.9	(23)	
		MCWB	10.1	10.8	12.9	15.1	17.4	19.1	20.3	20.5	20.2	17.9	14.4	11.3	(24)	
	10%	DB	15.4	17.8	22.1	26.1	31.1	36.0	38.4	37.9	33.2	28.1	21.2	16.5	(25)	
		MCWB	9.5	10.2	12.3	14.3	16.9	18.9	20.2	20.5	20.1	17.6	13.8	10.7	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	12.7	13.8	16.2	18.0	20.6	22.0	23.8	24.2	24.0	21.9	17.8	14.2	(27)	
		MCDB	17.3	21.3	23.2	29.6	31.0	32.3	33.7	34.0	31.9	28.0	24.2	18.0	(28)	
	2%	WB	11.5	12.5	14.7	16.6	19.5	21.0	22.6	23.2	22.7	20.7	16.5	13.1	(29)	
		MCDB	16.2	19.8	23.8	26.6	30.7	33.2	34.9	33.0	30.6	26.6	22.5	17.0	(30)	
	5%	WB	10.7	11.5	13.8	15.8	18.6	20.4	22.0	22.5	21.9	19.7	15.5	12.2	(31)	
		MCDB	15.4	18.0	22.3	25.1	29.6	33.1	34.4	32.7	29.6	26.2	21.0	16.2	(32)	
	10%	WB	10.0	10.5	12.9	15.1	17.8	19.7	21.3	21.9	21.2	18.9	14.6	11.3	(33)	
		MCDB	14.6	16.5	20.5	24.2	28.3	32.7	33.7	32.4	29.1	25.4	19.9	15.6	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	10.8	11.3	12.2	12.6	13.2	14.1	14.4	13.6	11.8	11.3	10.8	10.3	(35)	
		MCDBR	12.7	14.1	15.3	16.0	15.5	16.1	16.5	15.7	14.2	13.8	12.5	12.0	(36)	
	5% WB	MCWBR	7.1	7.1	6.5	5.8	5.1	4.8	4.9	4.8	4.5	5.1	5.8	6.6	(37)	
		MCWBR	11.1	12.3	13.3	13.7	13.7	14.5	14.8	13.6	12.2	11.2	10.8	10.2	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.332	0.360	0.446	0.501	0.532	0.504	0.536	0.519	0.505	0.453	0.390	0.343	(40)	
		taud	2.313	2.216	1.952	1.836	1.793	1.883	1.822	1.862	1.902	2.000	2.138	2.276	(41)	
	Ebn at Noon		864	875	820	794	774	794	765	769	756	760	779	822	(42)	
		Edh at Noon	101	124	175	207	219	199	211	199	182	152	119	99	(43)	
(44) All-Sky Solar Radiation	RadAvg		3.16	4.09	5.24	6.35	7.12	7.83	7.81	6.94	5.62	4.39	3.35	2.83	(44)	
	RadStd		0.18	0.18	0.23	0.28	0.34	0.26	0.19	0.22	0.22	0.19	0.13	0.18	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (8 neighbors)	+0.22	N/A	N/A	N/A	-0.33	N/A	N/A	N/A	+103	+60

Nomenclature: See separate page