

SIDI BOUZID, Tunisia

WMO: 607480

Lat: 35.000N

Lon: 9.483E

Elev: 1165

StdP: 14.09

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	37.4	39.7	23.9	18.8	56.2	26.8	21.6	56.3	21.1	53.8	18.8	55.3	2.0	250	0.388

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	25.5	105.5	69.4	101.9	69.6	98.8	69.3	75.7	91.4	74.0	89.0	72.6	87.6	8.1	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.1	123.9	79.4	70.2	116.2	78.5	68.6	109.6	78.1	39.9	91.8	38.3	88.5	37.0	87.4	80.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 18.0	15.6	13.8	32.2	112.6	1.7	1.5	31.0	113.7	30.0	114.6	29.1	115.4	27.9	116.5		
(5)			30.4	78.1	2.4	1.8	28.6	79.4	27.2	80.4	25.9	81.5	24.1	82.8		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	67.4	52.0	52.9	57.4	63.1	72.2	80.2	86.0	84.4	76.7	69.8	59.4	53.4	(6)
(7)		DBStd	13.12	4.58	5.06	5.66	5.80	5.82	6.42	4.32	4.53	5.29	4.99	4.55	4.94	(7)
(8)		HDD50	82	29	22	7	1	0	0	0	0	0	0	1	22	(8)
(9)		HDD65	1647	402	340	245	101	6	0	0	0	1	12	179	361	(9)
(10)		CDD50	6423	92	103	237	393	688	907	1116	1065	800	614	281	127	(10)
(11)		CDD65	2515	0	2	9	44	229	458	651	600	351	161	9	1	(11)
(12)		CDH74	28996	2	20	145	467	2256	5445	8665	7460	3248	1208	77	3	(12)
(13)		CDH80	15728	0	6	27	127	942	3095	5322	4375	1456	368	10	0	(13)
(14)	Wind	WSAvg	5.7	5.8	6.0	6.2	6.6	6.3	5.8	5.8	5.2	4.9	4.9	5.1	5.8	(14)
(15)	Precipitation	PrecAvg	10.0	1.4	0.7	0.9	1.1	0.8	0.4	0.2	0.6	1.4	0.8	0.9	0.8	(15)
(16)		PrecMax	23.3	9.9	2.5	2.8	3.1	2.9	1.6	1.4	2.0	4.8	2.6	4.1	3.5	(16)
(17)		PrecMin	4.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.0	0.0	(17)
(18)		PrecStd	4.1	2.2	0.7	0.7	0.9	0.7	0.4	0.3	0.6	1.1	0.6	0.9	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.9	76.7	83.5	89.6	99.5	109.0	110.2	108.9	101.0	93.5	81.2	72.8	(19)
(20)			MCWB	55.0	55.4	58.5	61.9	64.2	67.6	71.4	69.9	68.6	67.0	60.2	55.7	(20)
(21)		2%	DB	67.5	71.6	78.8	83.6	92.6	104.4	105.3	103.9	95.8	87.6	75.9	69.2	(21)
(22)			MCWB	52.6	55.1	57.1	60.5	64.0	68.1	70.6	69.8	69.2	65.4	58.8	54.4	(22)
(23)		5%	DB	64.2	67.7	74.3	79.2	88.8	98.9	102.1	100.1	92.0	83.8	72.4	65.8	(23)
(24)			MCWB	51.2	53.0	55.4	59.0	63.9	68.0	70.2	69.7	69.3	65.3	57.4	53.0	(24)
(25)		10%	DB	61.4	63.8	70.5	75.5	85.2	94.4	98.9	97.1	88.8	80.6	69.5	62.9	(25)
(26)			MCWB	50.3	50.8	54.4	57.8	62.8	67.1	70.1	69.9	68.7	64.9	56.7	52.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	56.5	61.2	62.0	64.5	69.3	74.7	77.7	78.0	77.2	72.2	64.3	58.8	(27)
(28)			MCD B	66.7	72.1	74.4	80.9	86.8	100.3	102.0	94.3	86.2	83.0	73.0	66.4	(28)
(29)		2%	WB	54.5	55.9	59.6	62.1	67.1	71.3	75.1	75.6	74.8	70.0	61.8	56.6	(29)
(30)			MCD B	63.5	68.2	73.5	78.6	84.8	90.8	95.3	90.1	84.6	78.3	70.1	64.0	(30)
(31)		5%	WB	53.0	54.0	57.6	60.6	65.5	69.8	73.2	74.0	72.6	68.3	60.0	55.0	(31)
(32)			MCD B	60.8	64.9	70.8	74.2	83.3	89.7	92.3	87.7	82.4	76.9	68.1	62.1	(32)
(33)		10%	WB	51.6	52.2	55.4	59.2	64.0	68.4	71.9	72.7	71.2	67.0	58.3	53.4	(33)
(34)			MCD B	59.1	61.7	67.5	71.3	80.9	88.9	90.8	86.7	81.5	75.7	66.3	61.4	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	17.0	18.8	20.8	19.9	22.4	24.1	25.5	24.0	20.4	19.8	19.2	17.0	(35)
(36)			MCDBR	21.8	24.6	28.1	27.0	26.9	30.7	29.5	28.1	25.2	24.7	23.4	20.4	(36)
(37)			MCWBR	11.1	12.0	11.9	9.5	8.4	8.3	8.2	7.5	7.4	8.6	9.9	10.2	(37)
(38)		5% WB	MCD BR	17.7	22.4	25.0	23.6	23.9	26.4	26.6	23.7	21.5	19.8	19.0	18.1	(38)
(39)			MCWBR	10.1	11.9	11.7	8.9	8.5	8.8	9.1	8.0	7.1	8.0	9.5	10.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.320	0.346	0.421	0.472	0.499	0.471	0.500	0.488	0.476	0.429	0.371	0.330	(40)	
(41)		taud	2.376	2.291	2.059	1.943	1.904	2.006	1.946	1.975	2.009	2.101	2.236	2.354	(41)	
(42)		Ebn at Noon	279	283	268	260	254	260	252	252	248	249	254	266	(42)	
(43)		Edh at Noon	30	36	50	59	62	56	59	56	52	43	34	29	(43)	
(44)	All-Sky Solar Radiation	RadAvg	939	1210	1582	1926	2205	2444	2459	2183	1724	1336	1006	840	(44)	
(45)		RadStd	57	65	81	104	118	91	59	77	68	58	43	58	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46) Station Only	DBAvg	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(47) Regional (11 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
		+0.40	N/A	N/A	N/A	-0.59	N/A	N/A	+200	+121

Nomenclature: See separate page