

DJERBA ZARZIS, Tunisia

WMO: 607690

Lat: 33.875N

Lon: 10.775E

Elev: 19

StdP: 14.69

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	45.3	47.8	28.1	22.1	61.2	31.7	26.1	59.3	31.0	54.7	28.1	54.3	6.5	180	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.0	102.2	71.2	98.2	71.8	94.3	72.4	80.6	87.5	79.4	86.6	78.3	85.8	9.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.9	150.2	84.8	77.3	142.0	83.9	75.9	135.3	83.3	44.4	88.0	43.0	86.4	41.7	85.8	88.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
26.9	23.7	21.1	DB	40.7	111.1	2.1	2.9	39.2	113.2	38.0	114.9	36.8	116.5	35.4	118.6
			WB	37.7	82.9	2.2	2.2	36.1	84.4	34.8	85.7	33.5	87.0	31.9	88.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.4	56.3	57.3	61.8	66.8	72.7	78.9	83.7	85.0	81.4	75.1	66.2	59.0	(6)
	DBStd	10.99	3.27	4.18	4.73	4.69	5.13	5.29	4.12	3.78	4.24	4.54	4.62	3.68	(7)
	HDD50	2	1	1	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	877	271	221	125	29	1	0	0	0	0	0	39	191	(9)
	CDD50	7454	196	205	365	504	704	868	1045	1086	941	777	485	278	(10)
	CDD65	2853	0	5	24	83	240	418	580	621	491	313	74	4	(11)
	CDH74	28837	1	30	183	484	1508	3900	7036	7981	5271	2176	255	12	(12)
	CDH80	12321	0	4	50	149	569	1640	3327	3919	2034	595	33	1	(13)
(14) Wind	WSAvg	10.2	10.6	10.7	10.6	11.2	11.1	10.6	9.6	9.2	9.7	8.9	10.0	11.0	(14)
(15) Precipitation	PrecAvg	8.6	1.2	0.7	1.0	0.6	0.3	0.1	0.0	0.1	0.9	1.2	1.1	1.4	(15)
	PrecMax	16.5	8.0	2.4	5.0	5.3	0.9	0.6	0.1	0.7	4.3	7.5	4.4	4.4	(16)
	PrecMin	4.4	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.2	0.1	0.1	(17)
	PrecStd	3.2	1.5	0.7	1.1	1.0	0.2	0.1	0.0	0.2	1.1	1.5	1.2	1.1	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	70.1	77.5	86.0	90.0	100.1	106.5	107.3	107.2	101.8	95.0	84.1	75.2	(19)
		MCWB	56.3	58.0	59.8	63.8	67.2	69.6	70.7	73.5	71.8	69.0	64.1	58.5	(20)
	2%	DB	66.6	71.9	78.7	84.3	91.4	98.7	100.7	101.2	96.4	89.5	79.3	69.9	(21)
		MCWB	55.3	56.1	58.7	61.8	66.6	68.5	71.9	73.2	72.7	70.0	64.0	58.4	(22)
	5%	DB	64.5	67.9	73.8	79.1	85.9	92.9	96.3	96.8	91.7	85.9	76.9	67.6	(23)
		MCWB	55.1	55.2	58.3	61.4	65.9	69.5	72.7	73.1	74.2	70.1	64.1	57.8	(24)
	10%	DB	62.6	64.6	70.0	75.2	81.4	88.1	92.0	92.9	88.2	82.7	73.8	65.8	(25)
		MCWB	54.7	54.4	57.8	60.7	65.4	69.5	73.1	74.8	74.6	70.8	63.1	57.2	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	61.0	61.3	65.6	68.1	72.7	78.3	81.7	82.7	82.2	78.3	71.6	63.8	(27)
		MCDB	64.2	70.1	73.7	79.0	83.1	87.9	89.3	89.6	87.5	82.8	77.2	68.2	(28)
	2%	WB	59.0	59.4	63.1	66.0	70.5	76.1	79.7	80.8	80.0	76.2	68.8	61.5	(29)
		MCDB	62.8	66.3	70.6	75.3	79.8	84.6	87.2	87.9	85.9	81.5	75.0	66.2	(30)
	5%	WB	57.4	57.8	61.2	64.6	69.1	74.5	78.3	79.7	78.8	74.6	66.8	59.8	(31)
		MCDB	61.9	63.9	68.4	72.6	78.4	82.7	86.1	87.2	85.0	80.0	72.7	65.0	(32)
	10%	WB	56.0	56.3	59.9	63.4	67.8	72.9	77.1	78.6	77.4	73.1	65.1	58.4	(33)
		MCDB	60.6	62.5	66.6	70.6	77.1	81.4	85.5	86.5	84.4	79.1	71.5	63.9	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	12.5	14.0	15.1	15.1	15.1	15.7	16.0	15.0	13.4	13.7	13.4	11.7	(35)
		MCDBR	16.0	20.1	22.7	23.6	24.2	25.2	24.5	23.6	20.2	19.2	17.6	15.2	(36)
	5% WB	MCWBR	8.7	9.0	8.9	8.5	8.2	8.6	9.2	9.2	7.9	8.2	8.8	8.5	(37)
		MCWBR	13.6	15.6	17.0	16.8	18.0	17.6	16.8	15.8	14.2	14.3	14.2	12.5	(38)
(40) Clear-Sky Solar Irradiance	taub		0.373	0.399	0.482	0.533	0.544	0.500	0.523	0.514	0.525	0.479	0.427	0.385	(40)
		taud	2.309	2.220	1.984	1.887	1.890	2.032	1.992	2.026	1.997	2.073	2.160	2.261	(41)
	Ebn at Noon		260	266	251	244	243	253	246	246	236	235	237	247	(42)
		Edn at Noon	33	40	54	62	63	55	56	54	53	45	38	33	(43)
(44) All-Sky Solar Radiation	RadAvg		942	1220	1572	1915	2165	2352	2370	2112	1683	1304	997	843	(44)
	RadStd		43	54	81	94	109	82	63	57	68	65	43	57	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(46)	Station Only	+0.54	N/A	N/A	N/A	N/A	N/A	N/A	-95	+209	N/A
(47)	Regional (5 neighbors)	N/A	N/A	N/A	N/A	-0.70	-0.81	N/A	N/A	+158	N/A

Nomenclature: See separate page