

DJERBA ZARZIS, Tunisia

WMO: 607690

Lat: 33.875N

Lon: 10.775E

Elev: 6

StdP: 101.26

Time Zone: 1.00 (E01)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	7.4	8.8	-2.2	3.2	16.2	-0.1	3.7	15.1	13.9	12.6	12.6	12.4	2.9	180	0.472

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.3	39.0	21.8	36.8	22.1	34.6	22.4	27.0	30.8	26.3	30.3	25.7	29.9	4.2	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.5	29.3	25.2	20.3	28.8	24.4	19.3	28.5	85.3	31.1	82.1	30.2	79.1	29.9	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
12.0	10.6	9.4	4.8	44.0	1.1	1.6	4.0	45.1	3.3	46.0	2.7	46.9	1.9	48.1		
			3.2	28.3	1.2	1.2	2.3	29.1	1.5	29.9	0.8	30.6	-0.1	31.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.3	13.5	14.0	16.5	19.3	22.6	26.1	28.7	29.5	27.4	23.9	19.0	15.0
	DBStd	6.11	1.81	2.32	2.63	2.60	2.85	2.94	2.29	2.10	2.35	2.52	2.57	2.04
	HDD10.0	1	1	1	0	0	0	0	0	0	0	0	0	0
	HDD18.3	487	151	123	69	16	1	0	0	0	0	0	22	106
	CDD10.0	4141	109	114	203	280	391	482	581	603	523	432	269	154
	CDD18.3	1585	0	3	13	46	133	232	322	345	273	174	41	2
	CDH23.3	16021	1	17	102	269	838	2167	3909	4434	2928	1209	142	7
(13)	CDH26.7	6845	0	2	28	83	316	911	1848	2177	1130	331	18	1
(14)	Wind	WSAvg	4.6	4.7	4.8	4.7	5.0	4.7	4.3	4.1	4.3	4.0	4.4	4.9
(15) Precipitation	PrecAvg	219	31	17	25	15	7	2	0	3	24	30	27	36
	PrecMax	418	202	60	128	134	22	16	3	17	108	190	112	113
	PrecMin	113	0	0	2	0	0	0	0	0	1	4	2	2
	PrecStd	82	39	18	29	25	6	3	1	5	29	38	30	28
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	21.2	25.3	30.0	32.2	37.9	41.4	41.8	41.8	38.8	35.0	28.9	24.0
		MCWB	13.5	14.5	15.5	17.7	19.5	20.9	21.5	23.1	22.1	20.6	17.9	14.7
	2%	DB	19.2	22.2	26.0	29.0	33.0	37.0	38.2	38.5	35.8	32.0	26.3	21.0
		MCWB	12.9	13.4	14.8	16.6	19.2	20.3	22.1	22.9	22.6	21.1	17.8	14.7
	5%	DB	18.1	20.0	23.2	26.2	29.9	33.8	35.7	36.0	33.1	29.9	24.9	19.8
		MCWB	12.9	12.9	14.6	16.4	18.8	20.8	22.6	22.8	23.5	21.2	17.8	14.3
	10%	DB	17.0	18.1	21.1	24.0	27.5	31.2	33.4	33.9	31.2	28.1	23.2	18.8
		MCWB	12.6	12.4	14.3	15.9	18.6	20.8	22.8	23.8	23.7	21.6	17.3	14.0
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	16.1	16.3	18.7	20.0	22.6	25.7	27.6	28.2	27.9	25.7	22.0	17.6
		MCDB	17.9	21.2	23.2	26.1	28.4	31.1	31.8	32.0	30.8	28.2	25.1	20.1
	2%	WB	15.0	15.2	17.3	18.9	21.4	24.5	26.5	27.1	26.7	24.5	20.4	16.4
		MCDB	17.1	19.1	21.4	24.1	26.6	29.2	30.7	31.1	29.9	27.5	23.9	19.0
	5%	WB	14.1	14.3	16.2	18.1	20.6	23.6	25.7	26.5	26.0	23.6	19.4	15.5
		MCDB	16.6	17.7	20.2	22.6	25.8	28.1	30.1	30.6	29.4	26.7	22.6	18.4
	10%	WB	13.3	13.5	15.5	17.4	19.9	22.7	25.1	25.9	25.2	22.8	18.4	14.7
		MCDB	15.9	16.9	19.2	21.5	25.0	27.5	29.7	30.3	29.1	26.2	21.9	17.7
(35) Mean Daily Temperature Range	5% DB	MDBR	6.9	7.8	8.4	8.4	8.4	8.7	8.9	8.3	7.4	7.6	7.5	6.5
		MCDBR	8.9	11.2	12.6	13.1	13.5	14.0	13.6	13.1	11.2	10.7	9.8	8.5
		MCWBR	4.9	5.0	4.9	4.7	4.5	4.8	5.1	5.1	4.4	4.6	4.9	4.7
	5% WB	MCDBR	7.6	8.7	9.5	9.3	10.0	9.8	9.3	8.8	7.9	8.0	7.9	6.9
		MCWBR	5.0	4.9	4.7	4.2	4.2	4.5	4.4	4.4	4.3	4.4	4.8	4.5
(40) Clear-Sky Solar Irradiance	taub		0.373	0.399	0.482	0.533	0.544	0.500	0.523	0.514	0.525	0.479	0.427	0.385
	taud		2.309	2.220	1.984	1.887	1.890	2.032	1.992	2.026	1.997	2.073	2.160	2.261
	Ebn at Noon		821	837	791	769	765	798	777	777	743	742	747	778
	Edh at Noon		103	125	171	197	199	172	178	169	167	143	119	103
(44) All-Sky Solar Radiation	RadAvg		2.97	3.85	4.96	6.04	6.82	7.42	7.47	6.66	5.30	4.11	3.14	2.66
	RadStd		0.14	0.17	0.26	0.30	0.34	0.26	0.20	0.18	0.21	0.20	0.14	0.18

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.30	N/A	N/A	N/A	N/A	N/A	N/A	-53	+116	N/A
(47) Regional (5 neighbors)	N/A	N/A	N/A	N/A	-0.39	-0.45	N/A	N/A	+88	N/A

Nomenclature: See separate page