

AGADEZ, Niger

WMO: 610240

Lat: 16.967N

Lon: 7.983E

Elev: 505

StdP: 95.40

Time Zone: 1.00 (E01)

Period: 82-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	10.7	12.1	-8.2	2.0	24.3	-8.2	2.0	24.3	16.2	20.5	14.9	21.8	3.1	100	0.539

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
5	12.6	42.2	19.3	41.7	19.3	40.9	19.2	24.1	33.6	23.7	33.3	23.2	33.0	4.5	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
21.9	17.7	27.6	21.1	16.8	27.9	20.4	16.0	28.3	75.4	33.4	73.4	33.1	71.7	32.9	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)		
(4) 13.4	11.5	10.1	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			1.6	26.5	1.9	1.8	0.3	27.7	-0.8	28.8	-1.8	29.8	-3.2	31.0		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	28.9	20.3	23.6	27.5	31.9	34.5	34.6	32.9	31.4	32.5	29.9	25.4	21.5
	DBStd	5.47	3.01	3.82	3.58	2.83	1.89	1.48	1.83	1.78	1.25	2.26	2.58	2.97
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	21	13	3	0	0	0	0	0	0	0	0	0	5
	CDD10.0	6883	318	380	543	658	759	738	711	665	675	616	463	358
	CDD18.3	3864	73	149	285	408	501	488	452	407	425	357	213	104
	CDH23.3	57392	765	1844	3939	6515	8442	8132	6918	5711	6528	5066	2448	1083
	CDH26.7	36401	254	911	2287	4401	6007	5748	4501	3397	4193	3075	1231	397
(14) Wind	WSAvg	4.5	5.4	4.9	5.1	4.7	4.2	4.1	4.1	4.1	3.8	4.4	4.4	4.8
(15) Precipitation	PrecAvg	117	0	0	0	1	5	9	43	56	15	0	0	0
	PrecMax	225	0	1	6	50	34	37	125	150	78	4	0	0
	PrecMin	4	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	49	0	0	1	7	9	10	28	33	19	1	0	0
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	33.8	37.9	40.1	42.4	43.3	43.0	42.1	40.3	41.0	39.9	37.2	34.2
		MCWB	14.8	16.7	18.1	19.5	19.4	19.4	20.4	19.7	19.2	18.5	17.2	16.1
	2%	DB	31.6	35.9	38.7	41.3	42.5	42.1	40.9	39.4	40.0	38.8	35.9	32.3
		MCWB	13.9	16.1	17.5	18.7	19.2	19.5	20.4	19.9	19.1	18.3	16.5	14.9
	5%	DB	29.5	34.0	37.2	40.5	41.8	41.3	39.8	38.4	39.2	37.9	34.2	30.4
		MCWB	13.2	15.1	16.8	18.4	19.0	19.5	20.3	20.1	19.2	17.7	15.7	14.1
	10%	DB	27.5	31.9	35.8	39.5	41.0	40.5	38.6	37.0	38.3	36.9	32.9	28.8
		MCWB	12.3	14.0	16.0	18.1	19.0	19.5	20.7	21.1	19.3	17.3	15.3	13.4
	0.4%	WB	15.9	18.5	20.1	21.6	24.0	24.4	24.8	25.0	24.2	22.6	18.3	17.6
		MCDB	30.7	35.0	35.8	37.6	37.8	36.6	34.1	33.0	34.2	33.4	34.6	31.1
	2%	WB	14.4	16.8	18.6	20.5	22.9	23.5	23.9	24.1	23.4	20.9	17.1	15.8
		MCDB	30.0	33.8	35.3	38.3	36.9	35.5	33.9	32.0	33.3	33.9	34.1	30.9
(31) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	5%	WB	13.4	15.5	17.5	19.5	22.0	22.8	23.4	23.7	22.6	19.6	16.3	14.6
		MCDB	28.9	32.8	35.5	38.4	35.7	35.3	33.4	31.7	32.7	34.9	33.2	29.7
	10%	WB	12.5	14.4	16.5	18.6	21.1	22.2	22.9	23.2	21.9	18.2	15.6	13.5
		MCDB	27.1	31.3	34.5	37.9	34.8	35.2	33.0	31.5	32.4	35.0	32.2	28.1
(35) Mean Daily Temperature Range	5% DB	MDBR	13.9	14.7	14.2	14.0	12.6	12.2	11.4	11.3	12.2	13.3	14.1	14.0
		MCDBR	15.5	15.7	14.6	14.0	13.3	12.8	12.5	12.5	13.1	13.4	15.0	15.4
		MCWBR	7.3	6.8	6.3	6.0	5.3	5.2	4.6	4.0	5.0	5.3	6.5	7.0
	5% WB	MCDBR	15.3	15.2	13.5	13.4	11.6	11.7	11.2	10.9	11.6	12.5	14.7	15.0
		MCWBR	7.4	6.9	6.2	6.2	5.2	5.2	4.0	3.5	4.9	5.9	6.6	7.1
(40) Clear-Sky Solar Irradiance	taub		0.466	0.521	0.594	0.669	0.714	0.731	0.715	0.684	0.654	0.603	0.498	0.461
	taud		1.914	1.760	1.611	1.510	1.445	1.451	1.535	1.592	1.598	1.637	1.806	1.895
	Ebn at Noon		810	785	744	692	653	635	647	673	689	707	771	798
	Edh at Noon		184	225	269	298	314	309	285	271	268	251	203	182
(44) All-Sky Solar Radiation	RadAvg		5.43	6.03	6.75	7.06	7.07	6.81	6.79	6.51	6.46	6.13	5.64	5.20
	RadStd		0.13	0.23	0.31	0.27	0.21	0.30	0.16	0.15	0.17	0.18	0.12	0.17

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page