

BAMAKO, Mali

WMO: 612910

Lat: 12.534N

Lon: 7.950W

Elev: 1247

StdP: 14.05

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	59.0	61.2	13.6	11.5	86.8	17.3	13.8	80.6	19.2	78.5	17.7	79.5	4.3	20	0.376

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	23.9	105.0	67.4	103.7	67.5	102.1	67.8	80.6	88.6	79.2	87.4	78.5	86.7	8.1	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.0	157.5	83.3	77.4	149.3	81.8	76.9	146.8	81.3	45.4	87.7	43.9	87.7	43.1	86.9	96.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.8	15.3	13.6	DB	52.9	107.8	3.5	1.3	50.3	108.7	48.2	109.5	46.2	110.3	43.7	111.2	(4)
(5)			WB	42.3	84.0	2.4	3.4	40.6	86.4	39.2	88.4	37.8	90.4	36.0	92.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.4	76.8	82.1	87.4	90.4	89.0	84.5	80.4	79.2	80.3	82.4	80.1	77.0	(6)	
	DBStd	5.36	3.77	4.26	3.46	3.05	3.68	3.75	2.97	2.40	2.35	2.06	2.51	3.24	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD50	11840	830	897	1160	1212	1207	1036	942	904	909	1004	902	837	(10)	
	CDD65	6365	365	477	695	762	742	586	477	439	459	539	452	372	(11)	
	CDH74	77116	3894	5969	10136	11843	10723	7221	4485	3425	4021	5705	5553	4141	(12)	
	CDH80	42615	1919	3380	6316	7756	6601	3776	1767	1151	1651	2975	3203	2120	(13)	
(14) Wind	WSAvg	6.3	7.7	8.0	7.2	6.7	7.2	6.9	5.7	5.1	4.4	4.2	5.6	7.3	(14)	
(15) Precipitation	PrecAvg	37.2	0.0	0.0	0.2	0.8	2.3	4.8	9.1	10.4	7.4	2.6	0.1	0.0	(15)	
	PrecMax	58.7	0.3	0.2	1.3	5.4	5.6	11.3	16.1	18.4	19.8	10.1	1.2	1.0	(16)	
	PrecMin	25.3	0.0	0.0	0.0	0.0	0.1	1.5	4.3	5.1	3.4	0.0	0.0	0.0	(17)	
	PrecStd	6.9	0.0	0.0	0.3	1.0	1.4	1.8	2.7	3.0	3.0	2.2	0.3	0.1	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	98.6	102.5	105.5	107.4	106.1	102.2	95.1	91.7	94.8	98.5	98.7	97.0	(19)	
		MCWB	61.9	63.6	65.4	66.5	69.1	72.0	76.3	77.9	77.8	71.1	66.2	63.4	(20)	
	2%	DB	95.0	100.4	103.8	105.7	104.2	99.0	92.8	89.8	92.8	96.7	97.0	95.1	(21)	
		MCWB	61.3	62.7	64.4	67.1	70.1	74.5	76.6	77.3	77.4	71.8	66.1	62.6	(22)	
	5%	DB	92.8	98.5	102.2	104.0	102.3	96.8	90.6	88.1	90.6	95.0	95.9	93.3	(23)	
		MCWB	60.1	62.5	64.6	67.6	71.6	75.1	76.5	76.9	77.2	73.3	65.8	61.7	(24)	
	10%	DB	89.9	96.2	100.5	102.3	100.2	94.6	88.3	86.2	88.5	93.2	94.7	91.1	(25)	
		MCWB	59.0	61.4	64.1	68.2	72.2	75.6	76.3	76.7	77.0	74.3	65.5	61.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	67.9	72.1	75.2	79.7	80.7	80.9	81.4	81.5	82.1	81.4	76.5	68.0	(27)	
		MCDB	83.0	90.1	94.2	93.3	92.3	91.1	87.3	86.3	88.5	88.9	86.8	87.4	(28)	
	2%	WB	64.8	68.4	73.0	77.2	78.6	79.2	79.1	79.2	79.9	79.1	74.3	65.5	(29)	
		MCDB	85.7	90.5	91.4	91.4	90.7	89.4	86.1	85.0	86.5	87.8	85.1	89.0	(30)	
	5%	WB	62.3	65.0	71.2	75.5	77.5	78.3	78.1	78.2	78.6	78.0	72.5	63.8	(31)	
		MCDB	87.3	92.1	89.6	91.5	89.8	88.4	85.2	84.2	85.6	86.7	83.2	88.3	(32)	
	10%	WB	60.5	62.6	69.4	74.2	76.5	77.4	77.4	77.4	77.8	77.1	70.5	62.1	(33)	
		MCDB	87.1	92.4	90.1	90.7	89.2	87.5	84.4	83.1	84.8	85.7	82.7	86.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	27.1	27.0	26.0	23.9	21.5	19.1	15.9	14.7	17.2	22.6	30.1	28.4	(35)	
		MCDBR	30.4	29.4	28.0	26.7	24.2	22.1	18.6	17.2	19.9	25.8	32.2	31.9	(36)	
	5% WB	MCWBR	12.1	11.4	10.8	10.5	8.3	7.1	6.8	7.1	8.0	8.4	10.3	10.9	(37)	
		MCWBR	27.9	26.5	23.2	21.8	20.9	19.7	17.0	15.9	18.4	21.7	26.5	28.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.498	0.555	0.691	0.675	0.648	0.624	0.554	0.514	0.521	0.541	0.487	0.464	(40)	
		taud	1.963	1.818	1.567	1.663	1.724	1.807	1.999	2.118	2.072	1.993	2.037	2.065	(41)	
	Ebn at Noon		254	245	216	219	220	223	240	253	253	246	255	260	(42)	
		Edh at Noon	57	69	90	82	75	68	57	51	54	57	53	51	(43)	
(44) All-Sky Solar Radiation	RadAvg		1760	1918	2037	2057	1966	1863	1732	1667	1771	1840	1797	1728	(44)	
	RadStd		98	92	86	89	86	60	79	69	80	45	64	61	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	+0.54	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	+0.54	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page