

SIKASSO, Mali

WMO: 612970

Lat: 11.350N

Lon: 5.683W

Elev: 1230

StdP: 14.05

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	62.7	64.8	19.8	15.5	86.1	24.1	19.1	85.7	16.7	81.6	15.6	82.3	2.7	0	0.335

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	20.8	101.7	68.8	100.3	69.0	99.0	69.1	79.1	91.1	78.3	90.0	77.8	89.1	6.1	40

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
76.2	143.4	83.9	75.5	139.7	83.0	74.9	136.9	82.5	43.6	91.5	42.8	90.4	42.2	89.4	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
Min	Max		Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.9	13.2	11.4	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	82.6	77.6	84.0	88.5	88.9	86.9	83.0	79.8	79.1	79.9	82.7	82.5	78.4
	DBStd	4.80	3.45	4.24	3.32	3.22	3.36	3.28	2.44	2.25	2.36	2.35	2.08	3.11
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11893	855	951	1193	1168	1145	990	925	896	1014	974	880	
	CDD65	6418	390	531	728	718	680	540	460	437	446	549	524	415
	CDH74	76439	4234	7092	10876	10544	9308	6266	4242	3487	3705	5874	6283	4528
	CDH80	39091	2017	4053	6713	6407	5185	2816	1426	1005	1313	2668	3289	2199
(14) Wind	WSAvg	4.9	5.2	5.5	5.1	5.4	6.2	6.0	5.1	4.7	3.9	4.2	3.6	4.6
(15) Precipitation	PrecAvg	45.7	0.0	0.2	0.5	1.9	3.9	6.1	9.6	11.8	8.3	3.1	0.4	0.0
	PrecMax	66.1	0.7	1.5	2.7	10.0	7.6	9.7	15.2	19.4	17.0	12.4	2.3	1.6
	PrecMin	29.7	0.0	0.0	0.0	0.0	1.0	1.1	4.0	5.6	2.7	0.0	0.0	0.0
	PrecStd	8.1	0.2	0.3	0.7	1.8	1.8	1.5	2.8	3.5	2.7	2.1	0.6	0.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	95.8	101.4	103.3	103.3	102.2	97.2	93.1	90.2	92.5	96.3	96.9	95.9
		MCWB	64.2	65.6	66.5	71.8	73.7	76.8	77.7	77.4	77.6	71.4	67.6	64.2
	2%	DB	93.5	99.6	101.7	101.5	99.6	94.7	90.3	88.4	90.4	94.3	95.4	94.0
		MCWB	62.5	65.5	66.4	71.0	75.2	77.2	76.6	76.9	77.2	73.6	68.0	63.8
	5%	DB	91.8	98.1	100.4	99.9	97.7	92.8	88.4	87.0	88.7	92.7	94.2	92.2
		MCWB	61.3	65.1	67.0	70.8	75.5	77.0	76.3	76.5	76.9	74.6	68.2	63.4
	10%	DB	89.9	96.3	99.0	98.4	95.7	90.9	86.8	85.5	86.9	91.1	93.0	90.4
		MCWB	60.4	64.8	67.0	71.3	75.6	76.6	76.1	76.0	76.4	75.2	68.3	62.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	71.8	74.9	77.3	79.8	80.0	79.7	78.7	78.8	79.6	79.0	78.2	72.4
		MCDB	87.0	92.4	92.8	93.9	92.1	92.4	89.2	87.4	88.9	89.2	89.6	87.1
	2%	WB	66.5	72.8	75.5	77.9	78.8	78.4	77.8	77.7	78.3	77.9	75.7	68.5
		MCDB	85.1	90.4	92.3	94.0	92.7	90.5	87.4	85.8	87.5	88.4	88.1	85.2
	5%	WB	64.2	71.0	74.3	76.5	78.0	77.9	77.2	77.1	77.5	77.1	74.5	65.5
		MCDB	84.6	89.4	91.2	92.0	91.6	89.5	86.1	84.9	86.4	87.8	86.8	87.7
	10%	WB	62.2	69.1	73.1	75.5	77.3	77.2	76.5	76.4	76.8	76.4	73.3	63.9
		MCDB	86.3	89.2	90.1	90.4	90.5	88.3	84.8	83.6	85.2	86.8	84.5	86.5
(35) Mean Daily Temperature Range	5% DB	MDBR	24.5	23.2	20.8	18.8	17.3	15.5	13.8	12.4	14.7	17.8	23.5	25.3
		MCDBR	26.7	24.5	22.4	20.5	19.4	17.9	15.6	14.8	17.1	19.8	24.6	26.8
		MCWBR	8.5	8.5	8.2	6.5	5.4	5.9	5.6	5.6	6.7	6.3	7.4	7.5
	5% WB	MCDBR	24.5	19.5	18.3	18.3	17.3	16.6	14.7	14.1	16.1	17.4	20.2	25.1
		MCWBR	9.6	8.9	8.2	6.0	6.1	6.4	5.9	5.7	6.9	6.6	7.8	8.6
(40) Clear-Sky Solar Irradiance	taub	0.536	0.607	0.735	0.683	0.625	0.584	0.524	0.498	0.503	0.548	0.517	0.493	
	taud	1.879	1.730	1.530	1.697	1.791	1.902	2.098	2.179	2.143	1.989	1.981	2.001	
	Ebn at Noon	244	233	207	217	225	232	247	258	259	245	248	253	
	Edh at Noon	63	75	94	79	70	62	51	48	50	57	56	55	
(44) All-Sky Solar Radiation	RadAvg	1811	1902	1960	1937	1925	1799	1688	1603	1706	1844	1800	1758	
(45)	RadStd	93	94	91	81	50	61	49	73	80	50	54	59	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page