

NOUAKCHOTT, MauritaniaWMO: **614420**Lat: **18.300N**Lon: **15.976W**Elev: **26**StdP: **14.68**Time Zone: **0.00 (E00)**Period: **94-17**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	55.2	57.3	10.0	9.2	79.0	13.9	11.1	78.2	25.2	75.8	22.8	74.2	8.3	50	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	15.3	106.6	68.1	103.3	67.9	100.0	67.8	83.8	86.8	82.3	86.1	81.0	85.8	13.9	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
83.1	173.3	84.8	81.5	163.9	84.0	80.1	156.6	83.8	47.9	87.4	46.3	85.4	44.7	85.8	91.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
21.1	18.9	17.3	49.9	113.0	2.4	2.1	48.2	114.6	46.8	115.8	45.5	117.0	43.8	118.6		
			38.5	85.8	2.1	2.8	37.0	87.8	35.8	89.5	34.7	91.0	33.2	93.0		
			DB													
			WB													

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.8	71.5	74.2	77.2	78.6	80.9	82.4	82.0	84.2	86.3	85.9	80.3	74.1
	DBStd	6.78	4.55	4.77	5.82	6.37	6.38	6.34	3.82	2.96	3.91	4.55	4.41	4.41
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	4	4	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10886	666	676	844	859	959	971	992	1061	1089	1114	909	746
	CDD65	5415	205	256	379	409	494	521	527	596	639	649	459	281
	CDH74	54531	2011	2469	3448	3325	4217	4733	5074	6894	7956	7399	4488	2517
	CDH80	25543	767	1131	1852	1753	2241	2254	1659	2767	3900	3896	2308	1015
Wind	WSAvg	10.1	10.2	10.9	10.7	11.5	11.5	10.9	10.4	9.5	8.9	9.2	8.6	9.2
Precipitation	PrecAvg	4.4	0.0	0.1	0.0	0.0	0.0	0.1	0.4	1.8	1.6	0.2	0.1	0.1
	PrecMax	9.1	0.5	1.0	0.1	0.1	0.1	0.7	1.6	5.0	4.7	1.5	1.4	2.7
	PrecMin	0.8	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.1	0.0	0.0	0.0
	PrecStd	2.3	0.1	0.2	0.0	0.0	0.0	0.2	0.5	1.3	1.4	0.4	0.3	0.5
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.7	98.9	104.1	107.5	109.5	111.5	104.4	100.5	107.5	107.6	102.4	95.3
		MCWB	63.2	61.6	64.5	65.6	67.3	68.5	70.7	74.8	71.3	68.4	65.9	63.6
	2%	DB	90.6	93.9	98.9	101.8	103.8	105.4	93.4	94.8	101.9	104.1	98.8	91.7
		MCWB	59.6	59.3	62.1	64.7	66.6	68.1	73.9	77.4	73.5	68.6	65.6	63.2
	5%	DB	87.6	91.1	95.2	95.9	97.1	97.1	89.4	91.4	96.4	100.5	95.4	89.2
		MCWB	58.2	58.6	61.0	64.9	66.5	69.4	75.7	78.4	75.8	69.2	64.9	61.9
	10%	DB	84.3	87.7	91.1	89.9	91.6	91.0	86.7	89.4	92.8	96.5	92.1	86.0
		MCWB	57.6	58.2	61.1	65.6	67.1	70.6	76.0	78.5	77.3	69.9	64.0	60.5
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.9	70.2	72.1	74.2	76.4	80.7	83.0	86.2	86.4	83.8	76.9	73.8
		MCDB	80.4	77.6	82.4	84.3	85.9	85.8	85.6	87.7	88.5	87.3	83.4	79.9
	2%	WB	66.9	67.5	69.8	71.9	74.1	78.5	80.8	83.7	84.0	81.0	73.8	70.4
		MCDB	75.2	75.2	79.1	81.8	83.4	83.4	84.1	86.0	87.4	86.2	82.1	78.8
	5%	WB	64.5	65.6	68.3	70.1	72.4	76.9	79.4	82.1	82.5	79.3	71.7	68.3
		MCDB	73.8	74.1	77.6	80.6	82.1	82.6	83.3	85.3	86.8	85.6	80.1	77.5
	10%	WB	62.2	63.9	66.9	68.8	70.9	75.5	78.2	80.7	81.2	77.6	70.0	66.3
		MCDB	73.4	73.1	76.4	79.0	81.2	81.7	82.8	85.5	86.4	84.7	79.4	76.9
Mean Daily Temperature Range	5% DB	MDBR	25.5	25.3	25.5	23.7	23.1	19.1	11.8	11.9	15.3	21.4	24.3	24.4
		MCDBR	29.7	30.1	31.7	30.7	30.4	29.9	17.6	15.9	21.6	26.9	28.3	28.2
		MCWBR	14.2	13.7	12.7	11.3	11.2	11.4	9.1	8.7	11.4	12.2	12.0	12.8
	5% WB	MCDBR	24.2	23.2	25.0	23.6	21.8	16.9	12.2	12.2	14.7	19.1	22.8	23.1
	MCWBR	13.3	11.9	11.2	10.9	10.7	10.1	9.1	10.2	10.8	11.8	12.1	12.1	
Clear-Sky Solar Irradiance	taub	0.504	0.501	0.555	0.583	0.661	0.771	0.801	0.759	0.716	0.618	0.487	0.490	
	taud	1.834	1.854	1.747	1.732	1.588	1.460	1.449	1.529	1.584	1.719	1.966	1.906	
	Ebn at Noon	243	254	245	239	219	194	188	198	204	220	247	243	
	Edh at Noon	62	64	74	76	87	97	99	92	86	73	54	57	
All-Sky Solar Radiation	RadAvg	1613	1847	2172	2364	2411	2345	2239	2152	2031	1899	1642	1500	
	RadStd	105	98	78	63	68	88	55	59	76	74	94	74	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page