

NOUAKCHOTT, Mauritania

WMO: 614420

Lat: 18.300N

Lon: 15.976W

Elev: 8

StdP: 101.23

Time Zone: 0.00 (E00)

Period: 94-17

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.9	14.1	-12.2	1.3	26.1	-10.1	1.6	25.7	11.3	24.3	10.2	23.5	3.7	50	0.467

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
9	8.5	41.4	20.1	39.6	20.0	37.8	19.9	28.8	30.5	28.0	30.0	27.2	29.9	6.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
28.4	24.8	29.4	27.5	23.4	28.9	26.7	22.4	28.8	93.6	30.8	89.8	29.7	86.2	29.9	33.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 9.4	8.4	7.7	DB	9.9	45.0	1.3	1.2	9.0	45.9	8.2	46.6	7.5	47.2	6.5	48.1	(4)
(5)			WB	3.6	29.9	1.1	1.5	2.8	31.0	2.1	31.9	1.5	32.8	0.7	33.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.6	21.9	23.4	25.1	25.9	27.2	28.0	27.8	29.0	30.2	30.0	26.8	23.4	(6)	
	DBStd	3.77	2.53	2.65	3.23	3.54	3.55	3.52	2.12	1.64	2.17	2.53	2.45	2.45	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	2	2	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	6048	370	376	469	477	533	539	551	589	605	619	505	414	(10)	
	CDD18.3	3008	114	142	211	227	274	289	293	331	355	361	255	156	(11)	
	CDH23.3	30295	1117	1372	1916	1847	2343	2629	2819	3830	4420	4111	2493	1398	(12)	
	CDH26.7	14191	426	628	1029	974	1245	1252	922	1537	2167	2164	1282	564	(13)	
(14) Wind	WSAvg	4.5	4.5	4.9	4.8	5.2	5.2	4.9	4.6	4.2	4.0	4.1	3.8	4.1	(14)	
(15) Precipitation	PrecAvg	112	1	2	0	0	0	2	11	45	40	5	3	3	(15)	
	PrecMax	230	12	25	2	2	2	17	40	128	120	38	36	68	(16)	
	PrecMin	21	0	0	0	0	0	0	0	2	2	0	0	0	(17)	
	PrecStd	59	3	5	0	0	0	5	12	33	35	10	8	13	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.8	37.1	40.1	41.9	43.1	44.2	40.2	38.1	42.0	42.0	39.1	35.2	(19)	
		MCWB	17.3	16.4	18.0	18.7	19.6	20.3	21.5	23.8	21.8	20.2	18.8	17.5	(20)	
	2%	DB	32.6	34.4	37.2	38.8	39.9	40.8	34.1	34.9	38.9	40.1	37.1	33.2	(21)	
		MCWB	15.3	15.2	16.7	18.2	19.2	20.1	23.3	25.2	23.1	20.3	18.7	17.3	(22)	
	5%	DB	30.9	32.8	35.1	35.5	36.2	36.2	31.9	33.0	35.8	38.1	35.2	31.8	(23)	
		MCWB	14.6	14.8	16.1	18.3	19.2	20.8	24.3	25.8	24.3	20.6	18.3	16.6	(24)	
	10%	DB	29.1	30.9	32.8	32.2	33.1	32.8	30.4	31.9	33.8	35.9	33.4	30.0	(25)	
		MCWB	14.2	14.6	16.2	18.7	19.5	21.5	24.4	25.8	25.2	21.0	17.8	15.8	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.6	21.2	22.3	23.5	24.7	27.1	28.3	30.1	30.2	28.8	24.9	23.2	(27)	
		MCDB	26.9	25.3	28.0	29.1	29.9	29.9	29.8	30.9	31.4	30.7	28.6	26.6	(28)	
	2%	WB	19.4	19.7	21.0	22.2	23.4	25.8	27.1	28.7	28.9	27.2	23.2	21.4	(29)	
		MCDB	24.0	24.0	26.1	27.6	28.6	28.6	29.0	30.0	30.8	30.1	27.8	26.0	(30)	
	5%	WB	18.1	18.7	20.1	21.2	22.4	25.0	26.3	27.8	28.1	26.3	22.1	20.2	(31)	
		MCDB	23.2	23.4	25.3	27.0	27.8	28.1	28.5	29.6	30.4	29.8	26.7	25.3	(32)	
	10%	WB	16.8	17.7	19.4	20.4	21.6	24.2	25.7	27.1	27.4	25.3	21.1	19.0	(33)	
		MCDB	23.0	22.9	24.7	26.1	27.3	27.6	28.2	29.7	30.2	29.3	26.4	24.9	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	14.2	14.0	14.2	13.2	12.9	10.6	6.6	6.6	8.5	11.9	13.5	13.5	(35)	
		MCDBR	16.5	16.7	17.6	17.1	16.9	16.6	9.8	8.9	12.0	15.0	15.7	15.6	(36)	
	5% WB	MCWBR	7.9	7.6	7.0	6.3	6.2	6.3	5.0	4.8	6.3	6.8	6.7	7.1	(37)	
		MCWBR	13.4	12.9	13.9	13.1	12.1	9.4	6.8	6.8	8.2	10.6	12.7	12.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.504	0.501	0.555	0.583	0.661	0.771	0.801	0.759	0.716	0.618	0.487	0.490	(40)	
		taud	1.834	1.854	1.747	1.732	1.588	1.460	1.449	1.529	1.584	1.719	1.966	1.906	(41)	
	Edn at Noon		767	800	773	754	689	611	594	623	644	692	779	765	(42)	
		Edh at Noon	197	203	234	239	273	307	311	289	271	230	171	179	(43)	
(44) All-Sky Solar Radiation	RadAvg		5.08	5.82	6.85	7.45	7.60	7.39	7.06	6.79	6.40	5.99	5.18	4.73	(44)	
	RadStd		0.33	0.31	0.25	0.20	0.21	0.28	0.17	0.18	0.24	0.23	0.30	0.23	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page