

CAP SKIRRING, Senegal

WMO: 616970

Lat: 12.395N

Lon: 16.748W

Elev: 52

StdP: 14.67

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	63.4	64.6	40.6	37.3	77.6	43.7	42.0	77.4	20.3	77.7	18.6	77.4	6.5	0	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	12.3	93.5	70.5	91.7	73.5	90.3	75.6	82.5	88.5	81.7	87.7	81.0	87.0	8.0	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
80.8	160.2	86.7	80.0	156.0	86.0	79.2	151.7	85.2	46.3	88.5	45.4	88.3	44.8	87.7	86.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
16.3	14.2	12.4	DB	59.7	100.5	3.2	2.0	57.3	102.0	55.4	103.2	53.6	104.3	51.2	105.8	
			WB	50.9	84.5	2.0	1.0	49.4	85.2	48.2	85.8	47.1	86.4	45.6	87.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	79.8	76.8	76.8	76.6	76.6	78.6	82.5	82.2	81.6	81.9	83.5	82.1	78.1	(6)
	DBStd	3.61	2.68	3.33	3.02	2.69	2.91	2.12	1.99	1.91	1.94	1.91	2.03	2.62	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
	CDD50	10872	831	749	823	798	887	976	1000	980	957	1037	963	871	(10)
	CDD65	5397	366	329	358	348	422	526	535	515	507	572	513	406	(11)
	CDH74	50053	2609	2261	2286	2046	3173	5778	5944	5411	5458	6715	5258	3114	(12)
	CDH80	17413	1057	918	754	516	788	1974	1919	1488	1779	2741	2204	1275	(13)
(14) Wind	WSAvg	6.4	7.4	8.0	7.3	7.5	6.8	6.2	6.0	6.3	5.4	4.6	4.9	6.8	(14)
(15) Precipitation	PrecAvg	52.2	0.0	0.0	0.0	0.0	0.2	2.8	13.2	18.1	12.9	5.2	0.2	0.0	(15)
	PrecMax	73.0	0.4	0.0	0.0	0.0	1.2	6.4	19.3	31.5	23.0	10.4	1.7	0.0	(16)
	PrecMin	35.3	0.0	0.0	0.0	0.0	0.0	0.2	4.7	11.1	8.4	0.8	0.0	0.0	(17)
	PrecStd	9.4	0.1	0.0	0.0	0.0	0.2	1.7	4.1	5.0	3.7	2.6	0.4	0.0	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	94.8	96.3	95.8	91.6	89.9	90.9	89.7	89.2	90.4	92.5	94.5	94.6	(19)
		MCWB	68.3	67.1	68.9	71.3	76.3	78.7	80.1	80.8	81.4	79.2	72.6	71.0	(20)
	2%	DB	91.5	92.5	90.0	87.8	87.8	89.4	88.3	87.9	89.3	91.2	92.1	91.6	(21)
		MCWB	67.8	66.7	69.2	71.9	76.8	79.1	79.7	80.3	81.1	80.5	74.5	70.2	(22)
	5%	DB	88.8	89.1	87.1	84.9	86.0	88.2	87.8	86.9	88.1	90.0	90.7	89.4	(23)
		MCWB	67.6	66.7	69.4	71.8	76.3	79.0	79.6	79.9	80.6	80.5	76.0	69.7	(24)
	10%	DB	85.9	86.0	84.2	82.7	84.4	87.5	86.8	86.0	87.3	89.4	89.4	87.1	(25)
		MCWB	67.5	67.2	70.6	72.2	75.5	78.8	79.1	79.4	80.2	80.5	76.8	70.1	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	76.5	75.6	76.7	76.9	80.1	82.8	81.8	82.2	82.8	83.6	82.5	80.1	(27)
		MCDB	84.6	83.3	84.2	84.3	87.3	87.3	87.2	87.4	88.4	89.7	89.3	86.7	(28)
	2%	WB	74.5	73.6	74.8	75.2	78.7	80.9	80.8	81.0	81.8	82.6	81.3	77.3	(29)
		MCDB	83.1	81.8	82.3	82.0	85.1	87.0	86.7	86.2	87.5	88.9	88.0	83.9	(30)
	5%	WB	72.7	72.0	73.5	74.1	77.8	80.0	80.1	80.5	81.1	81.8	80.2	75.4	(31)
		MCDB	81.7	80.9	80.8	81.0	83.9	86.3	85.9	85.6	86.8	88.1	86.8	82.4	(32)
	10%	WB	70.8	70.2	72.3	72.9	76.6	79.3	79.6	79.9	80.5	81.2	79.2	73.6	(33)
		MCDB	79.9	79.6	79.9	79.9	82.5	85.5	85.2	84.6	86.2	87.4	85.4	80.8	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	22.1	21.1	18.0	14.9	11.6	10.1	9.4	8.6	10.7	12.3	16.1	20.2	(35)
		MCDBR	25.6	26.4	23.1	18.6	13.4	11.0	10.2	10.0	11.9	13.0	18.4	23.3	(36)
		MCWBR	12.6	12.2	9.9	6.8	5.3	4.9	4.9	5.2	6.2	6.1	8.0	10.7	(37)
	5% WB	MCDBR	22.2	21.6	18.4	14.3	10.8	10.3	10.0	9.4	11.2	12.2	14.1	19.8	(38)
		MCWBR	12.1	11.5	9.4	6.7	5.2	5.2	5.2	5.4	6.3	6.5	7.1	10.1	(39)
(40) Clear-Sky Solar Irradiance	taub		0.539	0.583	0.667	0.659	0.680	0.672	0.598	0.541	0.532	0.575	0.542	0.516	(40)
	taud		1.916	1.826	1.669	1.734	1.705	1.785	1.962	2.129	2.135	1.991	2.011	2.025	(41)
	Ebn at Noon		243	238	222	222	213	212	230	247	251	237	240	246	(42)
	Edh at Noon		60	68	82	76	76	70	59	50	50	57	54	53	(43)
(44) All-Sky Solar Radiation	RadAvg		1726	1923	2145	2216	2136	1868	1556	1495	1600	1730	1686	1634	(44)
(45)	RadStd		88	79	66	49	79	83	90	98	79	78	77	80	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page