

CAP SKIRRING, Senegal

WMO: 616970

Lat: 12.395N

Lon: 16.748W

Elev: 16

StdP: 101.14

Time Zone: 0.00 (E00)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	17.4	18.1	4.8	5.3	25.4	6.5	6.0	25.2	9.1	25.4	8.3	25.2	2.9	0	0.342

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
10	6.8	34.2	21.4	33.2	23.1	32.4	24.2	28.0	31.4	27.6	31.0	27.2	30.6	3.6	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.1	22.9	30.4	26.7	22.3	30.0	26.2	21.7	29.6	89.8	31.4	87.6	31.3	86.3	30.9	30.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 7.3	6.3	5.6	15.4	38.1	1.8	1.1	14.1	38.9	13.0	39.5	12.0	40.2	10.7	41.0		
(5)			10.5	29.2	1.1	0.6	9.7	29.6	9.0	29.9	8.4	30.2	7.6	30.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	26.5	24.9	24.9	24.8	24.8	25.9	28.1	27.9	27.6	27.7	28.6	27.8	25.6
	DBStd	2.00	1.49	1.85	1.68	1.50	1.61	1.18	1.10	1.06	1.08	1.06	1.13	1.45
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6040	462	416	457	443	493	542	556	544	532	576	535	484
	CDD18.3	2998	203	183	199	193	234	292	297	286	282	318	285	226
	CDH23.3	27807	1449	1256	1270	1137	1763	3210	3302	3006	3032	3731	2921	1730
	CDH26.7	9674	587	510	419	287	438	1097	1066	827	988	1523	1224	708
Wind	WSAvg	2.9	3.3	3.6	3.3	3.4	3.1	2.8	2.7	2.8	2.4	2.0	2.2	3.0
Precipitation	PrecAvg	1327	1	0	0	0	5	71	336	459	327	132	5	0
	PrecMax	1855	10	1	1	0	30	163	489	799	585	264	44	1
	PrecMin	897	0	0	0	0	0	5	119	283	214	21	0	0
	PrecStd	238	2	0	0	0	6	43	103	127	93	65	9	0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.9	35.7	35.4	33.1	32.2	32.7	32.1	31.8	32.5	33.6	34.7	34.8
		MCWB	20.1	19.5	20.5	21.8	24.6	26.0	26.7	27.1	27.4	26.2	22.5	21.7
	2%	DB	33.1	33.6	32.2	31.0	31.0	31.9	31.3	31.1	31.8	32.9	33.4	33.1
		MCWB	19.9	19.3	20.7	22.1	24.9	26.2	26.5	26.8	27.3	27.0	23.6	21.2
	5%	DB	31.6	31.7	30.6	29.4	30.0	31.2	31.0	30.5	31.2	32.2	32.6	31.9
		MCWB	19.8	19.3	20.8	22.1	24.6	26.1	26.4	26.6	27.0	27.0	24.4	21.0
	10%	DB	29.9	30.0	29.0	28.2	29.1	30.8	30.4	30.0	30.7	31.9	31.9	30.6
		MCWB	19.7	19.6	21.5	22.3	24.2	26.0	26.1	26.3	26.8	26.9	24.9	21.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	24.7	24.2	24.9	25.0	26.7	28.2	27.7	27.9	28.2	28.7	28.1	26.7
		MCDB	29.2	28.5	29.0	29.0	30.7	30.7	30.7	30.8	31.4	32.0	31.8	30.4
	2%	WB	23.6	23.1	23.8	24.0	25.9	27.2	27.1	27.2	27.7	28.1	27.4	25.2
		MCDB	28.4	27.7	27.9	27.8	29.5	30.6	30.4	30.1	30.8	31.6	31.1	28.8
	5%	WB	22.6	22.2	23.1	23.4	25.4	26.7	26.7	26.9	27.3	27.7	26.8	24.1
		MCDB	27.6	27.2	27.1	27.2	28.8	30.2	29.9	29.8	30.4	31.2	30.4	28.0
	10%	WB	21.6	21.2	22.4	22.7	24.8	26.3	26.5	26.6	27.0	27.3	26.2	23.1
		MCDB	26.6	26.4	26.6	26.6	28.0	29.7	29.5	29.2	30.1	30.8	29.7	27.1
Mean Daily Temperature Range	5% DB	MDBR	12.3	11.7	10.0	8.3	6.4	5.6	5.2	4.8	5.9	6.8	9.0	11.2
		MCDBR	14.2	14.6	12.8	10.3	7.5	6.1	5.7	5.5	6.6	7.2	10.2	13.0
		MCWBR	7.0	6.8	5.5	3.8	3.0	2.7	2.7	2.9	3.4	3.4	4.5	5.9
	5% WB	MCDBR	12.4	12.0	10.2	7.9	6.0	5.7	5.5	5.2	6.2	6.8	7.8	11.0
		MCWBR	6.7	6.4	5.2	3.7	2.9	2.9	2.9	3.0	3.5	3.6	4.0	5.6
Clear-Sky Solar Irradiance	taub	0.539	0.583	0.667	0.659	0.680	0.672	0.598	0.541	0.532	0.575	0.542	0.516	
	taud	1.916	1.826	1.669	1.734	1.705	1.785	1.962	2.129	2.135	1.991	2.011	2.025	
	Ebn at Noon	765	750	699	701	673	669	725	778	790	747	758	774	
	Edh at Noon	190	215	257	239	241	220	185	159	159	180	171	167	
All-Sky Solar Radiation	RadAvg	5.44	6.06	6.76	6.99	6.74	5.89	4.91	4.71	5.04	5.45	5.31	5.15	
	RadStd	0.28	0.25	0.21	0.15	0.25	0.26	0.28	0.31	0.25	0.25	0.24	0.25	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (2 neighbors)		(m) N/A	(n) N/A	(o) N/A	(p) N/A	(q) N/A	(r) N/A	(s) N/A	(t) N/A	(u) N/A

Nomenclature: See separate page