

DIEGO GARCIA, British Indian Ocean Territory

WMO: 619670

Lat: 7.300S

Lon: 72.400E

Elev: 14

StdP: 14.69

Time Zone: 6.00 (E06)

Period: 94-19

WBAN: 70701

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	74.8	75.1	67.6	101.5	80.7	68.9	106.2	79.8	23.3	80.4	21.9	80.9	8.9	130	0.462

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	9.8	92.4	82.4	91.2	81.8	89.9	81.1	84.0	90.2	83.2	89.1	82.5	88.1	7.7	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
82.4	169.1	88.6	81.4	163.6	87.4	80.8	160.2	86.5	48.1	90.6	47.1	89.7	46.4	88.3	89.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.0	19.0	17.7	71.4	95.8	2.6	2.5	69.6	97.6	68.1	99.1	66.7	100.5	64.8	102.3		
(5)			69.0	85.8	2.0	1.5	67.5	86.8	66.3	87.7	65.2	88.5	63.7	89.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	82.6	82.8	83.2	84.1	84.0	83.2	82.0	80.9	80.7	81.2	82.3	83.1	83.2
	DBStd	2.29	2.41	2.34	2.16	1.80	1.86	1.70	1.64	1.61	1.76	2.19	2.22	2.24
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11882	1015	931	1056	1020	1030	961	958	953	935	1002	992	1029
	CDD65	6407	550	511	591	570	565	511	493	488	485	537	542	564
	CDH74	68601	6014	5771	6944	6682	6321	5229	4647	4494	4702	5602	5949	6246
	CDH80	20964	1935	1993	2639	2484	2070	1323	946	872	1043	1605	1956	2098
Wind	WSAvg	9.1	8.2	8.3	7.0	6.7	8.5	10.8	12.1	12.3	10.9	9.1	7.8	7.1
Precipitation	PrecAvg	109.6	14.2	12.4	9.1	8.0	8.1	6.5	4.8	5.1	9.6	11.1	10.9	10.4
	PrecMax	149.6	23.9	21.2	15.0	17.2	15.2	17.4	16.5	17.0	27.0	22.5	23.0	22.8
	PrecMin	80.2	7.5	6.6	3.4	1.1	2.2	1.5	0.7	0.7	1.7	0.8	1.1	0.6
	PrecStd	22.0	4.4	4.2	3.0	4.0	4.6	4.2	3.9	4.6	6.5	5.5	6.1	5.6
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	92.6	94.2	93.5	93.1	91.6	90.0	88.1	88.0	89.8	92.0	92.9	93.0
		MCWB	82.7	83.9	83.2	82.9	81.9	81.3	80.4	80.3	80.8	81.4	81.6	83.3
	2%	DB	90.2	91.3	91.6	90.9	89.7	88.0	86.4	86.3	87.6	89.8	90.4	90.5
		MCWB	81.5	81.9	82.4	81.9	81.5	80.6	79.5	79.2	80.0	80.6	80.7	81.3
	5%	DB	88.9	89.5	89.8	89.4	88.1	86.4	85.6	85.5	86.1	88.0	89.2	89.2
		MCWB	80.9	81.1	81.3	81.3	80.7	79.6	79.1	78.6	79.0	79.8	80.3	80.6
	10%	DB	87.5	87.8	88.2	88.0	87.2	85.6	84.4	84.3	84.7	86.4	87.6	87.7
		MCWB	80.3	80.6	80.6	80.6	80.2	79.0	78.3	77.8	78.2	79.1	79.9	80.2
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	84.3	85.0	85.0	84.6	83.5	82.8	82.4	82.1	82.5	83.3	83.6	84.2
		MCDB	90.9	91.6	91.5	90.6	89.4	87.8	86.4	86.2	86.8	88.7	90.1	90.3
	2%	WB	82.8	83.3	83.5	83.3	82.4	81.6	80.9	80.6	80.9	81.8	82.2	82.7
		MCDB	88.5	89.5	89.9	89.1	87.9	86.2	84.5	84.8	85.6	87.3	88.3	88.7
	5%	WB	81.8	82.1	82.4	82.3	81.6	80.6	79.9	79.5	79.9	80.6	81.2	81.6
		MCDB	87.0	87.8	88.5	87.7	86.6	84.8	83.5	83.6	84.5	86.2	87.1	87.1
	10%	WB	80.9	81.1	81.4	81.4	80.7	79.7	79.1	78.7	79.1	79.7	80.2	80.6
		MCDB	85.7	86.1	86.9	86.4	85.3	83.8	82.7	82.6	83.3	84.7	85.7	85.6
Mean Daily Temperature Range	5% DB	MDBR	9.6	9.7	9.8	9.3	8.8	7.9	7.8	7.8	8.3	9.2	9.7	9.7
		MCDBR	11.4	11.7	11.4	10.8	9.9	9.0	8.8	8.9	9.8	11.0	11.6	11.4
		MCWBR	6.3	6.3	6.4	6.0	5.5	5.3	5.2	5.1	5.6	6.0	6.0	6.2
	5% WB	MCDBR	10.4	10.8	10.8	9.8	9.5	8.5	8.1	8.4	9.2	10.1	10.8	10.6
		MCWBR	6.3	6.5	6.5	6.1	5.6	5.6	5.3	5.4	5.8	6.1	6.2	6.2
Clear-Sky Solar Irradiance	taub	0.393	0.400	0.389	0.390	0.400	0.414	0.426	0.430	0.441	0.434	0.415	0.393	
	taud	2.606	2.580	2.624	2.624	2.574	2.519	2.464	2.456	2.428	2.458	2.524	2.600	
	Ebn at Noon	300	297	296	287	275	266	265	272	277	283	291	299	
	Edh at Noon	33	34	32	30	30	31	34	36	38	37	35	33	
All-Sky Solar Radiation	RadAvg	1757	1844	1922	1797	1673	1549	1547	1702	1669	1803	1856	1787	
	RadStd	179	199	107	81	106	104	118	82	134	137	157	153	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	+0.56	+1.96	+0.85	+1.42	+1.17	N/A	N/A	+198	+198
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page