

ILE JUAN DE NOVA, French Southern Territories

WMO: 619700

Lat: 17.055S

Lon: 42.712E

Elev: 33

StdP: 14.68

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	70.5	71.9	58.5	73.4	77.2	60.3	78.2	77.2	23.9	76.4	22.5	76.1	3.0	100	0.425

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	8.8	90.6	80.3	89.8	80.0	89.1	79.6	81.7	88.4	81.0	87.7	80.6	87.3	8.1	220

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.9	155.2	86.1	79.2	151.5	85.6	78.7	149.0	85.3	45.4	88.7	44.8	88.0	44.3	87.6	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
22.7	20.1	17.9	DB	67.3	93.1	2.5	3.5	65.6	95.6	64.1	97.7	62.8	99.7	61.0	102.2	
			WB	62.0	83.1	2.4	1.2	60.3	84.0	58.9	84.6	57.6	85.3	55.9	86.1	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.3	83.4	83.3	84.0	83.4	81.4	79.1	77.8	77.3	78.6	80.4	82.7	83.9
	DBStd	2.92	2.07	1.95	1.75	1.59	1.63	1.42	1.50	1.40	1.27	1.51	1.42	1.76
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	11414	1035	933	1055	1002	972	874	861	847	859	943	981	1052
	CDD65	5939	570	513	590	552	507	424	396	382	409	478	531	587
	CDH74	60693	6854	6156	7240	6447	5041	3324	2469	2344	3144	4530	5998	7146
	CDH80	18759	2571	2296	2910	2270	1181	473	215	235	553	1152	2047	2856
(14) Wind	WSAvg	8.9	8.3	7.9	7.6	9.5	10.4	10.8	10.9	9.4	8.7	8.5	7.9	6.8
(15) Precipitation	PrecAvg	32.0	9.8	9.2	4.6	1.7	0.4	0.4	0.3	0.2	0.1	0.3	0.4	3.7
	PrecMax	57.4	34.3	35.2	12.5	8.7	2.2	2.4	2.4	1.2	1.2	4.3	2.9	21.6
	PrecMin	10.3	0.9	1.4	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.4
	PrecStd	12.4	7.3	7.6	3.2	1.9	0.6	0.6	0.5	0.3	0.3	0.9	0.8	4.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	91.1	90.8	91.4	90.4	87.8	85.4	83.9	84.2	85.5	87.6	89.8	91.5
		MCWB	80.5	80.5	81.3	80.4	77.3	74.0	72.8	72.6	74.9	77.0	79.0	80.0
	2%	DB	90.1	89.7	90.1	89.0	86.8	84.4	82.8	83.1	84.6	86.6	88.9	90.4
		MCWB	80.3	80.3	80.5	79.3	76.5	73.7	72.1	72.4	74.3	76.5	78.5	79.8
	5%	DB	89.0	88.8	89.3	88.1	85.9	83.5	82.1	82.3	83.9	85.9	88.1	89.5
		MCWB	79.9	79.9	80.0	78.8	75.9	73.2	71.7	72.2	73.9	76.1	78.1	79.5
	10%	DB	88.0	87.8	88.4	87.2	85.0	82.7	81.2	81.4	83.1	85.1	87.3	88.6
		MCWB	79.5	79.6	79.5	78.3	75.3	72.7	71.3	71.8	73.5	75.6	77.7	79.2
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	82.1	82.5	82.8	81.8	79.1	76.7	74.9	75.2	76.9	78.7	80.3	81.7
		MCDB	88.7	88.2	89.6	88.6	85.9	83.1	81.8	81.6	83.8	85.9	88.1	89.4
	2%	WB	81.2	81.6	81.6	80.8	78.0	75.5	73.9	74.3	76.0	77.8	79.6	80.9
		MCDB	87.7	87.4	88.5	87.2	84.9	82.1	80.5	80.7	82.7	84.8	87.2	88.6
	5%	WB	80.7	80.9	80.9	80.0	77.2	74.8	73.3	73.6	75.3	77.2	79.0	80.2
		MCDB	87.2	86.7	87.7	86.4	84.0	81.4	79.8	80.0	81.9	84.0	86.4	87.7
	10%	WB	80.1	80.3	80.2	79.3	76.4	74.2	72.7	72.9	74.6	76.5	78.3	79.7
		MCDB	86.3	86.1	86.8	85.6	83.2	80.8	79.3	79.3	81.1	83.1	85.5	86.9
(35) Mean Daily Temperature Range	5% DB	MDBR	8.4	8.6	8.8	7.8	7.7	7.7	7.6	8.8	9.6	9.8	9.7	9.5
		MCDBR	9.8	9.6	9.5	8.6	8.1	8.3	8.2	9.7	10.2	10.4	10.4	10.3
	5% WB	MCWBR	4.0	4.2	4.2	3.8	3.7	4.1	4.1	4.3	4.1	4.1	3.9	3.8
		MCDWR	8.7	8.9	9.0	8.3	7.9	7.8	7.9	9.0	9.7	9.9	9.8	9.9
(40) Clear-Sky Solar Irradiance	taub	taub	0.431	0.417	0.394	0.374	0.358	0.346	0.350	0.368	0.416	0.442	0.439	0.414
		taud	2.478	2.521	2.594	2.627	2.625	2.628	2.604	2.537	2.392	2.347	2.392	2.509
	Ebn at Noon	Ebn at Noon	291	292	292	286	280	279	280	284	280	281	286	295
		Edh at Noon	37	36	32	29	27	26	28	31	38	42	41	36
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1857	1943	1922	1820	1640	1497	1553	1788	2062	2246	2321	2189
	RadStd	RadStd	192	167	138	93	38	45	49	54	35	65	111	146

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page