

ILE EUROPA, French Southern Territories

WMO: 619720

Lat: 22.344S

Lon: 40.341E

Elev: 6

StdP: 101.25

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	17.8	18.4	10.9	8.1	21.6	11.9	8.7	21.9	11.1	22.6	10.3	22.8	2.3	160	0.378

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	5.1	32.3	26.1	31.7	25.9	31.2	25.7	27.2	30.6	26.8	30.2	26.5	29.9	3.8	140

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.2	21.7	29.4	25.9	21.2	29.2	25.5	20.8	29.0	86.0	30.7	84.3	30.4	82.9	30.1	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.5	9.4	8.5	DB	15.8	34.6	1.2	1.7	15.0	35.8	14.3	36.8	13.6	37.7	12.8	38.9	(4)
(5)			WB	13.2	28.0	0.6	0.6	12.8	28.4	12.4	28.8	12.0	29.1	11.6	29.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	25.4	28.4	28.3	27.9	26.3	24.5	23.2	22.4	22.5	23.4	24.6	26.2	27.4	(6)	
	DBStd	2.43	1.03	1.06	1.08	1.30	1.11	1.06	0.98	0.98	1.10	1.18	1.15	1.14	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	5623	570	513	554	489	449	395	383	389	403	453	486	539	(10)	
	CDD18.3	2581	312	280	296	239	191	145	125	131	153	195	236	281	(11)	
	CDH23.3	21591	3685	3257	3229	2072	1088	539	327	407	728	1194	2074	2990	(12)	
	CDH26.7	5827	1367	1178	1042	476	112	16	3	11	54	163	480	926	(13)	
(14) Wind	WSAvg	4.2	4.3	4.5	4.4	4.4	4.0	4.0	4.3	4.0	4.2	4.4	4.3	4.0	(14)	
(15) Precipitation	PrecAvg	555	132	116	68	27	23	14	11	6	8	7	27	101	(15)	
	PrecMax	860	497	601	214	122	115	52	39	36	65	29	122	294	(16)	
	PrecMin	213	0	9	0	2	0	0	0	0	0	0	0	6	(17)	
	PrecStd	188	116	122	58	29	28	12	11	7	13	8	30	85	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.9	33.1	32.7	31.9	29.3	27.8	27.1	27.8	29.0	29.8	31.4	32.2	(19)	
		MCWB	26.3	26.5	26.4	26.2	23.4	22.2	21.4	21.1	22.2	23.4	24.6	25.9	(20)	
	2%	DB	32.2	32.2	31.9	30.9	28.5	27.1	26.3	26.7	27.9	28.9	30.4	31.5	(21)	
		MCWB	26.1	26.0	26.1	25.4	22.9	21.7	21.1	21.2	22.6	23.6	24.8	25.6	(22)	
	5%	DB	31.6	31.6	31.2	29.9	27.8	26.5	25.7	26.0	27.2	28.3	29.7	30.8	(23)	
		MCWB	25.9	25.8	25.8	24.6	22.5	21.3	20.7	21.0	22.4	23.2	24.6	25.4	(24)	
	10%	DB	31.0	30.9	30.5	29.1	27.2	25.9	25.1	25.4	26.5	27.6	29.0	30.1	(25)	
		MCWB	25.8	25.7	25.4	23.9	22.1	20.8	20.2	20.6	22.0	22.8	24.2	25.0	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.6	27.7	27.5	26.7	25.2	24.0	23.0	23.2	24.5	25.4	26.8	27.2	(27)	
		MCDB	31.2	31.3	30.8	30.7	27.8	26.7	25.6	25.6	27.1	28.2	29.3	30.3	(28)	
	2%	WB	27.2	27.2	26.8	26.0	24.2	23.0	22.2	22.6	23.8	24.7	26.2	26.7	(29)	
		MCDB	30.6	30.7	30.6	30.0	27.3	25.8	25.1	25.2	26.5	27.5	28.7	29.7	(30)	
	5%	WB	26.7	26.7	26.4	25.3	23.5	22.3	21.6	22.0	23.2	24.1	25.6	26.2	(31)	
		MCDB	30.1	30.1	30.1	28.9	26.9	25.5	24.8	24.9	26.0	27.2	28.3	29.5	(32)	
	10%	WB	26.4	26.3	26.0	24.7	22.9	21.6	21.0	21.4	22.7	23.5	25.1	25.8	(33)	
		MCDB	29.9	29.6	29.7	28.1	26.4	25.1	24.4	24.6	25.7	26.7	28.1	29.1	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	5.1	5.3	5.2	5.5	5.7	5.7	5.8	6.1	6.4	5.8	5.7	5.5	(35)	
		MCDBR	5.9	6.1	6.2	6.4	6.4	6.5	6.6	6.9	7.4	6.7	6.4	6.1	(36)	
	5% WB	MCWBR	2.2	2.4	2.4	2.7	3.0	3.2	3.3	3.3	3.5	3.1	2.8	2.5	(37)	
		MCWBR	4.9	5.3	5.7	6.2	5.8	6.0	6.2	6.2	6.8	6.4	5.6	5.3	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.430	0.423	0.403	0.375	0.348	0.334	0.337	0.363	0.417	0.440	0.421	0.411	(40)	
		taud	2.456	2.470	2.525	2.574	2.606	2.624	2.604	2.500	2.326	2.300	2.414	2.485	(41)	
	Ebn at Noon		917	910	903	888	875	870	878	887	875	885	919	936	(42)	
		Edh at Noon	121	117	106	94	84	79	83	99	127	137	125	118	(43)	
(44) All-Sky Solar Radiation	RadAvg		7.22	7.00	6.40	5.42	4.63	4.21	4.43	5.32	6.19	6.87	7.37	7.44	(44)	
	RadStd		0.48	0.41	0.38	0.18	0.14	0.12	0.10	0.10	0.15	0.28	0.28	0.38	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page