

AGALEGA, Mauritius

WMO: 619740

Lat: 10.380S

Lon: 56.610E

Elev: 4

StdP: 101.28

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	22.0	22.8	18.2	13.1	25.1	18.9	13.7	25.2	8.7	26.1	8.3	26.2	1.7	150	0.397

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	5.6	32.1	26.8	31.7	26.6	31.4	26.4	27.6	31.1	27.2	30.7	27.0	30.5	3.1	120

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.5	22.1	29.9	26.2	21.6	29.5	25.9	21.3	29.3	87.3	31.2	86.0	31.0	84.8	30.6	29.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 8.0	7.3	6.9	19.6	33.2	0.9	1.0	18.9	33.9	18.3	34.4	17.8	35.0	17.1	35.6		
(5)			18.5	28.2	1.1	0.6	17.7	28.6	17.1	28.9	16.5	29.2	15.7	29.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	27.3	27.8	27.9	28.1	28.1	27.9	26.8	26.0	26.0	26.5	27.1	27.6	27.8		
	DBStd	1.19	0.91	0.92	0.91	1.00	1.03	0.91	0.82	0.87	0.84	0.85	1.00	0.96		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD10.0	6314	553	500	560	544	554	504	497	496	494	530	529	552		
	CDD18.3	3272	294	267	302	294	296	254	239	237	244	272	279	294		
	CDH23.3	32106	3206	2879	3318	3244	3166	2274	1774	1705	1936	2499	2882	3222		
	CDH26.7	8794	1032	935	1169	1123	915	399	221	222	332	548	811	1087		
(14) Wind	WSAvg	3.5	1.8	2.0	1.8	2.5	3.7	4.7	4.6	5.1	5.1	4.5	3.6	2.3		
(15) Precipitation	PrecAvg	1702	267	256	187	165	126	93	91	57	55	82	111	214		
	PrecMax	2788	497	455	361	503	339	224	207	146	137	377	324	711		
	PrecMin	1036	110	85	67	38	25	26	30	18	9	20	20	14		
	PrecStd	348	97	105	69	98	85	52	47	30	32	69	74	167		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.1	32.5	32.6	32.4	31.6	30.5	29.6	29.6	30.1	31.0	31.9	32.4		
		MCWB	26.7	27.3	27.1	27.2	26.5	25.4	24.3	23.9	24.3	25.9	26.5	26.5		
	2%	DB	31.5	31.7	32.0	31.8	31.1	29.8	29.0	29.0	29.5	30.3	31.2	31.8		
		MCWB	26.5	26.8	26.9	26.9	26.2	25.0	24.0	23.6	24.0	25.1	26.0	26.3		
	5%	DB	31.1	31.2	31.5	31.3	30.6	29.3	28.5	28.4	29.0	29.8	30.7	31.3		
		MCWB	26.3	26.5	26.7	26.6	26.0	24.7	23.7	23.5	23.8	24.7	25.7	26.1		
	10%	DB	30.6	30.7	31.0	30.8	30.1	28.8	28.0	27.9	28.6	29.3	30.1	30.8		
		MCWB	26.2	26.4	26.5	26.4	25.7	24.4	23.5	23.3	23.6	24.5	25.4	25.9		
	0.4%	WB	27.5	28.0	27.9	28.0	27.2	26.4	25.6	25.4	25.9	26.7	27.2	27.6		
		MCDB	31.0	31.6	31.5	31.5	30.5	29.3	28.3	28.0	28.6	29.9	30.9	31.1		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	27.0	27.3	27.4	27.4	26.9	25.9	24.9	24.7	25.2	26.1	26.7	27.1		
		MCDB	30.6	30.8	31.0	30.9	30.1	28.7	27.8	27.4	28.0	29.0	30.3	30.7		
	5%	WB	26.7	26.9	27.1	27.1	26.5	25.4	24.5	24.2	24.7	25.6	26.2	26.7		
		MCDB	30.1	30.5	30.7	30.6	29.6	28.2	27.3	27.1	27.6	28.4	29.5	30.1		
	10%	WB	26.4	26.6	26.8	26.7	26.1	25.0	24.1	23.8	24.2	25.2	25.9	26.3		
		MCDB	29.7	29.9	30.2	30.0	29.1	27.8	26.8	26.9	27.3	27.9	29.0	29.6		
	5% DB	MDBR	5.3	5.4	5.8	5.6	4.5	4.1	4.1	4.3	4.5	4.7	5.1	5.9		
		MCDBR	6.0	6.3	6.5	6.0	4.8	4.5	4.5	4.7	4.9	5.1	5.7	6.7		
		MCWBR	2.5	2.7	2.7	2.6	2.2	2.2	2.1	2.1	2.2	2.3	2.4	2.7		
		MCWBR	5.6	5.8	5.9	5.6	4.5	4.1	4.1	4.3	4.5	4.5	5.1	5.8		
(35) Mean Daily Temperature Range	5% WB	MCWBR	2.4	2.6	2.6	2.6	2.2	2.2	2.2	2.2	2.4	2.3	2.3	2.6		
		MCWBR	2.4	2.6	2.6	2.6	2.2	2.2	2.2	2.2	2.4	2.3	2.3	2.6		
	Clear-Sky Solar Irradiance	taub	0.399	0.407	0.392	0.387	0.397	0.413	0.414	0.409	0.416	0.420	0.404	0.391		
		taud	2.588	2.557	2.619	2.627	2.566	2.475	2.464	2.476	2.459	2.469	2.540	2.590		
(42) All-Sky Solar Radiation	RadAvg	Ebn at Noon	943	930	928	903	863	831	839	870	892	907	931	949		
		Edh at Noon	105	108	100	94	95	101	104	108	115	117	110	105		
(44)	RadStd	RadAvg	5.95	5.97	6.12	5.84	5.22	4.83	5.00	5.66	6.24	6.40	6.62	6.55		
(45)		RadStd	0.29	0.58	0.30	0.28	0.31	0.31	0.24	0.19	0.26	0.34	0.52	0.56		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Nomenclature: See separate page