

ILE TROMELIN, French Southern Territories

WMO: 619760

Lat: 15.888S

Lon: 54.521E

Elev: 43

StdP: 14.67

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	70.8	71.6	59.0	74.7	75.1	60.7	79.3	75.1	29.3	73.9	27.6	74.4	17.9	130	0.635

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.7	89.7	79.8	88.8	79.4	88.0	79.0	82.3	86.1	81.2	86.1	80.4	85.9	9.5	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
81.5	164.1	84.3	79.8	154.9	84.6	78.8	149.6	84.5	46.2	86.2	44.9	86.0	44.0	86.2	88.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.9	25.5	23.7	68.0	93.4	3.8	4.8	65.2	96.8	63.0	99.6	60.9	102.3	58.1	105.8		
(5)			61.4	82.5	1.5	1.6	60.3	83.6	59.4	84.5	58.6	85.4	57.5	86.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	79.9	83.5	83.7	83.5	82.4	80.3	77.5	75.8	75.6	76.3	78.1	80.2	82.5
	DBStd	3.43	1.98	1.97	1.71	1.45	1.47	1.56	1.33	1.31	1.46	1.55	1.76	1.61
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	10927	1039	943	1039	971	940	826	801	795	788	872	905	1008
	CDD65	5452	574	523	574	521	475	376	336	330	338	407	455	543
	CDH74	48776	6730	6261	6772	5752	4341	2286	1288	1157	1459	2644	4059	6027
	CDH80	12507	2387	2320	2384	1606	697	118	11	11	52	272	819	1830
Wind	WSAvg	14.9	12.8	11.3	12.8	14.0	15.5	17.4	18.7	17.9	16.8	15.7	13.6	12.3
Precipitation	PrecAvg	44.0	6.9	6.8	6.7	4.1	3.0	2.9	2.5	2.3	1.5	1.1	1.1	3.5
	PrecMax	67.6	20.9	20.6	18.9	10.1	8.3	12.6	6.1	8.3	4.0	3.7	5.3	10.8
	PrecMin	31.4	1.6	1.4	1.8	0.2	0.7	0.4	0.4	0.7	0.4	0.4	0.0	0.0
	PrecStd	9.1	4.6	4.9	4.1	2.3	2.0	2.2	1.4	1.5	0.8	0.8	1.1	2.4
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	90.8	91.0	90.0	88.3	86.4	83.3	81.0	81.0	82.3	84.5	87.7	89.8
		MCWB	80.6	80.9	80.1	78.5	78.2	74.2	72.0	71.4	72.1	74.7	78.2	79.1
	2%	DB	89.3	89.7	89.0	87.2	85.3	82.2	80.1	80.1	81.4	83.4	86.1	88.3
		MCWB	79.7	80.1	79.6	78.3	76.8	73.2	71.5	70.8	71.7	73.8	76.2	78.4
	5%	DB	88.3	88.7	88.1	86.4	84.3	81.4	79.5	79.4	80.6	82.6	85.0	87.2
		MCWB	79.3	79.5	79.3	78.0	75.7	72.7	71.2	70.6	71.4	73.2	75.4	77.8
	10%	DB	87.4	87.7	87.2	85.7	83.4	80.5	78.7	78.6	79.7	81.6	83.9	86.3
		MCWB	78.9	79.0	79.0	77.7	75.2	72.2	70.8	70.3	71.0	72.8	74.7	77.1
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	81.9	83.4	85.3	80.9	82.1	76.5	74.7	74.5	74.6	77.1	79.7	80.8
		MCDB	88.8	88.3	86.4	85.4	83.8	81.0	78.2	78.8	79.2	81.6	85.5	86.9
	2%	WB	81.0	82.1	82.8	80.0	79.7	75.5	73.8	73.1	73.5	75.9	78.2	79.8
		MCDB	87.5	86.5	85.0	84.9	82.6	80.0	78.0	77.9	78.9	80.7	84.0	85.9
	5%	WB	80.3	81.1	81.0	79.2	77.6	74.6	72.9	72.2	72.7	75.0	77.1	79.1
		MCDB	86.5	86.2	85.7	84.4	82.5	79.4	77.6	77.4	78.4	80.0	82.5	85.0
	10%	WB	79.7	80.2	80.0	78.6	76.5	73.7	72.1	71.5	71.9	74.1	76.2	78.4
		MCDB	85.6	85.7	85.4	84.0	81.8	79.1	77.1	76.9	77.9	79.6	81.9	84.2
Mean Daily Temperature Range	5% DB	MDBR	7.6	7.7	7.3	6.9	6.5	6.1	6.2	6.7	7.2	7.4	8.0	7.9
		MCDBR	8.6	8.8	8.1	7.5	7.1	6.5	6.8	7.2	7.7	7.9	8.4	8.6
		MCWBR	3.6	3.7	3.6	3.6	3.5	3.7	3.7	3.7	3.7	3.6	3.5	3.6
	5% WB	MCDBR	8.0	8.1	7.7	7.1	6.6	6.0	6.2	6.9	7.2	7.3	7.9	8.0
		MCWBR	3.7	4.1	4.0	3.7	3.6	3.9	3.8	4.0	4.0	3.8	3.7	3.7
Clear-Sky Solar Irradiance	taub	0.413	0.423	0.413	0.394	0.381	0.373	0.372	0.373	0.380	0.390	0.389	0.390	
	taud	2.531	2.496	2.532	2.575	2.589	2.568	2.569	2.557	2.518	2.505	2.543	2.572	
	Ebn at Noon	296	290	286	281	274	271	274	283	292	296	301	303	
	Edh at Noon	36	36	34	31	29	28	29	31	34	36	35	34	
All-Sky Solar Radiation	RadAvg	2151	2031	1941	1777	1578	1439	1487	1712	1967	2169	2324	2314	
	RadStd	144	162	95	101	69	38	42	43	43	67	73	95	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page