

ILE TROMELIN, French Southern Territories

WMO: 619760

Lat: 15.888S

Lon: 54.521E

Elev: 13

StdP: 101.17

Time Zone: 1.00 (EUC)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	21.5	22.0	15.0	10.7	23.9	15.9	11.3	23.9	13.1	23.3	12.3	23.5	8.0	130	0.635

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	4.3	32.0	26.6	31.6	26.3	31.1	26.1	28.0	30.1	27.3	30.1	26.9	30.0	4.2	110

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.5	23.4	29.0	26.6	22.1	29.2	26.0	21.4	29.2	89.5	30.1	86.6	30.0	84.6	30.1	31.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.5	11.4	10.6	DB	20.0	34.1	2.1	2.7	18.5	36.0	17.2	37.6	16.0	39.1	14.5	41.0	(4)
(5)			WB	16.3	28.0	0.8	0.9	15.7	28.7	15.2	29.2	14.8	29.7	14.1	30.3	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	26.6	28.6	28.7	28.6	28.0	26.8	25.3	24.4	24.2	24.6	25.6	26.8	28.1	(6)
(7)		DBStd	1.90	1.10	1.09	0.95	0.81	0.82	0.87	0.74	0.73	0.81	0.86	0.98	0.90	(7)
(8)		HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD10.0	6071	577	524	577	539	522	459	445	442	438	484	503	560	(10)
(11)		CDD18.3	3029	319	291	319	289	264	209	187	183	188	226	253	302	(11)
(12)		CDH23.3	27098	3739	3478	3762	3196	2412	1270	716	643	811	1469	2255	3348	(12)
(13)		CDH26.7	6948	1326	1289	1324	892	387	66	6	6	29	151	455	1017	(13)
(14)	Wind	WSAvg	6.7	5.7	5.1	5.7	6.2	6.9	7.8	8.4	8.0	7.5	7.0	6.1	5.5	(14)
(15)	Precipitation	PrecAvg	1117	176	173	171	104	76	73	63	58	39	29	29	89	(15)
(16)		PrecMax	1716	530	522	480	256	212	320	156	212	101	93	135	274	(16)
(17)		PrecMin	797	40	35	45	5	18	11	9	17	11	10	0	0	(17)
(18)		PrecStd	231	116	124	104	59	50	57	36	39	21	21	28	62	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.7	32.8	32.2	31.3	30.2	28.5	27.2	27.2	27.9	29.1	31.0	32.1	(19)
(20)			MCWB	27.0	27.2	26.7	25.8	25.7	23.5	22.2	21.9	22.3	23.7	25.7	26.2	(20)
(21)		2%	DB	31.8	32.1	31.7	30.7	29.6	27.9	26.7	26.7	27.4	28.6	30.0	31.3	(21)
(22)			MCWB	26.5	26.7	26.5	25.7	24.9	22.9	22.0	21.6	22.1	23.2	24.5	25.8	(22)
(23)		5%	DB	31.3	31.5	31.1	30.2	29.1	27.4	26.4	26.3	27.0	28.1	29.4	30.7	(23)
(24)			MCWB	26.3	26.4	26.3	25.5	24.3	22.6	21.8	21.4	21.9	22.9	24.1	25.4	(24)
(25)		10%	DB	30.8	31.0	30.7	29.9	28.6	26.9	25.9	25.9	26.5	27.6	28.9	30.2	(25)
(26)			MCWB	26.1	26.1	26.1	25.4	24.0	22.3	21.5	21.3	21.7	22.7	23.7	25.1	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.7	28.6	29.6	27.2	27.8	24.7	23.7	23.6	23.7	25.0	26.5	27.1	(27)
(28)			MCD B	31.6	31.3	30.2	29.7	28.8	27.2	25.7	26.0	26.2	27.6	29.7	30.5	(28)
(29)		2%	WB	27.2	27.8	28.2	26.7	26.5	24.2	23.2	22.8	23.1	24.4	25.7	26.6	(29)
(30)			MCD B	30.8	30.3	29.4	29.4	28.1	26.6	25.5	25.5	26.1	27.1	28.9	30.0	(30)
(31)		5%	WB	26.8	27.3	27.2	26.2	25.3	23.7	22.7	22.3	22.6	23.9	25.1	26.2	(31)
(32)			MCD B	30.3	30.1	29.8	29.1	28.0	26.3	25.3	25.2	25.8	26.7	28.0	29.5	(32)
(33)		10%	WB	26.5	26.8	26.7	25.9	24.7	23.2	22.3	21.9	22.2	23.4	24.6	25.8	(33)
(34)			MCD B	29.8	29.8	29.7	28.9	27.7	26.2	25.0	25.0	25.5	26.5	27.7	29.0	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	4.2	4.3	4.0	3.8	3.6	3.4	3.5	3.7	4.0	4.1	4.4	4.4	(35)
(36)			MCDBR	4.8	4.9	4.5	4.1	3.9	3.6	3.8	4.0	4.3	4.4	4.7	4.8	(36)
(37)			MCWBR	2.0	2.0	2.0	2.0	2.0	2.0	2.1	2.0	2.1	2.0	1.9	2.0	(37)
(38)		5% WB	MCD BR	4.4	4.5	4.3	3.9	3.7	3.4	3.4	3.8	4.0	4.1	4.4	4.5	(38)
(39)			MCWBR	2.1	2.3	2.2	2.1	2.0	2.2	2.1	2.2	2.2	2.1	2.1	2.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.413	0.423	0.413	0.394	0.381	0.373	0.372	0.373	0.380	0.390	0.389	0.390	(40)	
(41)		taud	2.531	2.496	2.532	2.575	2.589	2.568	2.569	2.557	2.518	2.505	2.543	2.572	(41)	
(42)		Ebn at Noon	932	914	903	886	863	853	864	893	920	934	949	954	(42)	
(43)		Edh at Noon	112	115	108	97	90	89	91	97	107	113	110	107	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.78	6.40	6.12	5.60	4.97	4.54	4.69	5.40	6.20	6.84	7.33	7.29	(44)	
(45)		RadStd	0.45	0.51	0.30	0.32	0.22	0.12	0.13	0.13	0.14	0.21	0.23	0.30	(45)	

Historical Trends

		Heating		Cooling			Degree-Days				
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page