

REUNION ST DENIS GILLOT, Réunion

WMO: 619800

Lat: 20.892S

Lon: 55.529E

Elev: 43

StdP: 14.67

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	62.4	63.9	49.9	53.2	67.8	51.6	56.7	68.1	29.1	73.5	27.4	74.2	7.1	180	0.499

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	10.7	88.0	77.5	87.1	77.1	86.2	76.7	79.8	85.4	79.0	84.9	78.2	84.3	16.0	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.1	146.3	83.5	77.1	141.5	83.1	76.3	137.5	82.7	43.4	85.5	42.5	85.1	41.7	84.4	82.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 27.1	25.0	23.2	59.8	89.9	1.0	1.2	59.1	90.8	58.5	91.5	57.9	92.1	57.2	93.0		
(5)			53.3	81.3	1.2	0.8	52.4	81.9	51.7	82.4	51.0	82.9	50.1	83.4		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	75.9	80.3	80.6	80.0	78.4	75.5	72.7	71.4	71.3	72.1	74.1	76.3	78.9		
	DBStd	3.89	1.61	1.67	1.74	1.65	1.95	1.84	1.73	1.68	1.72	2.02	1.93	1.98		
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0		
	CDD50	9468	940	858	929	851	790	682	662	661	664	746	789	896		
	CDD65	3993	475	438	464	401	325	232	197	196	214	281	339	431		
	CDH74	27160	4559	4289	4217	3091	1661	758	455	469	642	1215	2119	3685		
	CDH80	5762	1231	1238	1113	673	204	18	4	2	8	70	299	902		
(14) Wind	WSAvg	13.0	12.7	12.2	12.6	12.4	12.3	13.1	14.2	14.4	14.1	13.5	12.3	12.0		
(15) Precipitation	PrecAvg	60.0	11.3	10.4	8.2	6.8	3.7	2.6	2.6	2.1	1.7	1.6	3.1	6.4		
	PrecMax	100.0	49.7	33.4	28.3	26.9	10.2	8.3	9.0	6.3	5.2	5.0	13.3	23.7		
	PrecMin	26.9	0.0	0.9	0.0	0.1	0.3	0.3	0.2	0.2	0.1	0.2	0.0	0.0		
	PrecStd	17.0	9.3	7.7	5.6	5.9	2.9	2.2	1.9	1.4	1.2	1.3	2.7	5.3		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.8	89.1	89.0	87.0	84.6	81.8	80.4	80.1	81.0	83.3	85.6	88.5		
		MCWB	77.4	78.4	77.8	76.2	75.1	71.4	69.4	68.2	69.1	71.7	74.8	77.1		
	2%	DB	87.4	87.9	87.5	85.6	83.3	80.5	78.9	78.9	79.8	81.8	84.0	87.0		
		MCWB	77.1	78.1	77.4	75.6	73.9	70.4	68.4	67.7	68.6	71.1	73.5	75.9		
	5%	DB	86.4	87.0	86.3	84.6	82.3	79.3	77.8	77.9	78.8	80.7	82.8	85.7		
		MCWB	76.8	77.7	76.9	75.2	72.8	69.3	67.5	67.2	68.1	70.5	72.8	75.1		
	10%	DB	85.5	86.0	85.3	83.9	81.0	78.3	76.8	76.9	77.6	79.6	81.8	84.4		
		MCWB	76.6	77.3	76.4	74.9	71.8	68.4	66.9	66.7	67.6	69.8	72.2	74.7		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.1	81.0	80.7	78.6	77.3	74.2	72.0	71.9	72.3	74.6	76.9	79.1		
		MCDB	85.5	86.4	85.3	84.4	82.8	79.8	77.9	77.5	78.8	80.8	83.5	86.4		
	2%	WB	79.2	79.9	79.3	77.4	75.5	72.0	70.2	70.1	70.8	73.2	75.3	77.8		
		MCDB	85.0	85.7	84.6	83.8	81.9	78.4	76.7	76.7	77.6	79.6	82.0	84.8		
	5%	WB	78.4	79.0	78.3	76.4	74.2	70.8	69.1	68.9	69.7	72.0	74.2	76.7		
		MCDB	84.4	85.1	84.1	83.1	80.7	77.4	75.8	75.8	76.6	78.7	81.1	83.5		
	10%	WB	77.7	78.2	77.4	75.5	72.9	69.6	68.0	67.7	68.7	70.9	73.3	75.8		
		MCDB	83.6	84.3	83.6	82.3	79.3	76.4	74.8	74.7	75.8	77.8	80.3	82.7		
(35) Mean Daily Temperature Range	5% DB	MDBR	10.4	10.7	10.8	11.4	11.4	11.6	11.5	11.7	11.7	11.5	11.3	11.0		
		MCDBR	11.5	11.8	12.0	12.1	12.4	12.6	12.5	12.6	12.6	12.0	12.0	12.1		
	5% WB	MCWBR	7.6	7.4	7.6	8.0	8.2	8.3	8.0	8.0	8.1	7.6	8.1	8.0		
		MCWBR	10.4	10.6	10.9	11.4	11.6	11.7	11.6	12.0	12.1	11.2	11.2	11.0		
(40) Clear-Sky Solar Irradiance	taub	taub	0.401	0.411	0.396	0.380	0.358	0.339	0.341	0.345	0.361	0.371	0.376	0.383		
		taud	2.536	2.506	2.551	2.581	2.621	2.625	2.618	2.588	2.512	2.497	2.524	2.558		
	Ebn at Noon	Ebn at Noon	299	293	289	282	276	276	279	289	295	301	305	305		
		Edh at Noon	36	36	33	30	27	25	26	29	34	36	36	35		
(44) All-Sky Solar Radiation	RadAvg	RadAvg	2122	2052	1861	1626	1371	1265	1331	1564	1881	2118	2261	2299		
	RadStd	RadStd	142	117	120	92	60	39	36	45	60	50	86	114		

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.88	N/A	N/A	+0.85	N/A	N/A	N/A	N/A	+279	+279
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page