

REUNION ST DENIS GILLOT, Réunion

WMO: 619800

Lat: 20.892S

Lon: 55.529E

Elev: 13

StdP: 101.17

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.9	17.7	9.9	7.6	19.9	10.9	8.1	20.0	13.0	23.1	12.3	23.5	3.2	180	0.499

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.9	31.1	25.3	30.6	25.1	30.1	24.8	26.5	29.7	26.1	29.4	25.7	29.0	7.1	80

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
25.6	20.9	28.6	25.1	20.2	28.4	24.6	19.6	28.2	83.0	29.7	81.0	29.5	79.1	29.1	28.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
12.1	11.2	10.4	DB	15.4	32.2	0.6	0.7	15.0	32.7	14.7	33.0	14.4	33.4	14.0	33.9	
			WB	11.8	27.4	0.7	0.4	11.3	27.7	10.9	28.0	10.6	28.3	10.1	28.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	24.4	26.8	27.0	26.6	25.8	24.2	22.6	21.9	21.8	22.3	23.4	24.6	26.1
	DBStd	2.16	0.89	0.93	0.97	0.92	1.08	1.02	0.96	0.93	0.96	1.12	1.07	1.10
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5260	522	477	516	473	439	379	368	367	369	414	438	498
	CDD18.3	2218	264	243	258	223	181	129	109	109	119	156	188	239
	CDH23.3	15089	2533	2383	2343	1717	923	421	253	261	357	675	1177	2047
(14) Wind	WSAvg	5.8	5.7	5.5	5.6	5.6	5.5	5.9	6.4	6.4	6.3	6.1	5.5	5.4
	PrecAvg	1523	286	264	209	172	94	66	66	54	43	40	78	163
	PrecMax	2541	1262	849	719	684	259	211	228	159	133	128	339	602
	PrecMin	682	0	23	0	3	7	8	5	4	2	5	0	0
	PrecStd	433	235	195	142	150	73	56	47	36	31	32	69	134
	DB	31.5	31.7	31.7	30.5	29.2	27.6	26.9	26.7	27.2	28.5	29.8	31.4	
	MCWB	25.2	25.8	25.5	24.6	24.0	21.9	20.8	20.1	20.6	22.1	23.8	25.1	
(20) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	2% DB	30.8	31.1	30.8	29.8	28.5	26.9	26.1	26.1	26.6	27.7	28.9	30.6	
	2% MCWB	25.1	25.6	25.2	24.2	23.3	21.3	20.2	19.8	20.3	21.7	23.1	24.4	
	5% DB	30.2	30.5	30.2	29.2	27.9	26.3	25.4	25.5	26.0	27.0	28.2	29.8	
	5% MCWB	24.9	25.4	24.9	24.0	22.7	20.7	19.7	19.6	20.1	21.4	22.7	24.0	
	10% DB	29.7	30.0	29.6	28.8	27.2	25.7	24.9	24.9	25.4	26.4	27.7	29.1	
	10% MCWB	24.8	25.2	24.6	23.8	22.1	20.2	19.4	19.3	19.8	21.0	22.4	23.7	
	WB	26.7	27.2	27.1	25.9	25.1	23.4	22.2	22.2	22.4	23.7	25.0	26.2	
(28) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4% MCDB	29.7	30.2	29.6	29.1	28.2	26.5	25.5	25.3	26.0	27.1	28.6	30.2	
	2% WB	26.2	26.6	26.3	25.2	24.2	22.2	21.2	21.2	21.5	22.9	24.1	25.4	
	2% MCDB	29.5	29.8	29.2	28.8	27.7	25.8	24.8	24.8	25.3	26.5	27.8	29.3	
	5% WB	25.8	26.1	25.7	24.7	23.5	21.5	20.6	20.5	20.9	22.2	23.4	24.8	
	5% MCDB	29.1	29.5	29.0	28.4	27.0	25.2	24.3	24.4	24.8	25.9	27.3	28.6	
	10% WB	25.4	25.7	25.2	24.2	22.7	20.9	20.0	19.8	20.4	21.6	22.9	24.3	
	10% MCDB	28.7	29.1	28.6	28.0	26.3	24.7	23.8	23.7	24.3	25.4	26.8	28.1	
(35) Mean Daily Temperature Range	MDBR	5.8	5.9	6.0	6.3	6.3	6.5	6.4	6.5	6.5	6.4	6.3	6.1	
	5% DB MCDBR	6.4	6.5	6.6	6.7	6.9	7.0	6.9	7.0	7.0	6.7	6.7	6.7	
	5% DB MCWBR	4.2	4.1	4.2	4.4	4.5	4.6	4.4	4.5	4.5	4.2	4.5	4.5	
	5% WB MCDBR	5.8	5.9	6.0	6.3	6.4	6.5	6.5	6.7	6.7	6.2	6.2	6.1	
	5% WB MCWBR	4.1	4.0	4.2	4.4	4.6	4.7	4.4	4.7	4.8	4.3	4.5	4.4	
(40) Clear-Sky Solar Irradiance	taub	0.401	0.411	0.396	0.380	0.358	0.339	0.341	0.345	0.361	0.371	0.376	0.383	
	taud	2.536	2.506	2.551	2.581	2.621	2.625	2.618	2.588	2.512	2.497	2.524	2.558	
	Ebn at Noon	944	923	912	888	870	870	880	910	931	949	962	962	
	Edh at Noon	112	113	104	94	84	80	83	92	106	113	112	109	
(44) All-Sky Solar Radiation	RadAvg	6.69	6.47	5.87	5.13	4.32	3.99	4.20	4.93	5.93	6.68	7.13	7.25	
	RadStd	0.45	0.37	0.38	0.29	0.19	0.12	0.11	0.14	0.19	0.16	0.27	0.36	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	+0.49	N/A	N/A	+0.47	N/A	N/A	N/A	N/A	+155	+155
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page