

RODRIGUES POINTE CANON, Mauritius

WMO: 619880

Lat: 19.6811S

Lon: 63.4264E

Elev: 203

StdP: 14.59

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	66.4	67.5	54.4	63.5	70.5	56.1	67.6	71.1	28.3	72.8	26.9	72.3	11.8	130	0.480

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	7.9	87.9	78.7	86.8	78.0	86.0	77.6	80.2	85.2	79.4	84.3	78.9	83.7	14.0	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.9	150.9	83.7	78.1	146.8	82.9	77.3	143.0	82.1	44.0	85.4	43.2	84.9	42.5	83.8	83.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 26.6	24.4	22.5	63.8	90.2	2.6	1.5	61.9	91.3	60.4	92.2	58.9	93.1	57.0	94.2		
(5)			58.5	82.0	1.7	0.8	57.3	82.6	56.4	83.1	55.4	83.5	54.2	84.1	(4)	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	77.3	81.3	81.6	81.3	79.8	77.2	74.9	73.0	72.6	73.4	75.2	77.6	80.0	(6)	(7)
	DBStd	3.79	1.83	1.89	1.87	1.67	1.94	1.93	1.92	1.72	1.68	1.99	2.04	1.86	(7)	(8)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	(9)
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	(10)
	CDD50	9966	971	885	970	895	843	746	714	701	702	780	829	930	(10)	(11)
	CDD65	4491	506	465	505	445	378	296	249	236	252	315	379	465	(11)	(12)
	CDH74	30101	4978	4729	4948	3773	2079	922	448	383	547	1122	2247	3925	(12)	(13)
	CDH80	5529	1208	1178	1138	606	182	29	7	2	6	66	304	803	(13)	(14)
(14) Wind	WSAvg	13.4	13.3	12.6	12.6	12.9	12.3	13.5	14.2	14.6	14.3	14.1	13.4	13.4	(14)	(15)
(15) Precipitation	PrecAvg	41.5	5.4	7.1	5.8	4.8	3.4	2.8	3.3	2.5	1.9	1.7	1.7	2.4	(15)	(16)
	PrecMax	66.9	16.1	33.5	18.3	13.3	8.2	8.8	8.3	6.1	5.2	7.3	6.8	10.7	(16)	(17)
	PrecMin	17.0	1.1	0.4	1.1	0.8	1.0	0.6	0.5	1.1	0.2	0.4	0.2	0.4	(17)	(18)
	PrecStd	10.6	3.9	6.4	3.9	3.1	1.8	1.4	1.4	1.0	1.0	1.2	1.3	2.1	(18)	(19)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.4	89.2	89.3	87.0	84.6	82.3	80.8	80.1	80.8	82.8	86.0	88.0	(19)	(20)
		MCWB	78.2	79.2	79.8	78.3	76.6	73.5	72.5	70.9	70.9	72.9	75.8	77.5	(20)	(21)
	2%	DB	87.8	87.8	87.4	85.7	83.0	80.7	79.0	78.6	79.1	82.0	84.3	86.3	(21)	(22)
		MCWB	78.1	79.3	79.0	77.4	75.1	71.8	71.0	70.0	69.9	72.4	74.9	76.6	(22)	(23)
	5%	DB	86.3	86.3	86.1	84.3	82.1	79.4	77.4	77.2	78.4	80.5	82.8	85.5	(23)	(24)
		MCWB	77.3	78.5	78.2	76.5	74.1	71.0	69.7	68.9	69.5	71.6	74.0	76.3	(24)	(25)
	10%	DB	85.2	85.5	84.7	83.2	80.8	78.5	76.6	76.1	77.1	79.0	81.9	84.1	(25)	(26)
		MCWB	76.9	78.0	77.3	75.8	73.0	70.5	69.2	68.2	68.7	70.7	73.4	75.6	(26)	(27)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.3	81.4	81.1	79.8	78.6	75.4	74.7	73.2	72.8	75.3	78.0	79.5	(27)	(28)
		MCDB	86.0	86.1	86.3	84.3	82.8	79.9	78.3	77.4	78.1	80.0	82.6	84.8	(28)	(29)
	2%	WB	79.1	80.4	80.0	78.8	77.1	73.7	72.9	71.7	71.7	73.8	76.5	78.5	(29)	(30)
		MCDB	84.6	85.4	85.1	83.3	81.3	78.4	76.8	76.0	77.1	78.8	81.7	83.7	(30)	(31)
	5%	WB	78.6	79.6	79.2	78.0	75.7	72.6	71.7	70.5	70.6	72.8	75.5	77.6	(31)	(32)
		MCDB	83.9	84.3	84.1	82.3	80.0	77.5	75.8	75.2	76.1	78.1	80.8	82.8	(32)	(33)
	10%	WB	77.9	78.9	78.5	77.2	74.7	71.7	70.6	69.5	69.8	71.9	74.6	76.8	(33)	(34)
		MCDB	83.1	83.4	83.3	81.3	79.2	76.7	74.9	74.4	75.2	77.3	79.9	82.0	(34)	(35)
(35) Mean Daily Temperature Range	5% DB	MDBR	8.5	7.9	7.8	7.5	7.8	7.9	7.6	8.0	8.4	8.7	9.0	8.9	(35)	(36)
		MCDBR	9.9	8.9	8.8	8.6	8.7	8.6	8.4	8.8	9.4	9.9	10.1	10.2	(36)	(37)
	5% WB	MCWBR	4.3	4.2	4.3	4.5	4.6	4.8	5.0	4.9	4.7	4.7	4.7	4.4	(37)	(38)
		MCWBR	8.9	8.3	8.1	7.9	8.2	8.1	7.9	8.2	8.8	9.1	9.5	9.2	(38)	(39)
(39) Clear-Sky Solar Irradiance	taub	taub	0.400	0.415	0.411	0.390	0.364	0.346	0.353	0.353	0.367	0.376	0.374	0.384	(39)	(40)
		taud	2.542	2.507	2.498	2.558	2.613	2.615	2.598	2.584	2.525	2.519	2.558	2.564	(40)	(41)
	Ebn at Noon	Ebn at Noon	300	292	285	279	276	275	277	287	294	300	305	305	(41)	(42)
		Edh at Noon	35	36	35	31	27	26	27	30	33	35	35	35	(42)	(43)
(43) All-Sky Solar Radiation	RadAvg	RadAvg	2299	2126	1975	1675	1435	1315	1351	1604	1893	2141	2347	2403	(43)	(44)
	RadStd	RadStd	157	135	90	96	68	47	46	45	51	82	78	108	(44)	(45)

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		+1.13	+1.30	+1.75	+1.40	+0.72	+0.52	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page