

MAURITIUS PLAISANCE, Mauritius

WMO: 619900

Lat: 20.4348S

Lon: 57.6837E

Elev: 187

StdP: 14.60

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	62.3	64.2	53.2	60.6	69.6	55.0	64.9	70.2	23.1	72.3	21.4	72.3	5.5	320	0.378

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.7	87.8	78.6	86.4	77.8	85.8	77.4	80.1	85.0	79.3	84.2	78.8	83.7	12.5	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
78.8	150.4	83.4	77.9	145.9	82.6	77.2	142.7	82.1	43.8	85.5	43.1	84.7	42.4	84.0	83.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 20.9	18.8	17.5	DB	58.9	91.0	2.0	1.4	57.4	92.0	56.3	92.8	55.2	93.6	53.7	94.6	(4)
(5)			WB	55.9	81.9	1.6	1.1	54.8	82.7	53.8	83.4	52.9	84.1	51.7	84.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	76.0	80.5	80.7	80.0	78.5	75.3	72.8	71.3	71.3	72.1	74.1	76.5	79.2	(6)
(7)		DBStd	4.04	1.75	1.78	1.93	1.94	2.20	2.23	1.89	1.88	1.90	2.08	2.08	1.91	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	9492	945	861	931	854	786	683	661	659	664	748	794	906	(10)
(11)		CDD65	4017	480	441	466	404	321	233	196	194	214	283	344	441	(11)
(12)		CDH74	26676	4651	4288	4288	3139	1592	600	252	267	484	1117	2165	3833	(12)
(13)		CDH80	5207	1197	1124	981	528	121	10	2	2	3	52	294	893	(13)
(14)	Wind	WSAvg	9.4	8.8	8.7	8.5	8.6	8.9	9.8	10.7	10.8	10.4	9.9	8.8	8.7	(14)
(15)	Precipitation	PrecAvg	67.8	9.4	11.5	9.8	7.1	5.1	3.6	4.0	3.4	2.7	2.2	3.1	6.0	(15)
(16)		PrecMax	90.4	22.5	26.5	24.4	16.0	12.7	7.1	5.8	5.2	10.6	7.5	12.2	19.1	(16)
(17)		PrecMin	40.3	1.7	4.0	2.9	2.0	1.7	1.8	2.4	1.4	0.8	0.7	1.2	0.9	(17)
(18)		PrecStd	10.4	5.4	5.7	5.0	3.3	2.7	1.4	1.0	1.0	1.9	1.4	2.3	4.4	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	89.3	90.0	88.2	86.3	84.2	81.0	79.0	79.2	80.3	82.8	85.9	87.9	(19)
(20)			MCWB	78.6	79.4	79.1	77.2	75.6	72.3	70.4	69.6	69.9	72.3	75.0	77.1	(20)
(21)		2%	DB	87.4	87.7	86.5	85.0	82.5	79.4	77.4	77.5	78.9	81.2	84.1	86.3	(21)
(22)			MCWB	78.5	79.2	78.4	76.7	74.2	70.8	69.2	68.4	69.5	71.5	74.1	76.2	(22)
(23)		5%	DB	86.2	86.3	85.7	84.1	81.3	78.5	76.6	76.7	77.8	80.3	82.7	85.4	(23)
(24)			MCWB	77.7	78.5	77.9	76.0	73.4	70.1	68.6	68.0	68.9	71.0	73.2	75.8	(24)
(25)		10%	DB	85.1	85.4	84.4	82.9	80.3	77.2	75.4	75.4	76.9	79.0	81.8	84.3	(25)
(26)			MCWB	77.1	78.0	77.1	75.5	72.7	69.3	67.8	67.3	68.3	70.2	72.7	75.2	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.6	81.3	80.8	79.4	78.1	74.8	72.9	72.6	72.5	74.7	77.4	79.2	(27)
(28)			MCDWB	85.9	86.0	85.7	83.5	81.5	79.7	76.3	76.7	77.0	78.9	82.4	84.5	(28)
(29)		2%	WB	79.6	80.2	79.6	78.4	76.3	72.8	71.5	71.1	71.2	73.5	76.1	78.2	(29)
(30)			MCDWB	84.9	85.2	84.5	82.8	80.6	77.3	75.2	75.3	76.3	78.4	81.3	83.6	(30)
(31)		5%	WB	79.0	79.5	78.9	77.5	74.9	71.7	70.4	69.8	70.2	72.4	75.0	77.4	(31)
(32)			MCDWB	84.1	84.4	83.7	81.9	79.5	76.5	74.4	74.3	75.6	77.8	80.2	82.8	(32)
(33)		10%	WB	78.3	78.8	78.2	76.7	73.8	70.7	69.4	68.8	69.4	71.6	74.0	76.6	(33)
(34)			MCDWB	83.3	83.7	82.9	81.2	78.5	75.6	73.7	73.6	74.9	77.3	79.6	82.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	9.9	9.7	9.5	9.5	9.9	9.4	8.8	9.1	10.1	10.5	11.0	10.7	(35)
(36)			MCDBR	10.9	10.9	10.4	10.4	11.1	10.4	9.9	10.3	11.0	11.5	11.9	11.6	(36)
(37)			MCWBR	5.1	5.4	5.4	5.5	6.2	6.0	5.8	5.6	5.9	5.5	5.6	5.2	(37)
(38)		5% WB	MCDWR	10.0	10.1	9.5	9.5	10.2	9.9	9.1	9.6	10.4	10.5	10.5	(38)	
(39)			MCWBR	5.3	5.4	5.5	5.5	6.2	6.3	5.8	5.8	6.1	5.6	5.7	5.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.406	0.421	0.407	0.383	0.362	0.342	0.345	0.347	0.360	0.375	0.375	0.384	(40)	
(41)		taud	2.516	2.472	2.510	2.567	2.606	2.615	2.609	2.588	2.522	2.495	2.535	2.557	(41)	
(42)		Ebn at Noon	298	290	286	281	275	276	278	288	296	300	305	305	(42)	
(43)		Edh at Noon	36	37	35	30	27	26	27	29	33	36	35	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	2150	2015	1865	1628	1371	1252	1298	1533	1842	2095	2269	2292	(44)	
(45)		RadStd	144	120	111	86	57	38	45	41	65	63	77	121	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46)	Station Only	+1.26	+1.51	+0.95	+0.54	N/A	N/A	N/A	N/A	+389	+389	(46)
(47)	Regional (1 neighbor)	+1.08	+1.17	+0.72	+0.49	N/A	N/A	N/A	N/A	+389	+389	(47)

Nomenclature: See separate page