

MAURITIUS PLAISANCE, Mauritius

WMO: 619900

Lat: 20.4348S

Lon: 57.6837E

Elev: 57

StdP: 100.64

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	16.8	17.9	11.8	8.7	20.9	12.8	9.3	21.2	10.3	22.4	9.6	22.4	2.5	320	0.378

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.4	31.0	25.9	30.2	25.4	29.9	25.2	26.7	29.5	26.3	29.0	26.0	28.7	5.6	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.0	21.5	28.6	25.5	20.8	28.1	25.1	20.4	27.8	84.0	29.7	82.3	29.3	80.8	28.9	28.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
1%		2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)		(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
9.3	8.4	7.8	DB	14.9	32.8	1.1	0.8	14.1	33.3	13.5	33.8	12.9	34.2	12.1	34.8	
			WB	13.3	27.7	0.9	0.6	12.6	28.2	12.1	28.6	11.6	28.9	10.9	29.4	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.4	26.9	27.1	26.7	25.8	24.1	22.6	21.8	21.8	22.3	23.4	24.7	26.2
	DBStd	2.24	0.97	0.99	1.07	1.08	1.22	1.24	1.05	1.05	1.06	1.16	1.16	1.06
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	5273	525	478	517	474	437	379	367	366	369	416	441	503
	CDD18.3	2232	267	245	259	224	178	129	109	108	119	157	191	245
	CDH23.3	14820	2584	2382	2382	1744	884	333	140	148	269	621	1203	2129
	CDH26.7	2893	665	624	545	293	67	6	1	1	2	29	163	496
Wind	WSAvg	4.2	3.9	3.9	3.8	3.9	4.0	4.4	4.8	4.8	4.7	4.4	4.0	3.9
Precipitation	PrecAvg	1723	238	292	249	180	130	91	101	86	68	56	79	153
	PrecMax	2295	572	672	619	407	323	180	147	133	269	190	311	486
	PrecMin	1024	42	102	73	50	43	45	60	35	21	18	30	23
	PrecStd	265	138	145	126	85	69	35	25	26	48	36	58	112
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	31.8	32.2	31.2	30.2	29.0	27.2	26.1	26.2	26.8	28.2	29.9	31.0
		MCWB	25.9	26.3	26.1	25.1	24.2	22.4	21.3	20.9	21.1	22.4	23.9	25.0
	2%	DB	30.8	31.0	30.3	29.4	28.1	26.3	25.2	25.3	26.0	27.3	29.0	30.2
		MCWB	25.9	26.2	25.8	24.8	23.4	21.6	20.7	20.2	20.8	21.9	23.4	24.6
	5%	DB	30.1	30.2	29.8	28.9	27.4	25.8	24.8	24.8	25.4	26.9	28.2	29.7
		MCWB	25.4	25.8	25.5	24.5	23.0	21.2	20.4	20.0	20.5	21.6	22.9	24.3
	10%	DB	29.5	29.7	29.1	28.3	26.8	25.1	24.1	24.1	25.0	26.1	27.7	29.1
		MCWB	25.1	25.5	25.0	24.2	22.6	20.7	19.9	19.6	20.2	21.2	22.6	24.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	27.0	27.4	27.1	26.3	25.6	23.8	22.7	22.5	22.5	23.7	25.2	26.2
		MCDB	29.9	30.0	29.8	28.6	27.5	26.5	24.6	24.8	25.0	26.0	28.0	29.2
	2%	WB	26.5	26.8	26.5	25.8	24.6	22.7	21.9	21.7	21.8	23.1	24.5	25.7
		MCDB	29.4	29.6	29.2	28.2	27.0	25.2	24.0	24.0	24.6	25.8	27.4	28.7
	5%	WB	26.1	26.4	26.1	25.3	23.8	22.1	21.4	21.0	21.2	22.5	23.9	25.2
		MCDB	29.0	29.1	28.7	27.7	26.4	24.7	23.6	23.5	24.2	25.5	26.8	28.2
	10%	WB	25.7	26.0	25.7	24.9	23.2	21.5	20.8	20.5	20.8	22.0	23.4	24.8
		MCDB	28.5	28.7	28.3	27.3	25.8	24.2	23.2	23.1	23.9	25.2	26.4	27.8
Mean Daily Temperature Range	5% DB	MDBR	5.5	5.4	5.3	5.3	5.5	5.2	4.9	5.1	5.6	5.8	6.1	6.0
		MCDBR	6.1	6.1	5.8	5.8	6.2	5.8	5.5	5.7	6.1	6.4	6.6	6.4
		MCWBR	2.8	3.0	3.0	3.0	3.4	3.3	3.2	3.1	3.3	3.1	3.1	2.9
	5% WB	MCDBR	5.6	5.6	5.3	5.3	5.6	5.5	5.0	5.4	5.8	5.8	5.8	5.8
MCWBR		2.9	3.0	3.1	3.1	3.4	3.5	3.2	3.2	3.4	3.1	3.2	3.0	
Clear-Sky Solar Irradiance	taub	0.406	0.421	0.407	0.383	0.362	0.342	0.345	0.347	0.360	0.375	0.375	0.384	
	taud	2.516	2.472	2.510	2.567	2.606	2.615	2.609	2.588	2.522	2.495	2.535	2.557	
	Ebn at Noon	939	914	903	885	868	869	877	908	932	946	962	961	
	Edh at Noon	114	117	109	96	86	81	84	92	105	113	111	109	
All-Sky Solar Radiation	RadAvg	6.78	6.35	5.88	5.13	4.32	3.95	4.09	4.83	5.81	6.61	7.15	7.22	
	RadStd	0.45	0.38	0.35	0.27	0.18	0.12	0.14	0.13	0.20	0.20	0.24	0.38	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	+0.70	+0.84	+0.53	+0.30	N/A	N/A	N/A	N/A	+216	+216
Regional (1 neighbor)	+0.60	+0.65	+0.40	+0.27	N/A	N/A	N/A	N/A	+216	+216

Nomenclature: See separate page