

MARTIN-DE-VIVIES, French Southern TerritoriesWMO: **619960**Lat: **37.795S**Lon: **77.569E**Elev: **95**StdP: **14.65**Time Zone: **5.00 (E05)**Period: **95-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	43.6	44.9	32.8	27.3	46.8	34.4	29.3	47.3	40.8	55.7	38.1	55.0	15.7	200	0.705

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	9.4	72.5	66.6	71.0	65.4	69.5	64.5	68.5	70.6	67.4	69.4	66.4	68.3	13.8	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
67.7	102.2	69.6	66.6	98.3	68.7	65.5	94.6	67.8	32.8	70.8	31.9	69.6	31.1	68.5	73.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
35.6	32.2	29.7	40.7	75.7	1.0	2.6	40.0	77.6	39.4	79.2	38.8	80.6	38.1	82.5
			37.5	70.0	1.0	1.4	36.8	71.0	36.2	71.8	35.6	72.6	34.9	73.6
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	57.6	63.2	63.7	62.9	60.0	56.9	54.3	52.6	52.1	53.4	54.3	56.7	60.8
	DBStd	5.28	3.50	3.57	3.58	3.30	3.69	3.48	3.05	2.87	2.77	2.91	2.67	3.32
	HDD50	42	0	0	0	0	1	7	11	14	6	3	0	0
	HDD65	2796	78	61	84	151	251	320	386	399	349	332	249	136
	CDD50	2799	409	384	401	301	216	138	91	80	106	137	201	335
	CDD65	76	22	26	20	2	0	0	0	0	0	0	0	6
	CDH74	10	6	3	1	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
(14) Wind	WSAvg	15.7	12.5	12.4	12.4	13.6	16.6	18.5	19.3	18.0	19.4	16.3	15.7	13.5
(15) Precipitation	PrecAvg	42.2	3.1	2.8	2.9	3.9	4.4	4.3	4.1	3.6	3.2	3.1	3.6	3.1
	PrecMax	52.4	9.0	10.2	8.6	9.4	7.7	8.4	7.4	7.0	7.0	5.9	7.1	8.8
	PrecMin	30.8	0.7	0.4	0.6	1.0	2.2	1.9	2.0	1.3	0.8	0.5	1.4	0.6
	PrecStd	5.3	1.9	2.0	1.9	1.9	1.3	1.5	1.3	1.3	1.1	1.2	1.3	1.8
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	74.8	74.3	72.9	69.6	66.1	62.0	60.2	59.4	60.4	62.4	65.4	72.0
		MCWB	68.8	68.4	66.6	64.8	62.5	58.4	56.7	56.2	56.7	57.7	59.3	65.9
	2%	DB	72.5	72.5	71.2	67.6	64.5	61.0	58.9	58.2	59.2	60.9	63.7	69.2
		MCWB	66.6	66.7	65.4	63.7	61.4	58.1	56.2	55.2	55.8	56.8	58.9	63.7
	5%	DB	70.7	70.8	69.7	66.2	63.4	60.2	58.0	57.3	58.2	59.7	62.4	67.6
		MCWB	65.3	65.5	64.3	62.6	60.6	57.5	55.4	54.6	55.2	56.1	58.2	62.7
	10%	DB	69.0	69.3	68.1	64.9	62.4	59.4	57.2	56.5	57.3	58.7	61.2	66.1
		MCWB	64.2	64.6	63.9	61.7	59.7	56.9	54.7	53.9	54.6	55.5	57.4	61.7
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	70.3	70.4	68.5	67.0	64.0	60.2	58.4	57.6	57.9	59.4	61.9	68.2
		MCDB	73.0	72.6	70.8	68.9	65.0	60.9	59.1	58.5	59.1	60.9	63.1	70.4
	2%	WB	68.5	68.7	67.2	64.8	62.8	59.2	57.2	56.5	56.9	58.3	60.5	66.2
		MCDB	70.6	70.7	69.3	66.3	63.9	60.2	58.3	57.3	58.0	59.6	62.0	67.8
	5%	WB	67.2	67.6	66.3	63.7	61.7	58.3	56.3	55.6	56.2	57.4	59.4	64.6
		MCDB	69.3	69.4	68.1	65.2	62.9	59.6	57.6	56.6	57.4	58.7	61.0	66.2
	10%	WB	65.6	66.4	65.4	62.7	60.4	57.4	55.3	54.7	55.5	56.6	58.5	63.2
		MCDB	67.9	68.4	67.3	64.4	61.9	59.0	56.8	56.1	56.8	58.1	60.2	64.9
(35) Mean Daily Temperature Range	5% DB	MDBR	9.7	9.4	8.7	7.6	7.0	6.7	6.8	7.1	7.1	7.8	8.4	9.1
		MCDBR	10.8	9.9	9.9	8.0	7.2	6.7	6.6	7.2	7.2	8.1	9.3	10.2
		MCWBR	7.2	6.8	7.0	6.9	6.6	6.6	6.7	6.9	6.5	6.8	7.3	7.5
	5% WB	MCDBR	9.1	8.7	7.7	7.0	6.1	6.1	5.9	6.2	6.6	7.2	7.4	8.3
		MCWBR	6.8	7.1	6.3	7.1	6.2	6.6	6.6	6.9	6.6	6.7	6.6	7.4
(40) Clear-Sky Solar Irradiance	taub	0.344	0.341	0.339	0.327	0.336	0.338	0.340	0.349	0.374	0.363	0.354	0.349	(40)
	taud	2.593	2.608	2.620	2.632	2.565	2.507	2.501	2.484	2.405	2.455	2.517	2.560	(41)
	Ebn at Noon	314	307	295	280	255	243	250	266	278	297	308	313	(42)
	Edh at Noon	33	31	28	24	23	23	24	28	34	36	35	34	(43)
(44) All-Sky Solar Radiation	RadAvg	2077	1787	1381	978	703	563	632	867	1210	1608	1860	2086	(44)
	RadStd	120	100	130	61	40	46	23	62	45	70	104	93	(45)

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page