

MARTIN-DE-VIVIES, French Southern TerritoriesWMO: **619960**Lat: **37.795S**Lon: **77.569E**Elev: **29**StdP: **100.98**Time Zone: **5.00 (E05)**Period: **95-18**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.4	7.2	0.4	3.9	8.2	1.4	4.2	8.5	18.3	13.2	17.0	12.8	7.0	200	0.705

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	5.2	22.5	19.2	21.7	18.6	20.9	18.1	20.3	21.4	19.7	20.8	19.1	20.2	6.2	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
19.8	14.6	20.9	19.2	14.0	20.4	18.6	13.5	19.9	58.4	21.6	56.3	20.9	54.4	20.3	22.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
15.9	14.4	13.3	4.8	24.3	0.6	1.5	4.4	25.3	4.1	26.2	3.8	27.0	3.4	28.1
			3.0	21.1	0.5	0.8	2.7	21.6	2.3	22.1	2.0	22.5	1.6	23.1
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	14.2	17.3	17.6	17.2	15.6	13.8	12.4	11.4	11.2	11.9	12.4	13.7	16.0	(6)
(7)		DBStd	2.93	1.95	1.98	1.99	1.83	2.05	1.93	1.69	1.59	1.54	1.62	1.48	1.85	(7)
(8)		HDD10.0	23	0	0	0	0	1	4	6	8	3	2	0	0	(8)
(9)		HDD18.3	1553	43	34	47	84	139	178	214	222	194	184	138	76	(9)
(10)		CDD10.0	1555	227	213	223	167	120	77	51	44	59	76	112	186	(10)
(11)		CDD18.3	42	12	14	11	1	0	0	0	0	0	0	0	3	(11)
(12)		CDH23.3	6	3	2	1	0	0	0	0	0	0	0	0	0	(12)
(13)		CDH26.7	0	0	0	0	0	0	0	0	0	0	0	0	0	(13)
(14)	Wind	WSAvg	7.0	5.6	5.6	5.6	6.1	7.4	8.3	8.6	8.0	8.7	7.3	7.0	6.0	(14)
(15)	Precipitation	PrecAvg	1071	80	71	74	98	111	110	103	92	82	80	91	80	(15)
(16)		PrecMax	1331	229	259	218	238	196	214	188	178	177	151	181	223	(16)
(17)		PrecMin	782	17	11	16	26	57	48	50	34	20	12	35	14	(17)
(18)		PrecStd	135	48	51	47	47	33	37	32	32	29	31	32	45	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	23.8	23.5	22.7	20.9	19.0	16.7	15.7	15.2	15.8	16.9	18.5	22.2	(19)
(20)			MCWB	20.5	20.2	19.2	18.2	16.9	14.7	13.7	13.5	13.7	14.3	15.1	18.8	(20)
(21)		2%	DB	22.5	22.5	21.8	19.8	18.1	16.1	15.0	14.5	15.1	16.1	17.6	20.7	(21)
(22)			MCWB	19.2	19.3	18.5	17.6	16.4	14.5	13.4	12.9	13.2	13.8	15.0	17.6	(22)
(23)		5%	DB	21.5	21.6	20.9	19.0	17.4	15.7	14.5	14.0	14.6	15.4	16.9	19.8	(23)
(24)			MCWB	18.5	18.6	18.0	17.0	15.9	14.2	13.0	12.5	12.9	13.4	14.5	17.0	(24)
(25)		10%	DB	20.6	20.7	20.1	18.3	16.9	15.2	14.0	13.6	14.1	14.8	16.2	19.0	(25)
(26)			MCWB	17.9	18.1	17.7	16.5	15.4	13.8	12.6	12.2	12.5	13.1	14.1	16.5	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	21.3	21.4	20.3	19.4	17.8	15.7	14.7	14.2	14.4	15.2	16.6	20.1	(27)
(28)			MADB	22.8	22.5	21.6	20.5	18.3	16.0	15.0	14.7	15.1	16.0	17.3	21.3	(28)
(29)		2%	WB	20.3	20.4	19.6	18.2	17.1	15.1	14.0	13.6	13.8	14.6	15.8	19.0	(29)
(30)			MADB	21.4	21.5	20.7	19.1	17.7	15.7	14.6	14.1	14.5	15.3	16.7	19.9	(30)
(31)		5%	WB	19.5	19.8	19.1	17.6	16.5	14.6	13.5	13.1	13.5	14.1	15.2	18.1	(31)
(32)			MADB	20.7	20.8	20.1	18.5	17.2	15.3	14.2	13.7	14.1	14.8	16.1	19.0	(32)
(33)		10%	WB	18.7	19.1	18.6	17.0	15.8	14.1	13.0	12.6	13.0	13.6	14.7	17.3	(33)
(34)			MADB	20.0	20.2	19.6	18.0	16.6	15.0	13.8	13.4	13.8	14.5	15.7	18.3	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	5.4	5.2	4.8	4.2	3.9	3.7	3.8	3.9	3.9	4.4	4.7	5.0	(35)
(36)			MADB	6.0	5.5	5.5	4.4	4.0	3.7	3.7	4.0	4.0	4.5	5.2	5.7	(36)
(37)			MCWBR	4.0	3.8	3.9	3.8	3.7	3.7	3.7	3.8	3.6	3.8	4.1	4.2	(37)
(38)		5% WB	MADB	5.1	4.8	4.3	3.9	3.4	3.4	3.3	3.5	3.7	4.0	4.1	4.6	(38)
(39)			MCWBR	3.8	4.0	3.5	3.9	3.4	3.7	3.7	3.8	3.6	3.7	3.7	4.1	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.344	0.341	0.339	0.327	0.336	0.338	0.340	0.349	0.374	0.363	0.354	0.349	(40)	
(41)		taud	2.593	2.608	2.620	2.632	2.565	2.507	2.501	2.484	2.405	2.455	2.517	2.560	(41)	
(42)		Ebn at Noon	989	969	931	882	804	765	787	840	877	935	972	988	(42)	
(43)		Edh at Noon	103	97	89	77	72	71	75	88	108	112	110	107	(43)	
(44)	All-Sky Solar Radiation	RadAvg	6.55	5.63	4.35	3.08	2.21	1.78	1.99	2.73	3.82	5.07	5.87	6.58	(44)	
(45)		RadStd	0.38	0.31	0.41	0.19	0.13	0.14	0.07	0.20	0.14	0.22	0.33	0.29	(45)	

Historical Trends

		Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
(46) Station Only	DBAvg	(d) N/A	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A
(47) Regional (0 neighbors)		(m) N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page