

PORT-AUX-FRANCAIS, French Southern Territories

WMO: 619980

Lat: 49.3522S

Lon: 70.2433E

Elev: 98

StdP: 14.64

Time Zone: 5.00 (E05)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	26.3	27.9	18.5	14.0	30.4	20.2	15.2	31.6	56.4	43.4	51.9	42.3	21.9	270	1.159

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	12.0	61.4	54.0	58.9	52.7	56.6	51.3	55.4	59.8	53.6	57.8	51.9	55.7	22.2	310

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
52.7	59.4	58.1	51.0	55.7	56.1	49.4	52.4	54.4	23.6	59.9	22.5	58.0	21.5	55.9	67.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
48.5	43.5	39.5	DB	22.4	67.9	2.2	2.1	20.8	69.4	19.5	70.6	18.3	71.8	16.7	73.3
			WB	21.0	59.6	2.2	1.6	19.4	60.8	18.1	61.7	16.9	62.6	15.3	63.8

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	41.0	46.6	47.2	45.9	43.2	39.0	36.8	36.1	36.2	36.8	38.9	41.1	44.6
	DBStd	5.93	4.11	4.25	4.33	4.64	4.28	4.46	4.40	4.65	4.10	4.28	3.92	3.92
	HDD50	3359	123	100	142	211	343	397	430	429	396	345	269	174
	HDD65	8761	571	498	591	654	807	847	895	894	846	809	718	631
	CDD50	72	17	21	16	7	1	0	0	0	0	1	1	8
	CDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH74	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDH80	0	0	0	0	0	0	0	0	0	0	0	0	0
Wind	WSAvg	21.4	21.0	19.7	20.4	20.2	21.4	21.4	21.8	22.7	23.3	22.3	21.9	20.5
Precipitation	PrecAvg	26.5	2.0	1.7	2.4	2.2	2.8	2.9	2.6	2.1	2.0	1.9	1.9	2.0
	PrecMax	36.4	3.3	3.3	5.2	7.4	5.9	6.7	4.7	4.6	4.9	4.6	4.0	5.4
	PrecMin	17.5	0.2	0.4	1.1	0.4	0.7	0.5	0.8	0.4	0.7	0.4	0.6	0.5
	PrecStd	5.9	0.8	0.8	1.1	1.5	1.5	1.6	1.1	0.9	1.0	1.0	0.9	1.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	64.7	65.5	63.3	60.3	54.3	51.9	51.0	51.2	52.7	55.5	58.6	62.2
		MCWB	55.5	57.1	55.8	55.3	50.7	48.5	47.5	47.1	48.2	49.2	49.7	53.6
	2%	DB	60.2	61.0	59.4	57.2	51.6	49.2	48.7	48.7	49.2	51.3	53.3	57.6
		MCWB	52.7	53.9	53.8	53.4	48.8	46.3	46.0	45.7	45.4	46.6	47.5	50.8
	5%	DB	57.3	58.0	56.4	54.2	49.3	46.6	46.7	46.7	46.7	48.4	50.4	54.4
		MCWB	51.2	52.3	51.9	50.8	46.5	44.1	44.4	43.9	43.5	44.4	45.7	48.7
	10%	DB	54.4	55.3	53.7	51.6	46.8	44.1	44.1	44.2	44.2	46.2	48.1	52.0
		MCWB	48.9	50.5	50.0	48.3	43.9	41.6	41.6	41.5	41.1	42.6	43.6	46.6
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	57.1	58.4	56.7	55.8	51.5	48.8	48.2	47.9	48.7	50.3	51.1	54.3
		MCDB	62.2	64.5	61.5	59.1	53.8	51.3	50.5	50.3	51.7	54.0	56.2	60.0
	2%	WB	54.2	55.2	54.3	53.4	49.1	46.6	46.3	45.8	45.8	47.2	48.6	51.8
		MCDB	59.0	59.7	58.4	56.8	51.3	48.9	48.4	48.2	48.4	50.5	52.3	56.4
	5%	WB	51.7	53.1	52.4	51.1	46.9	44.5	44.6	44.0	43.8	44.9	46.4	49.7
		MCDB	56.3	57.0	55.9	53.9	49.2	46.4	46.7	46.3	46.5	47.8	49.8	53.7
	10%	WB	49.5	51.0	50.4	48.7	44.0	41.9	42.0	41.5	41.2	42.9	44.3	47.4
		MCDB	53.9	54.9	53.6	51.4	46.6	43.9	44.2	43.9	43.9	46.0	47.7	51.3
Mean Daily Temperature Range	5% DB	MDBR	12.1	12.0	11.6	10.5	8.7	8.2	8.6	8.9	9.4	10.6	10.9	11.7
		MCDBR	17.3	16.9	16.0	14.7	13.7	12.8	12.6	12.9	13.5	14.5	15.1	15.8
		MCWBR	12.7	12.2	13.2	13.0	13.1	12.3	12.2	11.9	12.5	12.2	12.1	12.1
	5% WB	MCDBR	16.3	15.8	15.6	14.6	13.7	12.9	12.5	13.0	13.3	14.4	14.4	15.4
		MCWBR	13.3	12.5	13.7	13.4	13.5	12.7	12.4	12.4	12.8	13.0	12.8	12.9
Clear-Sky Solar Irradiance	taub	0.344	0.336	0.334	0.322	0.326	0.327	0.336	0.350	0.347	0.349	0.338	0.341	
	taud	2.484	2.524	2.518	2.520	2.330	2.233	2.228	2.264	2.366	2.401	2.466	2.477	
	Ebn at Noon	307	299	281	256	213	189	202	235	270	291	307	311	
	Edh at Noon	35	31	28	23	21	20	23	28	32	35	35	36	
All-Sky Solar Radiation	RadAvg	1663	1398	986	584	329	222	258	458	829	1230	1570	1780	
	RadStd	95	77	55	29	18	11	20	33	54	65	95	106	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page