

SIRTE, Libyan Arab Jamahiriya

WMO: 620190

Lat: 31.208N

Lon: 16.572E

Elev: 43

StdP: 14.67

Time Zone: 2.00 (E02)

Period: 94-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	48.8	50.3	30.9	25.2	64.2	33.9	28.6	62.4	33.3	60.0	29.7	59.0	8.3	210	0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 10.7	(c) 98.3	(d) 71.6	(e) 93.5	(f) 71.8	(g) 89.8	(h) 72.7	(i) 80.7	(j) 87.0	(k) 79.8	(l) 85.7	(m) 78.8	(n) 84.6	(o) 13.0	(p) 180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
79.0	150.7	84.6	78.0	145.9	83.8	77.1	141.3	83.1	44.3	87.6	43.3	85.7	42.3	84.4	87.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a) 28.6	(b) 22.6	(c) 19.5	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		
(a) 28.6	(b) 22.6	(c) 19.5	(e) N/A	(f) N/A	(g) N/A	(h) N/A	(i) N/A	(j) N/A	(k) N/A	(l) N/A	(m) N/A	(n) N/A	(o) N/A	(p) N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	70.5	59.5	59.6	62.6	67.3	72.5	77.0	80.4	82.2	81.0	75.3	67.4	60.9
	DBStd	9.63	3.27	4.80	5.46	6.78	6.81	5.52	3.17	2.72	3.66	4.82	4.82	4.57
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	674	177	168	116	39	4	0	0	0	0	0	24	146
	CDD50	7486	294	268	390	518	696	811	942	997	929	783	521	337
	CDD65	2686	6	15	41	107	236	361	477	532	479	319	95	18
	CDH74	23496	47	119	261	770	1601	2631	4701	6007	4805	2065	405	84
CDH80	7881	9	36	88	387	754	934	1359	2112	1540	538	107	17	
Wind	WSAvg	9.0	9.2	9.8	9.6	10.3	9.5	8.8	7.8	7.9	9.0	8.5	8.2	8.9
Precipitation	PrecAvg	6.9	1.5	0.8	0.6	0.2	0.1	0.0	0.0	0.0	0.3	0.9	1.0	1.9
	PrecMax	13.3	6.1	4.1	2.3	1.1	0.9	0.4	1.5	0.2	1.4	4.1	2.9	8.7
	PrecMin	2.7	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.7	1.3	0.9	0.6	0.3	0.2	0.1	0.2	0.0	0.4	1.1	0.8	2.0
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	79.8	86.3	89.3	100.7	103.0	105.7	97.0	97.9	102.3	96.7	88.9	82.7
		MCWB	60.3	62.7	66.1	70.6	74.3	75.3	73.1	73.6	72.5	71.6	67.8	60.5
	2%	DB	72.1	78.2	81.0	90.2	94.9	95.5	91.5	92.1	93.4	90.6	83.3	75.4
		MCWB	57.2	60.0	61.3	66.8	69.8	70.9	73.2	74.8	75.3	70.0	66.2	59.7
	5%	DB	68.2	72.0	75.5	82.8	87.9	89.2	87.6	88.8	88.9	85.4	78.3	71.7
		MCWB	56.7	57.8	59.5	64.0	67.3	69.0	75.3	77.1	75.1	70.8	64.7	57.6
	10%	DB	65.6	67.1	70.8	75.8	82.4	84.4	85.8	87.2	86.7	82.4	75.3	68.4
		MCWB	56.5	57.4	58.8	62.3	65.3	71.1	76.0	77.7	75.6	71.5	64.8	57.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.0	65.0	67.3	73.1	78.6	79.7	81.4	82.0	81.6	78.5	73.3	65.6
		MCDB	70.7	76.7	78.5	89.4	95.4	89.9	86.0	87.6	88.4	83.5	79.9	74.4
	2%	WB	61.0	62.3	64.6	69.1	72.4	77.5	79.8	80.8	80.3	76.3	70.5	63.1
		MCDB	67.9	72.7	73.9	82.4	85.1	85.4	84.6	86.8	86.3	82.1	76.4	69.3
	5%	WB	59.5	60.6	62.8	66.6	70.7	75.7	78.8	79.9	79.1	74.6	68.5	61.7
		MCDB	65.3	69.5	69.3	75.0	80.0	82.0	84.0	85.9	84.7	80.9	74.9	67.8
	10%	WB	58.4	58.9	61.3	65.4	69.2	74.5	77.8	79.0	77.9	73.1	66.5	60.0
		MCDB	63.7	65.5	67.4	71.8	77.2	80.0	83.2	84.9	83.7	80.0	73.5	66.4
Mean Daily Temperature Range	5% DB	MDBR	13.0	13.3	13.1	13.8	12.7	11.6	9.9	10.7	11.3	12.6	14.3	13.7
		MCDBR	18.6	21.3	21.7	25.9	23.8	21.8	13.3	13.5	16.5	18.6	19.5	19.2
		MCWBR	11.5	11.3	11.6	11.2	10.3	10.6	8.3	7.8	9.7	10.4	11.7	12.9
	5% WB	MCDBR	14.0	16.3	15.4	18.1	16.8	13.8	11.4	11.1	12.4	13.8	14.5	14.6
		MCWBR	10.4	11.2	10.3	9.9	9.0	8.3	7.5	6.9	8.9	9.9	11.7	11.4
Clear-Sky Solar Irradiance	taub	0.398	0.432	0.498	0.560	0.560	0.489	0.469	0.471	0.521	0.475	0.428	0.406	
	taud	2.155	2.046	1.874	1.756	1.784	1.991	2.065	2.077	1.937	2.037	2.109	2.143	
	Ebn at Noon	255	258	249	239	240	257	261	259	239	241	242	244	
	Edh at Noon	40	48	62	72	70	57	53	51	57	48	41	38	
All-Sky Solar Radiation	RadAvg	1013	1291	1659	1952	2155	2345	2357	2146	1793	1396	1088	902	
	RadStd	55	77	92	92	72	97	89	45	48	61	68	41	52

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page