

SIRTE, Libyan Arab Jamahiriya

WMO: 620190

Lat: 31.208N

Lon: 16.572E

Elev: 13

StdP: 101.17

Time Zone: 2.00 (E02)

Period: 94-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.3	10.1	-0.6	3.6	17.9	1.1	4.1	16.9	14.9	15.5	13.3	15.0	3.7	210	0.402

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	6.0	36.8	22.0	34.2	22.1	32.1	22.6	27.1	30.5	26.5	29.9	26.0	29.2	5.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
26.1	21.5	29.2	25.6	20.8	28.8	25.1	20.2	28.4	85.2	30.9	82.8	29.8	80.5	29.1	30.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.8	10.1	8.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		
(5)			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	21.4	15.3	15.3	17.0	19.6	22.5	25.0	26.9	27.9	27.2	24.0	19.6	16.0		
	DBStd	5.35	1.81	2.67	3.03	3.76	3.79	3.06	1.76	1.51	2.03	2.68	2.68	2.54		
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0		
	HDD18.3	374	98	93	64	22	2	0	0	0	0	0	13	81		
	CDD10.0	4159	163	149	217	288	387	451	523	554	516	435	289	187		
	CDD18.3	1492	3	8	23	59	131	201	265	296	266	177	53	10		
	CDH23.3	13053	26	66	145	428	889	1462	2612	3337	2669	1147	225	47		
	CDH26.7	4378	5	20	49	215	419	519	755	1173	856	299	59	9		
(14) Wind	WSAvg	4.0	4.1	4.4	4.3	4.6	4.2	3.9	3.5	3.5	4.0	3.8	3.7	4.0		
(15) Precipitation	PrecAvg	176	38	20	14	5	3	1	1	0	7	24	25	47		
	PrecMax	337	154	104	58	27	23	9	37	6	36	105	74	221		
	PrecMin	68	1	0	0	0	0	0	0	0	0	0	0	0		
	PrecStd	69	32	23	14	7	5	2	6	1	10	28	21	50		
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	26.5	30.2	31.8	38.2	39.4	40.9	36.1	36.6	39.0	35.9	31.6	28.2		
		MCWB	15.7	17.0	19.0	21.4	23.5	24.1	22.8	23.1	22.5	22.0	19.9	15.8		
	2%	DB	22.3	25.7	27.2	32.3	34.9	35.3	33.0	33.4	34.1	32.6	28.5	24.1		
		MCWB	14.0	15.6	16.3	19.3	21.0	21.6	22.9	23.8	24.1	21.1	19.0	15.4		
	5%	DB	20.1	22.2	24.2	28.2	31.0	31.8	30.9	31.6	31.6	29.7	25.7	22.1		
		MCWB	13.7	14.4	15.3	17.8	19.6	20.6	24.0	25.1	24.0	21.5	18.2	14.2		
	10%	DB	18.7	19.5	21.6	24.3	28.0	29.1	29.9	30.6	30.4	28.0	24.0	20.2		
		MCWB	13.6	14.1	14.9	16.8	18.5	21.7	24.5	25.4	24.2	21.9	18.2	14.4		
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.2	18.3	19.6	22.8	25.9	26.5	27.4	27.8	27.5	25.8	23.0	18.6		
		MCDB	21.5	24.8	25.8	31.9	35.2	32.2	30.0	30.9	31.4	28.6	26.6	23.5		
	2%	WB	16.1	16.8	18.1	20.6	22.5	25.3	26.5	27.1	26.8	24.6	21.4	17.3		
		MCDB	19.9	22.6	23.3	28.0	29.5	29.6	29.2	30.5	30.2	27.8	24.6	20.7		
	5%	WB	15.3	15.9	17.1	19.2	21.5	24.3	26.0	26.6	26.2	23.7	20.3	16.5		
		MCDB	18.5	20.8	20.7	23.9	26.7	27.8	28.9	30.0	29.3	27.2	23.9	19.9		
	10%	WB	14.7	14.9	16.3	18.5	20.7	23.6	25.5	26.1	25.5	22.8	19.2	15.6		
		MCDB	17.6	18.6	19.7	22.1	25.1	26.7	28.5	29.4	28.7	26.7	23.1	19.1		
(35) Mean Daily Temperature Range	5% DB	MDBR	7.2	7.4	7.3	7.6	7.1	6.5	5.5	6.0	6.3	7.0	7.9	7.6		
		MCDBR	10.3	11.8	12.1	14.4	13.2	12.1	7.4	7.5	9.1	10.3	10.9	10.7		
	5% WB	MCWBR	6.4	6.3	6.4	6.2	5.7	5.9	4.6	4.4	5.4	5.8	6.5	7.2		
		MCWBR	7.8	9.0	8.5	10.0	9.3	7.7	6.4	6.2	6.9	7.7	8.1	8.1		
(40) Clear-Sky Solar Irradiance	taub		0.398	0.432	0.498	0.560	0.560	0.489	0.469	0.471	0.521	0.475	0.428	0.406		
		taud	2.155	2.046	1.874	1.756	1.784	1.991	2.065	2.077	1.937	2.037	2.109	2.143		
	Ebn at Noon		805	813	785	754	756	809	823	817	755	759	763	770		
		Edh at Noon	125	152	194	227	222	180	166	162	180	152	130	120		
(44) All-Sky Solar Radiation	RadAvg		3.19	4.07	5.23	6.15	6.79	7.39	7.43	6.77	5.65	4.40	3.43	2.84		
	RadStd		0.17	0.24	0.29	0.23	0.31	0.28	0.14	0.15	0.19	0.21	0.13	0.16		

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page