

AJDABIYA, Libyan Arab Jamahiriya

WMO: 620550

Lat: 30.717N

Lon: 20.167E

Elev: 23

StdP: 14.68

Time Zone: 2.00 (E02)

Period: 90-11

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	43.8	45.5	24.3	18.5	71.7	28.4	22.4	68.5	25.5	62.3	22.6	63.5	1.1	180	0.408

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	18.5	102.0	70.1	98.4	69.9	95.4	69.6	77.3	88.5	76.0	86.1	75.0	84.8	9.7	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
74.5	129.3	81.5	73.3	123.9	80.6	72.2	119.3	80.6	40.7	88.7	39.4	86.4	38.5	84.3	

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
23.3	20.8	18.5	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	70.7	57.1	57.5	62.3	68.8	75.6	81.1	81.3	82.4	81.3	75.1	66.0	58.9
	DBStd	10.82	3.21	4.97	5.72	6.81	6.98	5.82	3.21	2.84	4.88	5.01	4.65	4.19
	HDD50	1	0	1	0	0	0	0	0	0	0	0	0	0
	HDD65	852	247	219	123	28	1	0	0	0	0	1	37	196
	CDD50	7552	219	211	383	565	793	932	971	1004	939	779	481	275
	CDD65	2929	1	8	41	144	328	482	506	539	489	316	69	6
	CDH74	30093	5	71	373	1409	3311	5396	5226	5893	5282	2625	468	34
	CDH80	13847	1	15	98	607	1642	2858	2328	2659	2526	995	116	2
(14) Wind	WSAvg	7.3	5.5	7.0	7.3	9.1	9.1	8.2	8.8	8.2	7.2	6.4	5.5	5.8
(15) Precipitation	PrecAvg	5.9	1.8	0.7	0.4	0.2	0.0	0.0	0.0	0.0	0.1	0.3	0.7	1.5
	PrecMax	11.3	7.8	2.4	1.3	1.2	0.6	0.0	0.0	0.0	1.4	1.9	2.6	4.1
	PrecMin	3.2	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	2.0	1.3	0.7	0.3	0.3	0.1	0.0	0.0	0.0	0.2	0.4	0.7	1.2
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	73.7	82.2	88.8	99.1	104.0	106.3	102.4	100.4	105.1	97.5	88.7	78.4
		MCWB	54.5	57.4	60.3	62.6	69.5	71.0	69.7	73.0	72.7	68.4	64.3	57.6
	2%	DB	69.6	75.0	81.9	91.6	97.7	101.9	97.1	96.1	99.9	92.9	82.9	72.6
		MCWB	54.6	55.6	57.8	63.2	66.8	70.2	71.4	72.4	73.5	67.0	62.1	56.9
	5%	DB	66.9	69.8	77.7	87.1	93.3	98.1	93.0	92.9	95.7	89.3	79.1	69.8
		MCWB	54.9	55.5	56.8	60.8	66.4	68.8	71.1	72.2	72.0	66.5	61.4	56.8
	10%	DB	65.0	66.6	73.7	82.4	89.2	93.8	89.9	90.4	92.0	85.8	75.8	67.5
		MCWB	54.5	54.3	56.0	60.1	65.0	68.5	71.1	72.7	70.5	66.3	60.7	56.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	59.9	61.1	64.3	68.3	75.3	77.1	77.6	78.6	82.6	73.8	68.6	62.8
		MCDB	67.0	75.0	78.1	89.0	93.5	95.7	90.9	87.5	97.5	86.5	76.9	70.7
	2%	WB	57.9	58.9	61.7	65.2	70.7	74.0	76.0	77.1	77.4	71.4	65.8	60.3
		MCDB	65.0	70.3	73.3	83.0	89.4	89.3	85.9	86.3	89.1	83.2	76.1	68.0
	5%	WB	56.5	57.3	59.7	63.2	68.5	71.9	75.0	76.1	75.3	70.1	63.9	59.1
		MCDB	63.9	65.9	71.1	80.2	86.4	86.8	83.9	85.1	86.5	81.6	75.3	66.6
	10%	WB	55.5	56.0	58.1	61.6	66.8	70.6	74.0	75.2	73.7	68.8	62.4	57.6
		MCDB	63.0	64.1	69.6	77.4	82.8	85.4	83.1	84.1	85.0	80.4	73.3	65.2
(35) Mean Daily Temperature Range	5% DB	MDBR	16.9	17.4	20.0	20.9	20.9	21.6	18.6	18.5	20.1	20.2	19.3	16.6
		MCDBR	19.5	22.5	26.2	27.7	27.3	27.5	23.6	21.7	24.4	24.6	22.7	20.1
		MCWBR	10.2	10.4	10.5	10.5	10.7	9.9	8.4	7.6	9.8	9.7	10.9	10.6
	5% WB	MCDBR	17.3	18.6	22.0	24.1	23.1	22.9	18.7	18.7	20.2	20.1	20.7	17.3
		MCWBR	10.8	11.0	10.9	11.0	11.0	9.7	7.6	7.8	10.6	10.0	12.3	11.2
(40) Clear-Sky Solar Irradiance	taub		0.394	0.437	0.486	0.549	0.546	0.478	0.450	0.453	0.493	0.456	0.411	0.399
	taud		2.131	1.990	1.856	1.730	1.763	1.972	2.070	2.078	1.951	2.042	2.114	2.135
	Ebn at Noon		257	257	252	242	244	259	266	265	248	247	249	248
	Edh at Noon		41	51	63	74	72	58	53	51	56	48	41	39
(44) All-Sky Solar Radiation	RadAvg		1087	1361	1804	2115	2334	2540	2535	2324	1973	1540	1177	963
	RadStd		48	83	68	76	112	68	27	33	45	65	47	47

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page