

SALLUM, Egypt

WMO: 623050

Lat: 31.570N

Lon: 25.132E

Elev: 581

StdP: 14.39

Time Zone: 2.00 (E02)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	42.9	44.7	24.9	19.4	65.9	28.7	23.2	62.5	32.0	58.4	29.0	56.7	11.4	270	0.461

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	15.9	94.5	68.2	91.1	69.2	88.8	69.6	76.1	83.4	75.1	82.4	74.1	81.6	14.9	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
74.3	131.0	78.6	73.0	125.3	78.4	71.9	120.5	77.9	40.0	83.4	39.0	82.3	38.0	81.5	81.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
27.3	23.5	20.9	DB	39.9	101.7	2.8	3.3	37.8	104.1	36.2	106.0	34.6	107.9	32.6	110.2	
			WB	35.9	78.6	2.7	1.3	33.9	79.5	32.3	80.2	30.7	81.0	28.7	81.9	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	67.5	54.2	55.5	60.2	64.6	69.4	75.2	79.1	79.5	77.2	71.5	64.6	57.8	(6)
(7)		DBStd	9.87	3.74	5.35	6.09	5.64	5.11	4.30	2.92	2.61	4.10	4.39	4.13	3.79	(7)
(8)		HDD50	14	7	5	1	0	0	0	0	0	0	0	0	1	(8)
(9)		HDD65	1151	334	274	178	72	10	0	0	0	0	3	55	225	(9)
(10)		CDD50	6393	139	160	318	438	602	757	901	916	816	665	437	244	(10)
(11)		CDD65	2055	1	9	30	59	147	307	436	451	366	203	42	4	(11)
(12)		CDH74	16578	6	74	245	469	962	2438	4076	4251	2904	999	141	13	(12)
(13)		CDH80	5744	0	25	84	169	345	812	1565	1588	911	225	20	0	(13)
(14)	Wind	WSAvg	10.3	11.3	11.4	10.4	10.5	10.2	10.5	10.9	10.1	9.5	9.1	9.2	11.0	(14)
(15)	Precipitation	PrecAvg	3.6	0.9	0.6	0.2	0.1	0.2	0.0	0.0	0.0	0.1	0.3	0.4	0.6	(15)
(16)		PrecMax	9.4	2.3	1.9	0.9	0.6	2.4	0.0	0.0	0.1	0.4	1.7	1.7	4.5	(16)
(17)		PrecMin	0.8	0.1	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	(17)
(18)		PrecStd	2.0	0.6	0.6	0.3	0.2	0.5	0.0	0.0	0.0	0.1	0.4	0.5	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.6	83.6	89.3	92.7	97.0	96.9	95.5	99.5	92.5	83.3	75.7	(19)	
(20)			MCWB	54.3	57.3	58.6	61.0	63.6	66.3	70.7	72.0	67.9	65.0	60.9	55.6	(20)
(21)		2%	DB	67.3	73.7	80.3	84.4	88.5	90.8	91.6	91.7	92.1	85.7	78.0	70.6	(21)
(22)			MCWB	52.5	53.0	56.5	58.9	63.4	68.0	70.9	71.6	69.1	64.9	60.9	55.8	(22)
(23)		5%	DB	64.1	67.6	74.5	79.1	82.8	87.4	89.3	89.1	87.5	81.5	74.9	67.5	(23)
(24)			MCWB	52.8	52.7	55.6	57.8	63.1	68.9	70.9	71.7	69.7	66.7	61.8	56.4	(24)
(25)		10%	DB	62.0	63.8	69.6	74.3	78.5	84.4	87.3	87.1	84.4	78.9	72.3	65.3	(25)
(26)			MCWB	52.4	52.5	55.2	58.0	61.9	68.3	70.9	71.9	70.4	67.0	61.1	55.3	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	58.5	60.0	62.0	65.5	68.4	74.5	77.0	77.9	76.4	73.3	69.8	62.7	(27)
(28)			MCDWB	64.3	68.0	71.4	75.8	80.3	84.2	84.6	84.5	83.2	79.0	73.4	67.0	(28)
(29)		2%	WB	56.5	57.3	60.2	62.9	66.6	72.8	75.6	76.4	74.8	71.3	66.8	60.0	(29)
(30)			MCDWB	62.6	66.4	68.5	73.7	76.7	81.6	83.2	83.5	81.7	77.7	71.8	65.4	(30)
(31)		5%	WB	54.9	55.5	58.8	61.6	65.6	71.7	74.5	75.4	73.6	70.0	64.5	58.1	(31)
(32)			MCDWB	61.3	63.3	67.4	70.9	75.2	80.7	82.0	82.6	80.6	76.7	70.5	64.3	(32)
(33)		10%	WB	53.5	54.0	57.5	60.4	64.5	70.4	73.5	74.5	72.6	68.7	62.8	56.5	(33)
(34)			MCDWB	60.2	61.8	66.3	68.7	74.0	79.3	81.1	81.9	80.0	75.8	69.8	63.1	(34)
(35)	Mean Daily Temperature Range	MDBR	14.9	15.1	15.7	16.8	16.6	16.7	16.7	15.9	15.5	14.9	14.9	14.5	(35)	
(36)		5% DB	MCDDBR	18.1	20.5	23.1	24.7	23.6	20.9	19.6	18.6	20.3	18.3	17.4	16.9	(36)
(37)			MCWBR	9.5	9.3	8.7	9.5	8.9	7.3	6.5	5.9	7.8	7.4	8.4	8.8	(37)
(38)		5% WB	MCDDBR	15.3	15.9	16.8	17.8	17.3	17.6	16.4	15.8	15.3	14.7	14.3	14.6	(38)
(39)			MCWBR	9.5	9.2	8.8	8.6	7.9	7.5	7.0	6.5	7.5	7.2	8.8	8.9	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.369	0.414	0.452	0.499	0.490	0.431	0.413	0.414	0.444	0.417	0.382	0.373	(40)	
(41)		taud	2.210	2.051	1.937	1.841	1.901	2.104	2.163	2.170	2.083	2.161	2.213	2.211	(41)	
(42)		Ebn at Noon	265	263	262	254	257	272	276	275	261	259	258	256	(42)	
(43)		Edh at Noon	37	48	57	66	62	51	48	47	49	42	37	35	(43)	
(44)	All-Sky Solar Radiation	RadAvg	975	1237	1653	2031	2251	2449	2422	2222	1882	1449	1088	880	(44)	
(45)		RadStd	49	82	66	65	86	57	40	32	39	54	45	43	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	(47)

Nomenclature: See separate page