

SALLUM, Egypt

WMO: 623050

Lat: 31.570N

Lon: 25.132E

Elev: 177

StdP: 99.22

Time Zone: 2.00 (E02)

Period: 95-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	6.0	7.1	-3.9	2.8	18.9	-1.8	3.3	17.0	14.3	14.7	13.0	13.7	5.1	270	0.461

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a) 8	(b) 8.8	(c) 34.7	(d) 20.1	(e) 32.8	(f) 20.7	(g) 31.5	(h) 20.9	(i) 24.5	(j) 28.5	(k) 23.9	(l) 28.0	(m) 23.4	(n) 27.5	(o) 6.7	(p) 0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
23.5	18.7	25.9	22.8	17.9	25.8	22.2	17.2	25.5	75.1	28.5	72.8	27.9	70.6	27.5	27.3

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
12.2	10.5	9.3	4.4	38.7	1.6	1.8	3.2	40.1	2.3	41.1	1.4	42.1	0.3	43.5
			2.1	25.9	1.5	0.7	1.0	26.4	0.1	26.8	-0.7	27.2	-1.8	27.7
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	19.7	12.4	13.1	15.7	18.1	20.8	24.0	26.1	26.4	25.1	21.9	18.1	14.4
	DBStd	5.49	2.08	2.97	3.38	3.13	2.84	2.39	1.62	1.45	2.28	2.44	2.30	2.10
	HDD10.0	8	4	3	1	0	0	0	0	0	0	0	0	1
	HDD18.3	639	186	152	99	40	6	0	0	0	0	2	31	125
	CDD10.0	3552	77	89	177	243	334	421	501	509	453	369	243	136
	CDD18.3	1142	1	5	17	33	82	171	242	251	203	113	23	2
	CDH23.3	9210	3	41	136	261	534	1354	2264	2362	1613	555	78	7
CDH26.7	3191	0	14	47	94	192	451	869	882	506	125	11	0	
Wind	WSAvg	4.6	5.0	5.1	4.7	4.7	4.6	4.7	4.9	4.5	4.2	4.1	4.1	4.9
Precipitation	PrecAvg	91	22	14	6	3	4	0	0	0	2	7	9	16
	PrecMax	239	58	47	22	16	62	0	0	2	9	42	43	114
	PrecMin	20	3	0	0	0	0	0	0	0	0	0	0	2
	PrecStd	51	16	14	7	4	12	0	0	0	3	11	12	23
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.6	28.7	31.8	33.7	36.1	36.1	35.3	35.3	37.5	33.6	28.5	24.3
		MCWB	12.4	14.0	14.8	16.1	17.5	19.1	21.5	22.2	19.9	18.3	16.1	13.1
	2%	DB	19.6	23.2	26.8	29.1	31.4	32.7	33.1	33.1	33.4	29.9	25.6	21.5
		MCWB	11.4	11.7	13.6	14.9	17.4	20.0	21.6	22.0	20.6	18.3	16.1	13.2
	5%	DB	17.8	19.8	23.6	26.2	28.2	30.8	31.8	31.7	30.9	27.5	23.9	19.7
		MCWB	11.6	11.5	13.1	14.3	17.3	20.5	21.6	22.1	20.9	19.3	16.5	13.5
	10%	DB	16.7	17.7	20.9	23.5	25.9	29.1	30.7	30.6	29.1	26.0	22.4	18.5
		MCWB	11.3	11.4	12.9	14.4	16.6	20.2	21.6	22.2	21.3	19.5	16.1	12.9
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	14.7	15.6	16.6	18.6	20.2	23.6	25.0	25.5	24.7	22.9	21.0	17.1
		MCDB	17.9	20.0	21.9	24.3	26.8	29.0	29.2	29.2	28.4	26.1	23.0	19.4
	2%	WB	13.6	14.1	15.7	17.2	19.2	22.7	24.2	24.7	23.8	21.8	19.3	15.5
		MCDB	17.0	19.1	20.3	23.1	24.8	27.6	28.4	28.6	27.6	25.4	22.1	18.6
	5%	WB	12.7	13.1	14.9	16.4	18.6	22.1	23.6	24.1	23.1	21.1	18.0	14.5
		MCDB	16.3	17.4	19.7	21.6	24.0	27.0	27.8	28.1	27.0	24.9	21.4	18.0
	10%	WB	11.9	12.2	14.2	15.8	18.1	21.4	23.0	23.6	22.6	20.4	17.1	13.6
		MCDB	15.7	16.6	19.1	20.4	23.3	26.3	27.3	27.7	26.7	24.3	21.0	17.3
Mean Daily Temperature Range	5% DB	MDBR	8.3	8.4	8.7	9.3	9.2	9.3	9.3	8.8	8.6	8.3	8.3	8.1
		MCDBR	10.0	11.4	12.8	13.7	13.1	11.6	10.9	10.3	11.3	10.2	9.7	9.4
		MCWBR	5.3	5.1	4.8	5.3	4.9	4.1	3.6	3.3	4.4	4.1	4.7	4.9
	5% WB	MCDBR	8.5	8.8	9.3	9.9	9.6	9.8	9.1	8.8	8.5	8.2	7.9	8.1
		MCWBR	5.3	5.1	4.9	4.8	4.4	4.2	3.9	3.6	4.1	4.0	4.9	5.0
Clear-Sky Solar Irradiance	taub	0.369	0.414	0.452	0.499	0.490	0.431	0.413	0.414	0.444	0.417	0.382	0.373	
	taud	2.210	2.051	1.937	1.841	1.901	2.104	2.163	2.170	2.083	2.161	2.213	2.211	
	Ebn at Noon	836	829	825	802	811	857	871	867	823	817	814	807	
	Edh at Noon	117	151	181	208	197	161	151	148	155	133	116	111	
All-Sky Solar Radiation	RadAvg	3.07	3.90	5.21	6.40	7.09	7.72	7.64	7.00	5.93	4.57	3.43	2.77	
	RadStd	0.15	0.26	0.21	0.20	0.27	0.18	0.13	0.10	0.12	0.17	0.14	0.14	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page