

BALTIM, EgyptWMO: **623250**Lat: **31.5539N**Lon: **31.0844E**Elev: **7**StdP: **14.69**Time Zone: **2.00 (E02)**Period: **94-17**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	47.8	49.6	38.5	34.3	53.1	40.6	37.3	54.1	22.7	53.8	19.3	56.9	5.3	180	0.318

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	10.7	90.6	76.5	88.8	76.7	87.4	76.3	79.5	87.2	78.4	86.1	77.5	85.1	7.1	290

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
77.2	141.6	84.6	76.1	136.6	83.9	75.2	132.3	83.2	43.0	87.4	42.0	86.4	41.1	85.4	86.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4)	18.6	15.6	13.2	DB	43.7	99.8	4.0	2.9	40.8	101.9	38.4	103.6	36.1	105.2	33.2	107.3
(5)				WB	41.8	81.3	3.2	2.4	39.5	83.1	37.6	84.4	35.8	85.8	33.5	87.5

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	70.3	58.1	58.9	62.0	66.5	71.7	77.6	81.0	82.2	79.7	74.8	68.5	61.6	(6)
(7)		DBStd	9.09	3.29	3.81	4.06	4.12	3.85	3.14	2.02	1.91	2.38	3.14	3.89	3.67	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	654	215	174	110	25	1	0	0	0	0	0	12	117	(9)
(10)		CDD50	7400	251	250	372	496	672	828	960	997	891	768	556	359	(10)
(11)		CDD65	2579	1	4	17	71	208	378	495	532	441	303	118	11	(11)
(12)		CDH74	20960	3	23	93	294	918	2894	5003	5860	3998	1604	258	12	(12)
(13)		CDH80	5926	0	3	25	78	204	741	1534	2005	1068	244	24	0	(13)
(14)	Wind	WSAvg	5.5	5.1	5.6	5.9	6.1	5.6	6.4	6.8	6.5	5.2	4.3	4.1	4.1	(14)
(15)	Precipitation	PrecAvg	6.3	1.7	1.5	0.6	0.2	0.0	0.0	0.0	0.0	0.3	0.8	1.5	(15)	
(16)		PrecMax	12.1	3.6	3.4	1.9	0.7	0.6	0.0	0.0	0.2	1.5	3.2	4.4	(16)	
(17)		PrecMin	1.5	0.2	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)	
(18)		PrecStd	2.5	1.1	1.0	0.5	0.2	0.1	0.0	0.0	0.0	0.4	0.8	1.1	(18)	
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	72.8	77.6	82.5	88.3	92.6	92.8	92.4	91.8	92.0	88.0	83.2	75.8	(19)
(20)		MCWB	61.0	63.9	66.2	69.1	72.4	75.1	76.7	78.5	76.4	74.8	69.4	66.4	(20)	
(21)		2%	DB	68.4	70.8	75.3	80.9	85.2	88.6	89.1	89.8	88.5	84.5	78.8	71.8	(21)
(22)		MCWB	59.5	60.4	63.0	66.5	69.5	74.2	77.4	78.4	76.5	73.1	68.5	62.9	(22)	
(23)		5%	DB	66.2	67.5	71.3	76.6	81.0	86.0	87.6	88.5	86.6	82.6	76.8	69.8	(23)
(24)		MCWB	58.0	58.8	61.4	64.8	68.8	74.5	76.7	77.9	75.6	72.0	67.1	61.5	(24)	
(25)		10%	DB	64.4	65.4	68.4	73.4	78.4	83.9	86.3	87.3	85.1	80.9	74.9	68.0	(25)
(26)		MCWB	57.0	57.8	60.3	63.6	68.2	73.3	76.2	77.3	74.7	71.0	65.9	60.2	(26)	
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.2	65.2	67.8	70.4	73.2	78.1	80.2	81.0	79.7	77.0	72.1	68.0	(27)
(28)		MCD B	69.5	75.0	80.4	84.9	88.0	87.3	88.3	88.8	87.4	84.5	78.6	73.8	(28)	
(29)		2%	WB	60.8	61.9	64.3	67.7	71.2	76.6	78.8	79.9	77.8	74.6	70.1	64.7	(29)
(30)		MCD B	66.8	68.6	73.1	78.4	80.9	85.4	86.9	87.5	85.6	82.0	76.7	70.0	(30)	
(31)		5%	WB	59.2	59.9	62.4	65.8	70.0	75.5	77.8	79.0	76.7	73.2	68.4	62.7	(31)
(32)		MCD B	64.8	65.9	69.2	74.4	79.0	83.9	85.7	86.5	84.4	80.5	75.0	68.1	(32)	
(33)		10%	WB	57.7	58.5	61.0	64.3	68.9	74.2	77.0	78.1	75.7	72.0	67.0	61.0	(33)
(34)		MCD B	63.2	64.4	67.3	72.0	77.2	82.2	84.6	85.4	83.4	79.1	73.6	66.9	(34)	
(35)	Mean Daily Temperature Range		MDBR	12.5	12.3	12.5	12.9	12.7	11.8	10.7	10.7	11.1	11.7	12.0	12.3	(35)
(36)		5% DB	MCD BR	15.3	16.5	18.2	19.6	18.1	15.4	12.4	11.9	13.2	13.6	13.6	14.2	(36)
(37)		MCWBR	8.4	8.5	8.5	8.4	6.7	5.8	4.7	4.4	5.3	5.8	6.3	7.7	(37)	
(38)		5% WB	MCD BR	14.6	14.8	15.7	17.5	15.4	13.7	11.8	11.3	12.5	13.1	12.7	13.2	(38)
(39)		MCWBR	8.5	8.2	8.2	8.4	6.7	6.0	5.0	4.7	5.5	6.2	6.4	7.5	(39)	
(40)	Clear-Sky Solar Irradiance	taub	0.395	0.436	0.467	0.506	0.500	0.431	0.426	0.435	0.435	0.436	0.401	0.389	(40)	
(41)		taud	2.241	2.100	2.018	1.942	2.001	2.250	2.263	2.241	2.245	2.232	2.308	2.295	(41)	
(42)		Ebn at Noon	257	256	258	253	255	272	273	269	265	254	254	252	(42)	
(43)		Edh at Noon	36	46	53	60	57	44	43	44	42	40	34	33	(43)	
(44)	All-Sky Solar Radiation	RadAvg	970	1219	1649	2021	2319	2489	2414	2193	1882	1442	1072	879	(44)	
(45)		RadStd	41	81	61	83	72	40	33	34	27	50	47	29	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days				
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65	
(46)	Station Only	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(46)
		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47)	Regional (5 neighbors)	+0.99	N/A	-1.17	+0.95	+0.67	N/A	N/A	-104	+358	+254	(47)