

PORT SAID EL GAMIL, Egypt

WMO: 623320

Lat: 31.279N

Lon: 32.238E

Elev: 20

StdP: 14.69

Time Zone: 2.00 (E02)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	49.3	51.4	38.1	33.8	57.1	40.7	37.4	56.9	30.1	56.0	27.6	55.7	13.8	240	0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	9.7	89.9	77.5	88.2	77.7	87.5	77.5	80.6	86.8	79.5	85.7	78.8	84.9	10.5	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.9	150.2	85.2	77.4	142.6	84.3	76.8	139.8	84.0	44.4	87.0	43.3	86.0	42.3	85.0	87.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
23.4	21.0	19.0	DB	45.0	99.7	2.5	4.5	43.1	102.9	41.6	105.5	40.2	108.0	38.4	111.3
			WB	41.6	83.4	2.5	2.0	39.9	84.8	38.4	86.0	37.0	87.1	35.2	88.6

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	71.5	59.1	60.2	63.4	67.5	72.9	78.4	82.0	83.1	81.1	76.8	70.2	62.4	(6)
	DBStd	9.11	3.19	3.69	4.36	4.37	3.64	2.82	2.13	1.56	2.13	3.16	4.16	3.70	(7)
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
	HDD65	525	184	138	80	17	0	0	0	0	0	0	9	97	(9)
	CDD50	7843	283	287	415	524	710	852	992	1027	932	831	606	384	(10)
	CDD65	2892	1	5	30	91	245	402	527	562	482	366	165	16	(11)
	CDH74	23735	2	14	125	264	904	3079	5571	6394	4768	2270	337	7	(12)
	CDH80	6383	0	3	41	82	141	624	1737	2210	1226	296	23	0	(13)
(14) Wind	WSAvg	10.3	9.9	10.6	11.6	11.7	10.9	10.4	10.1	9.6	9.7	9.7	9.8	9.5	(14)
(15) Precipitation	PrecAvg	2.6	0.5	0.4	0.4	0.2	0.0	0.0	0.0	0.0	0.0	0.2	0.4	0.6	(15)
	PrecMax	6.7	2.1	1.5	1.2	0.9	0.2	0.0	0.0	0.0	0.0	1.3	1.4	3.1	(16)
	PrecMin	1.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	(17)
	PrecStd	1.2	0.5	0.4	0.3	0.3	0.0	0.0	0.0	0.0	0.0	0.4	0.4	0.7	(18)
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	71.5	75.1	85.6	89.9	88.3	91.3	91.8	91.5	90.9	86.8	82.6	74.8	(19)
		MCWB	58.5	60.5	64.0	66.2	69.8	76.3	78.6	79.2	75.6	75.6	71.3	65.2	(20)
	2%	DB	67.9	70.0	76.7	80.2	82.8	86.8	89.6	89.6	87.8	84.4	79.1	71.7	(21)
		MCWB	58.9	59.6	62.1	65.4	70.7	75.7	78.1	79.1	77.7	74.7	70.7	63.1	(22)
	5%	DB	66.2	67.7	71.6	75.6	80.6	84.6	87.9	88.1	86.2	82.7	77.2	69.9	(23)
		MCWB	58.4	59.4	61.8	65.7	70.5	75.0	77.8	78.7	76.6	73.5	69.0	62.0	(24)
	10%	DB	64.6	65.9	68.4	73.2	78.6	83.4	86.3	87.5	85.1	81.4	75.5	68.1	(25)
		MCWB	57.4	58.4	60.7	64.6	69.6	74.3	77.1	78.3	75.7	72.7	67.7	60.8	(26)
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	63.7	65.4	68.3	70.7	75.0	78.9	81.5	82.6	80.8	79.3	74.5	68.4	(27)
		MCDB	66.1	69.8	77.9	78.7	82.5	85.8	88.5	87.3	85.8	84.3	79.0	71.9	(28)
	2%	WB	61.7	62.9	65.3	68.5	72.9	77.5	79.9	81.0	79.3	77.2	72.3	65.3	(29)
		MCDB	65.1	66.9	71.6	76.0	80.0	84.3	86.7	86.8	85.0	82.1	77.2	69.6	(30)
	5%	WB	60.1	61.1	63.6	67.0	71.6	76.4	79.0	79.9	78.1	75.6	70.6	63.3	(31)
		MCDB	64.2	65.1	69.1	73.8	78.2	83.0	85.4	86.0	84.3	81.0	75.8	68.2	(32)
	10%	WB	58.9	59.6	62.2	65.4	70.2	75.2	78.2	79.0	77.0	74.0	69.1	61.7	(33)
		MCDB	63.4	64.1	67.2	71.9	76.8	81.8	84.6	85.2	83.5	79.9	74.7	67.0	(34)
(35) Mean Daily Temperature Range	5% DB	MDBR	11.0	10.9	10.8	10.9	10.0	9.8	10.1	9.7	9.1	9.0	9.5	10.7	(35)
		MCDBR	12.4	13.3	15.4	15.5	13.4	11.7	11.8	10.6	10.2	10.1	10.3	11.5	(36)
	5% WB	MCWBR	7.1	7.4	8.1	8.3	7.2	6.2	5.8	5.3	5.1	5.6	6.2	6.8	(37)
		MCWBR	11.0	11.3	12.3	13.2	11.6	11.0	11.1	10.0	9.5	9.1	9.2	10.3	(38)
(40) Clear-Sky Solar Irradiance	taub		0.389	0.427	0.462	0.504	0.501	0.429	0.429	0.435	0.436	0.443	0.399	0.386	(40)
		taud	2.241	2.116	2.020	1.934	1.979	2.229	2.234	2.221	2.221	2.189	2.293	2.281	(41)
	Ebn at Noon		259	260	260	254	255	272	272	269	265	252	254	254	(42)
		Edh at Noon	36	45	53	60	58	45	44	45	43	41	34	33	(43)
(44) All-Sky Solar Radiation	RadAvg		1005	1257	1672	2032	2310	2480	2404	2197	1886	1460	1101	917	(44)
	RadStd		36	72	62	83	79	42	33	28	34	49	40	30	(45)

Historical Trends

		DBAvg	Heating			Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP		HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
(47) Regional (5 neighbors)		+1.08	N/A	-2.45	N/A	N/A	N/A	N/A	-90	+382	+308	

Nomenclature: See separate page