

PORT SAID EL GAMIL, Egypt

WMO: 623320

Lat: 31.279N

Lon: 32.238E

Elev: 6

StdP: 101.25

Time Zone: 2.00 (E02)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	9.6	10.8	3.4	4.8	14.0	4.8	5.3	13.8	13.5	13.3	12.4	13.2	6.2	240	0.456

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	5.4	32.2	25.3	31.2	25.4	30.8	25.3	27.0	30.4	26.4	29.8	26.0	29.4	4.7	340

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
26.1	21.5	29.6	25.2	20.4	29.1	24.9	20.0	28.9	85.3	30.6	82.7	30.0	80.4	29.5	31.0

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
10.5	9.4	8.5	DB	7.2	37.6	1.4	2.5	6.2	39.4	5.4	40.9	4.6	42.2	3.5	44.1	45.0
			WB	5.4	28.5	1.4	1.1	4.4	29.3	3.6	30.0	2.8	30.6	1.8	31.4	32.0

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	21.9	15.1	15.7	17.4	19.7	22.7	25.8	27.8	28.4	27.3	24.9	21.2	16.9
	DBStd	5.06	1.77	2.05	2.42	2.43	2.02	1.56	1.18	0.86	1.18	1.75	2.31	2.06
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	292	102	77	44	9	0	0	0	0	0	5	54	
	CDD10.0	4357	157	159	231	291	394	473	551	571	518	462	337	213
	CDD18.3	1607	1	3	17	51	136	223	293	312	268	203	92	9
	CDH23.3	13186	1	8	69	147	502	1711	3095	3552	2649	1261	187	4
	CDH26.7	3546	0	2	23	46	78	347	965	1228	681	164	13	0
Wind	WSAvg	4.6	4.4	4.7	5.2	5.2	4.9	4.7	4.5	4.3	4.3	4.3	4.4	4.3
Precipitation	PrecAvg	67	13	10	10	5	1	0	0	0	0	5	10	16
	PrecMax	170	53	37	30	23	5	1	0	0	1	34	35	78
	PrecMin	26	1	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	31	13	9	7	7	1	0	0	0	0	9	11	17
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	22.0	23.9	29.8	32.2	31.3	32.9	33.2	33.1	32.7	30.5	28.1	23.8
		MCWB	14.7	15.8	17.8	19.0	21.0	24.6	25.9	26.2	24.2	24.2	21.8	18.5
	2%	DB	20.0	21.1	24.8	26.8	28.2	30.4	32.0	32.0	31.0	29.1	26.1	22.0
		MCWB	14.9	15.3	16.7	18.6	21.5	24.3	25.6	26.2	25.4	23.7	21.5	17.3
	5%	DB	19.0	19.9	22.0	24.2	27.0	29.2	31.1	31.2	30.1	28.2	25.1	21.0
		MCWB	14.7	15.2	16.6	18.7	21.4	23.9	25.5	25.9	24.8	23.1	20.5	16.7
	10%	DB	18.1	18.9	20.2	22.9	25.9	28.5	30.2	30.8	29.5	27.4	24.2	20.1
		MCWB	14.1	14.6	16.0	18.1	20.9	23.5	25.1	25.7	24.3	22.6	19.8	16.0
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	17.6	18.5	20.2	21.5	23.9	26.1	27.5	28.1	27.1	26.3	23.6	20.2
		MCDB	19.0	21.0	25.5	26.0	28.1	29.9	31.4	30.7	29.9	29.1	26.1	22.1
	2%	WB	16.5	17.2	18.5	20.3	22.7	25.3	26.6	27.2	26.3	25.1	22.4	18.5
		MCDB	18.4	19.4	22.0	24.4	26.7	29.0	30.4	30.4	29.4	27.8	25.1	20.9
	5%	WB	15.6	16.2	17.6	19.4	22.0	24.6	26.1	26.6	25.6	24.2	21.5	17.4
		MCDB	17.9	18.4	20.6	23.2	25.7	28.4	29.7	30.0	29.1	27.2	24.3	20.1
	10%	WB	14.9	15.3	16.8	18.6	21.2	24.0	25.7	26.1	25.0	23.3	20.6	16.5
		MCDB	17.5	17.9	19.6	22.2	24.9	27.7	29.2	29.6	28.6	26.6	23.7	19.4
Mean Daily Temperature Range	5% DB	MDBR	6.1	6.1	6.0	6.0	5.6	5.4	5.6	5.4	5.1	5.0	5.3	6.0
		MCDBR	6.9	7.4	8.6	8.6	7.4	6.5	6.6	5.9	5.6	5.6	5.7	6.4
		MCWBR	4.0	4.1	4.5	4.6	4.0	3.4	3.2	2.9	2.8	3.1	3.4	3.8
	5% WB	MCDBR	6.1	6.3	6.9	7.3	6.4	6.1	6.1	5.6	5.3	5.1	5.1	5.7
		MCWBR	4.1	4.1	4.2	4.5	3.9	3.5	3.2	3.1	3.1	3.4	3.5	4.0
Clear-Sky Solar Irradiance	taub	0.389	0.427	0.462	0.504	0.501	0.429	0.429	0.435	0.436	0.443	0.399	0.386	
	taud	2.241	2.116	2.020	1.934	1.979	2.229	2.234	2.221	2.221	2.189	2.293	2.281	
	Ebn at Noon	818	819	819	800	803	859	857	849	834	794	802	800	
	Edh at Noon	114	142	168	190	183	142	140	141	135	130	108	105	
All-Sky Solar Radiation	RadAvg	3.17	3.96	5.27	6.41	7.28	7.82	7.58	6.93	5.95	4.60	3.47	2.89	
	RadStd	0.12	0.23	0.20	0.26	0.25	0.13	0.10	0.09	0.11	0.16	0.13	0.09	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (5 neighbors)	+0.60	N/A	-1.36	N/A	N/A	N/A	N/A	-50	+212	+171

Nomenclature: See separate page