

KOSSEIR, Egypt

WMO: 624650

Lat: 26.1356N

Lon: 34.2583E

Elev: 35

StdP: 14.68

Time Zone: 2.00 (E02)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	53.8	55.6	25.5	19.5	66.2	29.2	23.2	65.6	22.9	66.5	20.9	66.6	7.0	290	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	8.6	95.2	72.8	93.5	73.8	92.3	74.0	82.4	88.1	80.5	88.4	79.1	88.3	7.4	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
81.0	161.2	86.0	78.3	147.1	85.9	76.3	137.5	86.3	46.3	88.1	44.2	88.5	42.7	88.3	89.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.2	19.0	17.3	49.9	99.4	2.3	2.1	48.3	100.9	46.9	102.1	45.7	103.3	44.0	104.8		
(5)			41.1	85.0	2.4	2.9	39.4	87.1	38.0	88.8	36.7	90.4	35.0	92.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	76.4	64.3	65.6	69.5	74.2	80.4	84.3	86.5	87.3	84.4	79.7	72.9	67.0
	DBStd	8.71	3.36	3.50	3.48	3.49	3.69	2.94	2.49	2.38	2.52	2.98	3.56	3.60
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	107	53	30	4	0	0	0	0	0	0	0	0	20
	CDD50	9637	444	437	603	726	943	1030	1131	1155	1031	922	687	528
	CDD65	4269	32	47	142	276	478	580	666	690	581	457	237	83
	CDH74	48892	39	95	462	1699	5250	7774	9744	10295	7729	4466	1166	173
CDH80	21722	0	5	38	254	1774	3581	5310	5845	3549	1214	141	11	
Wind	WSAvg	7.9	8.1	8.0	8.4	8.2	7.7	8.1	6.8	7.3	8.0	7.7	8.4	8.0
Precipitation	PrecAvg	0.3	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.1	0.0	0.0
	PrecMax	2.1	0.6	0.1	0.2	0.1	0.2	0.0	0.0	0.0	0.0	1.1	0.9	0.3
	PrecMin	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	0.4	0.2	0.0	0.0	0.0	0.1	0.0	0.0	0.0	0.0	0.2	0.2	0.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	77.4	79.8	84.1	87.9	95.9	97.2	97.4	97.4	94.4	90.5	85.2	81.8
		MCWB	67.0	64.3	65.6	66.5	68.7	69.4	72.2	76.1	74.7	73.3	70.5	65.3
	2%	DB	75.0	76.7	80.7	84.6	91.7	93.9	94.3	94.8	92.2	88.1	83.2	78.1
		MCWB	64.1	63.6	65.9	66.1	67.8	68.9	73.1	75.7	74.8	74.0	70.4	66.1
	5%	DB	73.2	74.6	78.3	82.7	88.8	91.5	92.7	93.3	90.8	86.6	81.7	75.8
		MCWB	62.5	63.4	65.7	66.3	68.5	69.8	73.9	76.0	74.9	73.2	69.6	64.0
	10%	DB	71.5	72.8	76.6	81.0	86.8	89.8	91.6	92.2	89.5	85.3	79.9	74.0
		MCWB	60.8	62.1	64.7	66.2	68.9	70.6	74.3	75.7	74.8	72.6	68.2	62.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	73.2	74.4	77.2	76.5	79.0	81.5	85.3	85.8	83.7	80.8	77.3	72.3
		MCDB	74.7	75.6	78.1	78.8	83.1	86.0	86.9	89.0	86.9	83.6	80.6	76.7
	2%	WB	69.0	70.1	72.6	73.5	75.9	77.4	81.8	82.1	80.8	78.6	74.1	68.7
		MCDB	72.5	72.9	76.1	78.7	83.4	87.6	88.0	90.4	87.3	83.7	80.5	75.3
	5%	WB	65.4	66.7	68.8	71.3	74.0	75.5	79.9	80.2	78.9	76.8	72.0	66.4
		MCDB	71.1	72.2	75.2	78.8	83.7	87.2	88.7	90.5	87.5	83.7	79.5	73.7
	10%	WB	62.2	63.6	66.2	69.1	72.4	74.3	78.4	78.8	77.4	75.1	69.6	63.9
		MCDB	69.4	71.0	75.0	78.6	83.8	86.9	88.9	90.3	87.6	83.6	78.2	72.5
Mean Daily Temperature Range	5% DB	MDBR	12.8	12.6	11.9	11.0	9.9	8.9	8.8	8.6	8.6	9.7	11.8	12.3
		MCDBR	14.3	14.8	14.4	13.6	13.2	11.6	10.2	9.4	9.6	10.4	13.3	14.0
		MCWBR	11.5	13.2	14.0	13.4	12.1	12.6	13.5	12.8	11.5	11.5	11.7	11.3
	5% WB	MCDBR	13.8	13.5	13.2	11.2	9.8	8.3	8.5	8.7	8.3	10.1	12.5	13.7
		MCWBR	13.4	15.1	15.7	14.4	13.7	13.6	16.2	15.4	12.8	13.2	12.7	13.0
Clear-Sky Solar Irradiance	taub		0.379	0.416	0.462	0.537	0.543	0.467	0.488	0.501	0.479	0.477	0.406	0.380
	taud		2.302	2.158	2.019	1.847	1.849	2.071	2.048	2.020	2.059	2.050	2.240	2.300
	Ebn at Noon		274	271	265	248	246	263	257	254	256	248	262	267
	Edh at Noon		36	45	55	67	66	53	54	55	52	49	38	35
All-Sky Solar Radiation	RadAvg		1342	1633	1986	2213	2364	2471	2383	2246	2036	1703	1423	1262
	RadStd		59	61	62	54	71	33	38	37	49	44	30	24

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		+1.13	N/A	N/A	+1.04	+1.06	+0.97	N/A	-68	+446

Nomenclature: See separate page