

KOSSEIR, Egypt

WMO: 624650

Lat: 26.1356N

Lon: 34.2583E

Elev: 11

StdP: 101.20

Time Zone: 2.00 (E02)

Period: 94-18

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
1	12.1	13.1	-3.6	2.8	19.0	-1.6	3.3	18.6	10.3	19.1	9.3	19.2	3.1	290	0.389

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	4.8	35.1	22.7	34.1	23.2	33.5	23.4	28.0	31.1	26.9	31.3	26.2	31.3	3.3	0

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
27.2	23.0	30.0	25.7	21.0	29.9	24.6	19.6	30.2	89.9	31.2	85.0	31.4	81.5	31.3	31.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
9.5	8.5	7.8	DB	10.0	37.5	1.3	1.1	9.0	38.3	8.3	39.0	7.6	39.6	6.7	40.4	
			WB	5.1	29.4	1.3	1.6	4.1	30.6	3.3	31.5	2.6	32.5	1.7	33.6	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	24.7	18.0	18.7	20.8	23.4	26.9	29.1	30.3	30.7	29.1	26.5	22.7	19.5
	DBStd	4.84	1.87	1.94	1.93	1.94	2.05	1.63	1.39	1.32	1.40	1.66	1.98	2.00
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	59	29	17	2	0	0	0	0	0	0	0	0	11
	CDD10.0	5354	247	243	335	403	524	628	642	573	512	382	293	
	CDD18.3	2372	18	26	79	153	266	322	370	383	323	254	132	46
	CDH23.3	27162	22	53	257	944	2917	4319	5413	5719	4294	2481	648	96
	CDH26.7	12068	0	3	21	141	986	1989	2950	3247	1972	674	78	6
Wind	WSAvg	3.5	3.6	3.6	3.7	3.7	3.5	3.6	3.0	3.3	3.6	3.4	3.7	3.6
Precipitation	PrecAvg	7	1	0	1	0	1	0	0	0	0	2	1	1
	PrecMax	54	16	2	6	2	6	0	0	0	0	29	23	7
	PrecMin	1	0	0	0	0	0	0	0	0	0	0	0	0
	PrecStd	11	4	0	1	0	2	0	0	0	0	6	4	2
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	25.2	26.6	28.9	31.0	35.5	36.2	36.3	36.3	34.7	32.5	29.6	27.6
		MCWB	19.5	17.9	18.7	19.2	20.4	20.8	22.4	24.5	23.7	23.0	21.4	18.5
	2%	DB	23.9	24.8	27.0	29.2	33.2	34.4	34.6	34.9	33.4	31.2	28.5	25.6
		MCWB	17.9	17.6	18.9	19.0	19.9	20.5	22.8	24.3	23.8	23.3	21.4	18.9
	5%	DB	22.9	23.7	25.7	28.2	31.6	33.1	33.7	34.0	32.6	30.3	27.6	24.3
		MCWB	16.9	17.5	18.7	19.1	20.3	21.0	23.3	24.4	23.8	22.9	20.9	17.8
	10%	DB	22.0	22.7	24.8	27.2	30.4	32.1	33.1	33.4	31.9	29.6	26.6	23.3
		MCWB	16.0	16.7	18.2	19.0	20.5	21.5	23.5	24.3	23.8	22.6	20.1	16.8
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.9	23.5	25.1	24.7	26.1	27.5	29.6	29.9	28.7	27.1	25.2	22.4
		MCDB	23.7	24.2	25.6	26.0	28.4	30.0	30.5	31.7	30.5	28.7	27.0	24.8
	2%	WB	20.6	21.2	22.6	23.1	24.4	25.2	27.7	27.8	27.1	25.9	23.4	20.4
		MCDB	22.5	22.7	24.5	26.0	28.5	30.9	31.1	32.4	30.7	28.7	27.0	24.0
	5%	WB	18.5	19.3	20.5	21.9	23.3	24.2	26.6	26.8	26.1	24.9	22.2	19.1
		MCDB	21.7	22.3	24.0	26.0	28.7	30.7	31.5	32.5	30.8	28.7	26.4	23.2
	10%	WB	16.8	17.5	19.0	20.6	22.5	23.5	25.8	26.0	25.2	23.9	20.9	17.7
		MCDB	20.8	21.7	23.9	25.9	28.8	30.5	31.6	32.4	30.9	28.7	25.7	22.5
Mean Daily Temperature Range	5% DB	MDBR	7.1	7.0	6.6	6.1	5.5	4.9	4.9	4.8	4.8	5.4	6.6	6.8
		MCDBR	7.9	8.2	8.0	7.5	7.3	6.4	5.6	5.2	5.3	5.8	7.4	7.8
		MCWBR	6.4	7.4	7.8	7.4	6.7	7.0	7.5	7.1	6.4	6.4	6.5	6.3
	5% WB	MCDBR	7.6	7.5	7.3	6.2	5.5	4.6	4.7	4.9	4.6	5.6	6.9	7.6
		MCWBR	7.4	8.4	8.7	8.0	7.6	7.5	9.0	8.5	7.1	7.3	7.0	7.2
Clear-Sky Solar Irradiance	taub	0.379	0.416	0.462	0.537	0.543	0.467	0.488	0.501	0.479	0.477	0.406	0.380	
	taud	2.302	2.158	2.019	1.847	1.849	2.071	2.048	2.020	2.059	2.050	2.240	2.300	
	Ebn at Noon	863	855	834	781	774	829	811	800	808	783	825	843	
	Edh at Noon	115	142	172	210	209	167	170	174	163	156	121	111	
All-Sky Solar Radiation	RadAvg	4.23	5.15	6.26	6.98	7.45	7.79	7.51	7.08	6.42	5.37	4.49	3.98	
	RadStd	0.19	0.19	0.20	0.17	0.22	0.10	0.12	0.12	0.15	0.14	0.09	0.08	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46)	Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47)	Regional (3 neighbors)	+0.63	N/A	N/A	+0.58	+0.59	+0.54	N/A	-38	+248	+223

Nomenclature: See separate page