

WAJIR, Kenya

WMO: 636710

Lat: 1.733N

Lon: 40.092E

Elev: 770

StdP: 14.29

Time Zone: 3.00 (E03)

Period: 90-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	71.2	72.3	48.1	51.2	85.2	52.0	59.3	89.6	29.9	80.9	23.4	84.9	4.8	180	0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	18.3	99.2	71.9	98.1	72.3	96.9	72.5	77.8	87.8	77.0	87.4	76.4	87.0	7.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
75.4	137.2	81.2	74.6	133.2	80.7	73.7	129.4	80.3	41.7	87.2	40.9	86.9	40.4	87.1	87.1

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.8	21.1	17.9	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
Temperatures, Degree-Days and Degree-Hours	DBAvg	84.1	85.9	87.3	87.5	85.8	84.6	82.7	81.4	81.2	82.9	83.9	82.8	83.9
	DBStd	3.02	1.72	1.67	2.12	2.51	2.08	1.99	1.99	2.78	2.25	2.32	2.30	2.77
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	12458	1114	1044	1164	1073	1072	982	972	966	987	1049	985	1050
	CDD65	6983	649	624	699	623	607	532	507	501	537	584	535	585
	CDH74	85669	8420	8637	9674	7914	7489	6242	5563	5624	6459	6883	5834	6930
	CDH80	41468	4483	4895	5432	3939	3514	2729	2279	2334	3040	3128	2361	3334
Wind	WSAvg	7.7	6.8	7.6	8.4	6.2	7.5	8.9	9.2	9.1	8.6	6.6	6.2	7.1
Precipitation	PrecAvg	11.4	0.4	0.4	1.6	3.8	1.7	0.1	0.1	0.1	0.1	1.5	2.6	0.9
	PrecMax	21.1	3.1	2.5	6.2	11.9	10.7	0.4	0.7	0.5	0.7	5.7	10.7	5.7
	PrecMin	4.2	0.0	0.0	0.0	0.4	0.0	0.0	0.0	0.0	0.0	0.0	0.0	0.0
	PrecStd	4.8	0.7	0.6	1.7	2.9	2.2	0.1	0.2	0.1	0.2	1.6	2.2	1.1
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	100.2	100.8	100.7	98.9	96.4	94.3	92.6	93.3	95.5	95.9	94.9	97.2
		MCWB	70.4	71.5	71.4	73.5	74.0	71.4	69.8	70.4	70.9	73.2	73.6	70.2
	2%	DB	98.2	99.1	99.0	96.8	94.6	92.6	91.2	91.6	93.7	94.3	93.2	96.1
		MCWB	71.4	72.0	72.3	74.3	73.9	71.4	69.6	69.6	70.4	72.7	73.5	70.3
	5%	DB	96.7	98.1	97.7	95.3	93.2	91.2	89.9	90.3	92.5	93.0	91.6	94.8
		MCWB	71.8	72.2	72.8	74.7	73.8	71.3	69.5	69.3	70.1	72.4	73.6	70.6
	10%	DB	95.0	96.7	96.4	93.6	91.7	89.9	88.8	89.1	91.2	91.4	89.9	92.8
		MCWB	72.0	72.3	73.1	74.8	73.8	71.0	69.4	69.2	69.9	72.3	73.9	71.3
Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	78.0	76.5	78.1	79.5	78.3	74.7	73.1	73.7	73.9	76.5	77.9	77.1
		MCDB	91.2	90.4	89.3	88.2	87.0	87.5	84.6	85.2	87.0	86.3	85.5	87.8
	2%	WB	76.5	75.5	76.8	77.8	76.5	73.7	72.1	72.0	72.7	75.6	77.0	76.1
		MCDB	89.6	90.7	89.7	87.4	87.1	86.9	84.5	84.8	86.8	85.6	84.9	86.1
	5%	WB	75.3	74.6	76.1	76.9	75.9	72.9	71.2	71.1	71.9	75.1	76.3	75.5
		MCDB	89.1	90.5	89.3	87.2	86.7	86.1	84.3	84.5	86.6	85.2	84.4	84.9
	10%	WB	74.4	73.9	75.4	76.3	75.3	72.3	70.6	70.4	71.2	74.5	75.7	74.8
		MCDB	88.4	90.3	89.0	86.8	86.4	85.3	84.0	84.3	86.1	84.6	83.9	84.1
Mean Daily Temperature Range	5% DB	MDBR	19.7	20.2	18.3	15.9	15.7	15.9	15.7	16.4	17.9	15.4	14.7	17.6
		MCDBR	22.0	21.9	20.3	17.7	17.1	17.1	17.4	18.1	19.4	17.1	16.8	19.9
		MCWBR	6.7	5.7	5.4	4.1	3.9	4.3	4.2	4.9	4.7	3.7	4.0	6.3
	5% WB	MCDBR	18.8	19.5	17.4	15.7	15.4	16.1	15.5	16.6	18.1	14.4	14.4	16.2
MCWBR		5.8	5.4	5.0	4.5	4.3	4.7	4.3	5.4	4.9	3.8	4.5	5.1	
Clear-Sky Solar Irradiance	taub	0.415	0.440	0.454	0.428	0.420	0.487	0.490	0.440	0.417	0.413	0.429	0.422	
	taud	2.336	2.245	2.228	2.352	2.377	2.117	2.096	2.259	2.330	2.387	2.347	2.348	
	Ebn at Noon	289	283	278	279	274	251	252	272	284	287	283	285	
	Edh at Noon	42	46	47	41	38	49	50	44	42	40	41	41	
All-Sky Solar Radiation	RadAvg	2061	2135	2033	1810	1774	1591	1559	1708	1875	1752	1666	1853	
	RadStd	65	62	110	63	52	85	81	53	66	65	75	96	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page