

WAJIR, Kenya

WMO: 636710

Lat: 1.733N

Lon: 40.092E

Elev: 235

StdP: 98.54

Time Zone: 3.00 (E03)

Period: 90-15

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	21.8	22.4	9.0	7.3	29.5	11.1	8.5	32.0	13.4	27.1	10.5	29.4	2.2	180	0.433

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	10.2	37.3	22.2	36.7	22.4	36.1	22.5	25.4	31.0	25.0	30.8	24.7	30.6	3.2	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
24.1	19.6	27.4	23.7	19.0	27.1	23.2	18.5	26.8	79.2	30.7	77.3	30.5	76.1	30.6	30.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature							
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years	
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11.1	9.4	8.0	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
			DB											
			WB											

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	29.0	30.0	30.7	30.9	29.9	29.2	28.2	27.4	27.3	28.3	28.8	28.2	28.8
	DBStd	1.68	0.95	0.93	1.18	1.40	1.16	1.11	1.11	1.54	1.25	1.29	1.28	1.54
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD10.0	6921	619	580	647	596	546	540	537	548	583	547	583	583
	CDD18.3	3879	361	347	388	346	337	296	282	278	298	324	297	325
	CDH23.3	47594	4678	4798	5374	4397	4161	3468	3091	3124	3588	3824	3241	3850
	CDH26.7	23038	2491	2719	3018	2188	1952	1516	1266	1297	1689	1738	1312	1852
(14) Wind	WSAvg	3.4	3.0	3.4	3.7	2.8	3.3	4.0	4.1	4.1	3.8	3.0	2.8	3.2
(15) Precipitation	PrecAvg	290	9	10	41	96	42	2	3	2	3	37	65	22
	PrecMax	537	78	63	158	303	273	11	17	13	17	145	272	146
	PrecMin	106	0	0	0	9	0	0	0	0	0	0	0	0
	PrecStd	121	17	15	43	74	56	3	4	3	5	41	57	29
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	37.9	38.2	38.1	37.2	35.8	34.6	33.7	34.1	35.3	35.5	35.0	36.2
		MCWB	21.3	21.9	21.9	23.1	23.4	21.9	21.0	21.4	21.6	22.9	23.1	21.2
	2%	DB	36.8	37.3	37.2	36.0	34.8	33.6	32.9	33.1	34.3	34.6	34.0	35.6
		MCWB	21.9	22.2	22.4	23.5	23.3	21.9	20.9	20.9	21.4	22.6	23.1	21.3
	5%	DB	35.9	36.7	36.5	35.1	34.0	32.9	32.2	32.4	33.6	33.9	33.1	34.9
		MCWB	22.1	22.3	22.7	23.7	23.2	21.8	20.9	20.7	21.2	22.5	23.1	21.5
	10%	DB	35.0	36.0	35.8	34.2	33.2	32.2	31.5	31.7	32.9	33.0	32.2	33.8
		MCWB	22.2	22.4	22.8	23.8	23.2	21.7	20.8	20.7	21.0	22.4	23.3	21.9
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	25.5	24.7	25.6	26.4	25.7	23.7	22.8	23.2	23.3	24.7	25.5	25.0
		MCDB	32.9	32.4	31.9	31.2	30.6	30.8	29.2	29.6	30.5	30.2	29.7	31.0
	2%	WB	24.7	24.2	24.9	25.5	24.7	23.2	22.3	22.2	22.6	24.2	25.0	24.5
		MCDB	32.0	32.6	32.0	30.8	30.6	30.5	29.2	29.3	30.5	29.8	29.4	30.1
	5%	WB	24.1	23.7	24.5	25.0	24.4	22.7	21.8	21.7	22.2	23.9	24.6	24.1
		MCDB	31.7	32.5	31.9	30.7	30.4	30.1	29.0	29.2	30.3	29.5	29.1	29.4
	10%	WB	23.6	23.3	24.1	24.6	24.0	22.4	21.5	21.3	21.8	23.6	24.3	23.8
		MCDB	31.3	32.4	31.7	30.4	30.2	29.6	28.9	29.1	30.0	29.2	28.9	29.0
(35) Mean Daily Temperature Range	5% DB	MDBR	10.9	11.2	10.2	8.8	8.7	8.8	8.7	9.1	9.9	8.6	8.1	9.8
		MCDBR	12.2	12.2	11.3	9.8	9.5	9.5	9.7	10.1	10.8	9.5	9.4	11.1
	5% WB	MCWBR	3.7	3.1	3.0	2.3	2.2	2.4	2.3	2.7	2.6	2.1	2.2	3.5
		MCWBR	10.4	10.8	9.7	8.7	8.6	9.0	8.6	9.2	10.1	8.0	8.0	9.0
(40) Clear-Sky Solar Irradiance	taub		0.415	0.440	0.454	0.428	0.420	0.487	0.490	0.440	0.417	0.413	0.429	0.422
		taud	2.336	2.245	2.228	2.352	2.377	2.117	2.096	2.259	2.330	2.387	2.347	2.348
	Ebn at Noon		911	893	875	879	864	792	795	856	894	906	891	898
		Edh at Noon	131	146	148	128	121	153	158	139	132	125	129	128
(44) All-Sky Solar Radiation	RadAvg		6.50	6.73	6.41	5.71	5.59	5.02	4.91	5.38	5.91	5.52	5.25	5.84
	RadStd		0.20	0.20	0.35	0.20	0.16	0.27	0.26	0.17	0.21	0.20	0.24	0.30

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page