

EL DORET INTL, Kenya

WMO: 636880

Lat: 0.404N

Lon: 35.239E

Elev: 7054

StdP: 11.32

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	46.4	48.0	30.3	31.8	75.3	33.8	37.0	72.1	17.4	66.8	14.5	67.1	7.2	100	0.415

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	25.0	80.8	55.8	79.2	56.1	78.5	56.3	63.0	71.4	62.2	70.8	61.4	70.1	12.2	60

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
60.7	103.6	65.6	59.4	98.6	64.0	59.1	97.5	63.6	32.6	70.6	31.7	70.9	31.2	70.5	77.4

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 21.0	18.5	16.4	DB	42.9	85.0	1.9	2.5	41.6	86.8	40.5	88.2	39.4	89.6	38.0	91.4	(4)
(5)			WB	40.6	67.9	2.0	3.4	39.1	70.3	38.0	72.3	36.8	74.1	35.4	76.6	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	63.6	63.7	64.9	65.8	65.4	64.1	62.7	61.7	61.8	62.6	63.9	63.4	63.2	(6)	
	DBStd	2.18	1.90	2.23	2.16	1.83	1.65	1.66	1.62	1.52	1.64	1.67	1.63	1.86	(7)	
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD65	643	48	26	16	17	38	70	102	99	73	41	52	61	(9)	
	CDD50	4962	426	417	490	461	436	382	363	366	379	431	402	409	(10)	
	CDD65	131	9	24	41	28	9	2	0	0	2	7	4	5	(11)	
	CDH74	2415	348	546	654	274	132	39	9	12	97	121	57	126	(12)	
	CDH80	87	4	25	49	7	1	0	0	0	0	0	0	1	(13)	
(14) Wind	WSAvg	7.1	8.5	8.9	8.7	7.2	6.0	5.1	5.1	5.2	5.9	7.6	8.1	8.5	(14)	
(15) Precipitation	PrecAvg	29.2	1.1	1.0	2.2	4.4	3.1	2.3	2.7	3.0	1.6	2.8	3.2	1.8	(15)	
	PrecMax	44.0	6.8	4.3	5.8	11.1	7.0	5.3	4.7	4.8	4.1	5.9	9.4	5.1	(16)	
	PrecMin	18.1	0.1	0.1	0.3	1.2	1.0	0.5	1.3	1.2	0.2	0.8	0.7	0.0	(17)	
	PrecStd	5.9	1.4	1.1	1.5	2.4	1.4	1.1	0.9	0.9	0.9	1.3	2.1	1.4	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	80.5	82.5	82.8	80.9	78.9	77.1	75.2	75.4	77.7	78.6	77.3	78.8	(19)	
		MCWB	55.2	55.3	56.0	56.5	58.6	57.5	58.8	58.7	58.0	57.7	57.4	55.4	(20)	
	2%	DB	78.8	80.6	81.0	78.9	77.1	75.2	73.4	73.6	76.7	76.9	75.5	76.9	(21)	
		MCWB	55.0	55.2	56.0	57.6	58.4	58.0	59.2	59.4	57.5	58.0	57.7	55.9	(22)	
	5%	DB	77.3	79.0	80.2	77.1	75.4	73.4	71.8	71.9	75.2	75.3	73.8	75.3	(23)	
		MCWB	55.4	55.3	56.2	58.0	58.7	59.2	59.2	59.4	57.6	58.0	58.3	56.3	(24)	
	10%	DB	76.0	77.4	78.3	75.3	73.6	71.7	70.1	70.2	73.4	73.7	72.3	73.6	(25)	
		MCWB	55.7	55.6	56.8	58.7	59.4	59.3	59.0	59.4	58.4	58.4	58.4	56.9	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	62.6	62.7	63.3	63.9	63.6	62.9	61.9	62.2	62.7	62.8	62.4	62.6	(27)	
		MCDB	71.9	70.9	73.2	71.8	71.1	70.9	70.6	70.6	72.3	71.0	70.3	69.6	(28)	
	2%	WB	60.9	61.0	61.8	62.6	62.4	61.5	60.9	61.0	61.1	61.1	61.0	60.8	(29)	
		MCDB	69.8	70.3	71.6	71.2	70.6	69.9	69.5	70.0	70.8	70.1	69.3	68.6	(30)	
	5%	WB	59.8	60.0	60.7	61.6	61.3	60.8	60.3	60.4	60.4	60.3	60.2	60.0	(31)	
		MCDB	69.5	69.9	70.2	70.0	69.6	69.2	68.7	69.2	69.9	69.7	68.7	68.1	(32)	
	10%	WB	58.6	58.9	59.8	60.8	60.7	60.2	59.7	59.8	59.7	59.6	59.6	59.1	(33)	
		MCDB	69.1	69.6	69.5	68.9	68.9	68.3	68.0	68.4	69.1	69.3	68.2	67.7	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	26.0	26.6	25.0	20.9	20.8	20.0	19.8	20.1	22.8	21.5	19.9	22.4	(35)	
		MCDBR	28.7	29.2	29.0	24.7	24.1	22.9	21.5	22.1	26.0	24.0	22.5	25.7	(36)	
	5% WB	MCWBR	11.3	10.5	10.1	8.9	9.9	10.1	10.3	10.6	11.2	9.4	8.6	9.7	(37)	
		MCWBR	23.6	24.2	23.7	20.3	20.2	19.2	19.8	20.2	22.1	20.9	19.1	19.9	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.317	0.335	0.340	0.331	0.339	0.393	0.405	0.383	0.349	0.337	0.325	0.320	(40)	
		taud	2.567	2.501	2.509	2.580	2.548	2.356	2.300	2.366	2.466	2.508	2.570	2.568	(41)	
	Ebn at Noon		321	316	311	307	298	277	275	288	304	311	316	319	(42)	
		Edh at Noon	33	36	36	32	32	38	41	39	36	35	33	33	(43)	
(44) All-Sky Solar Radiation	RadAvg		2005	2102	2061	1897	1846	1707	1644	1726	1941	1903	1812	1896	(44)	
	RadStd		144	110	142	116	63	96	87	89	81	74	102	122	(45)	

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (3 neighbors)		N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page