

ENTEBBE INTL, Uganda

WMO: 637050

Lat: 0.042N

Lon: 32.444E

Elev: 3782

StdP: 12.80

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	62.8	64.1	53.8	71.0	74.8	57.3	80.7	72.8	19.1	74.4	17.8	74.3	4.9	0	0.257

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	14.9	84.5	70.2	83.6	70.7	82.4	71.1	74.5	80.7	73.7	80.0	72.9	79.4	8.8	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
72.1	137.0	78.4	71.7	134.9	78.0	70.8	130.8	77.1	40.9	81.1	40.0	80.1	39.3	79.7	79.7

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature								
1%	2.5%	5%	Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years		
			Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
18.0	15.8	13.7	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	
			DB	51.3	77.8	10.4	1.1	43.8	78.5	37.7	79.2	31.8	79.8	24.3	80.6
			WB												

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	73.0	73.9	74.4	74.1	73.2	73.0	72.5	72.1	71.8	72.5	72.8	72.6	73.0
	DBStd	2.14	1.86	3.28	2.53	2.05	1.72	1.83	1.63	1.63	1.72	1.64	1.77	1.77
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	4	0	4	0	0	0	0	0	0	0	0	0	0
	CDD50	8385	742	684	746	696	712	675	685	674	674	705	679	713
	CDD65	2914	277	268	281	246	247	225	220	209	224	240	229	248
	CDH74	12210	1509	1641	1442	985	807	755	747	658	831	914	881	1040
	CDH80	1139	253	296	198	60	26	31	34	24	41	42	42	92
(14) Wind	WSAvg	6.1	5.9	6.3	6.4	6.1	6.0	6.0	6.2	6.2	6.3	6.5	5.9	5.5
(15) Precipitation	PrecAvg	64.1	3.3	3.3	7.2	10.0	10.2	4.4	3.0	2.9	2.8	5.0	6.5	4.7
	PrecMax	105.5	9.2	7.8	15.4	20.3	18.3	14.8	9.9	8.3	5.9	12.9	15.2	12.5
	PrecMin	41.6	0.3	0.2	1.7	3.0	3.4	1.3	0.5	0.4	0.7	1.0	0.8	0.4
	PrecStd	12.2	2.2	2.1	3.7	4.0	3.7	2.6	2.4	1.9	1.5	2.8	3.1	2.5
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	86.2	86.1	85.7	82.8	82.5	82.5	82.7	82.3	82.8	82.6	82.7	84.1
		MCWB	66.5	68.5	71.2	72.3	71.4	71.0	69.8	70.4	70.9	71.3	70.6	69.6
	2%	DB	84.2	84.4	84.0	82.0	80.5	80.7	80.8	80.5	80.8	80.9	80.9	82.3
		MCWB	68.8	70.3	72.5	72.0	71.6	70.8	69.4	70.0	70.8	71.2	70.9	70.3
	5%	DB	82.6	82.8	82.3	80.6	79.1	79.2	79.1	79.0	79.2	80.2	80.3	80.7
		MCWB	69.9	71.2	72.4	71.5	71.2	70.4	69.5	69.5	70.3	71.0	70.8	70.3
	10%	DB	80.9	82.1	80.6	79.0	78.5	78.4	78.0	77.4	78.7	78.8	78.8	79.1
		MCWB	69.7	71.3	71.6	71.1	71.0	70.2	69.1	69.0	70.1	70.4	70.4	70.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	74.5	75.6	75.6	74.6	74.1	73.8	72.8	72.7	73.2	73.2	72.9	73.8
		MCDB	81.0	81.6	82.2	80.0	78.8	79.0	79.3	78.7	80.2	80.0	79.9	79.9
	2%	WB	73.2	74.3	74.4	73.4	72.9	72.5	71.4	71.3	72.0	72.2	72.0	72.6
		MCDB	80.0	80.9	81.1	79.4	78.3	78.5	78.1	78.2	79.2	79.3	79.2	79.1
	5%	WB	72.0	73.2	73.1	72.5	72.2	71.5	70.5	70.5	71.1	71.4	71.3	71.6
		MCDB	78.7	80.0	79.8	78.4	77.7	77.8	77.2	77.3	78.2	78.5	78.3	78.5
	10%	WB	71.2	72.1	72.2	71.7	71.4	70.6	69.6	69.7	70.4	70.7	70.7	70.8
		MCDB	77.6	79.1	78.6	77.6	76.9	76.6	76.1	76.2	77.2	77.4	77.3	77.2
(35) Mean Daily Temperature Range	5% DB	MDBR	14.6	14.9	12.7	11.7	11.2	12.1	13.0	12.8	13.5	12.9	12.8	13.2
		MCDBR	17.7	16.4	14.5	13.2	12.3	13.6	15.0	14.7	14.7	14.3	14.4	15.4
	5% WB	MCWBR	8.3	8.3	7.1	6.7	6.4	6.8	7.4	7.2	7.5	7.4	7.0	7.5
		MCWBR	14.0	15.2	13.3	12.1	11.5	12.9	13.9	13.7	14.2	13.3	13.4	13.7
(40) Clear-Sky Solar Irradiance	taub		0.431	0.434	0.425	0.377	0.367	0.407	0.432	0.423	0.386	0.383	0.383	0.411
		taud	2.318	2.315	2.375	2.538	2.571	2.417	2.309	2.331	2.451	2.467	2.488	2.387
	Ebn at Noon		285	285	286	293	289	273	267	276	293	297	298	290
		Edh at Noon	43	43	41	34	31	36	40	41	37	37	36	39
(44) All-Sky Solar Radiation	RadAvg		1718	1819	1779	1639	1573	1498	1527	1555	1659	1664	1618	1610
	RadStd		160	131	129	127	91	101	107	90	71	73	95	115

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page