

ENTEBBE INTL, Uganda

WMO: 637050

Lat: 0.042N

Lon: 32.444E

Elev: 1153

StdP: 88.22

Time Zone: 3.00 (E03)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	17.1	17.8	12.1	10.1	23.8	14.1	11.5	22.7	8.5	23.6	8.0	23.5	2.2	0	0.257

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	8.3	29.1	21.2	28.7	21.5	28.0	21.7	23.6	27.0	23.2	26.7	22.7	26.3	3.9	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	
22.3	19.6	25.8	22.0	19.3	25.5	21.6	18.7	25.0	77.2	27.3	75.3	26.7	73.4	26.5	26.5

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	(q)
(4) 8.0	7.0	6.1	DB	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(5)			WB	10.7	25.4	5.8	0.6	6.5	25.9	3.2	26.2	-0.1	26.5	-4.3	27.0	

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	22.8	23.3	23.6	23.4	22.9	22.8	22.5	22.3	22.1	22.5	22.6	22.6	22.8
	DBStd	1.19	1.03	1.82	1.41	1.14	0.95	1.02	0.91	0.90	0.96	0.91	0.98	0.99
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD18.3	2	0	2	0	0	0	0	0	0	0	0	0	0
	CDD10.0	4658	412	380	414	387	396	375	381	374	374	392	377	396
	CDD18.3	1619	154	149	156	137	137	125	122	116	124	133	127	138
	CDH23.3	6783	838	912	801	547	448	419	415	366	462	508	489	578
(13)	CDH26.7	633	141	164	110	33	14	17	19	13	23	23	23	51
(14)	Wind	WSAvg	2.7	2.6	2.8	2.9	2.7	2.7	2.8	2.8	2.8	2.9	2.6	2.5
(15) Precipitation	PrecAvg	1627	83	85	182	253	259	112	76	74	70	128	165	120
	PrecMax	2679	234	199	391	516	466	376	252	210	150	327	385	317
	PrecMin	1056	8	6	44	76	86	32	12	9	17	26	21	10
	PrecStd	311	55	53	94	102	93	67	61	47	38	72	80	64
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	30.1	30.1	29.8	28.2	28.0	28.2	28.0	28.2	28.2	28.1	28.1	29.0
		MCWB	19.2	20.3	21.8	22.4	21.9	21.7	21.0	21.4	21.6	21.8	21.4	20.9
	2%	DB	29.0	29.1	28.9	27.8	27.0	27.1	27.1	26.9	27.1	27.2	27.2	28.0
		MCWB	20.5	21.3	22.5	22.2	22.0	21.5	20.8	21.1	21.6	21.8	21.6	21.3
	5%	DB	28.1	28.2	27.9	27.0	26.2	26.2	26.2	26.1	26.2	26.8	26.8	27.1
		MCWB	21.0	21.8	22.4	21.9	21.8	21.3	20.8	20.8	21.3	21.6	21.5	21.3
	10%	DB	27.2	27.9	27.0	26.1	25.8	25.8	25.6	25.2	25.9	26.0	26.0	26.2
		MCWB	20.9	21.8	22.0	21.7	21.7	21.2	20.6	20.5	21.2	21.3	21.3	21.3
	0.4%	WB	23.6	24.2	24.2	23.7	23.4	23.2	22.7	22.6	22.9	22.9	22.7	23.2
		MCDB	27.2	27.6	27.9	26.7	26.0	26.1	26.3	26.0	26.8	26.6	26.6	26.6
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	2%	WB	22.9	23.5	23.5	23.0	22.7	22.5	21.9	21.8	22.2	22.4	22.2	22.5
		MCDB	26.7	27.2	27.3	26.3	25.7	25.9	25.6	25.7	26.2	26.3	26.2	26.2
	5%	WB	22.2	22.9	22.9	22.5	22.3	22.0	21.4	21.4	21.7	21.9	21.8	22.0
		MCDB	25.9	26.7	26.6	25.8	25.4	25.5	25.1	25.1	25.6	25.8	25.7	25.9
	10%	WB	21.8	22.3	22.3	22.1	21.9	21.5	20.9	20.9	21.3	21.5	21.5	21.6
		MCDB	25.3	26.2	25.9	25.3	24.9	24.8	24.5	24.5	25.1	25.2	25.2	25.1
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	8.3	7.1	6.5	6.2	6.7	7.2	7.1	7.5	7.2	7.1	7.3
		MCDBR	9.8	9.1	8.1	7.3	6.8	7.6	8.3	8.2	8.2	7.9	8.0	8.6
		MCWBR	4.6	4.6	4.0	3.7	3.6	3.8	4.1	4.0	4.2	4.1	3.9	4.2
	5% WB	MCDBR	7.8	8.5	7.4	6.7	6.4	7.2	7.7	7.6	7.9	7.4	7.5	7.6
		MCWBR	4.2	4.9	4.1	4.0	3.7	3.9	4.1	4.1	4.2	4.0	3.9	4.1
(40) Clear-Sky Solar Irradiance	taub	0.431	0.434	0.425	0.377	0.367	0.407	0.432	0.423	0.386	0.383	0.383	0.383	0.411
	taud	2.318	2.315	2.375	2.538	2.571	2.417	2.309	2.331	2.451	2.467	2.488	2.488	2.387
	Ebn at Noon	899	900	901	924	911	860	843	870	923	936	939	913	913
	Edh at Noon	134	137	128	106	99	113	127	129	117	116	113	113	124
(44) All-Sky Solar Radiation	RadAvg	5.42	5.73	5.61	5.17	4.96	4.72	4.81	4.90	5.23	5.25	5.10	5.08	5.08
	RadStd	0.50	0.41	0.41	0.40	0.29	0.32	0.34	0.28	0.22	0.23	0.30	0.30	0.36

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page