

MUSOMA, Tanzania, United Republic ofWMO: **637330**Lat: **1.4962S**Lon: **33.8023E**Elev: **3763**StdP: **12.80**Time Zone: **3.00 (E03)**Period: **06-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	62.7	64.2	50.9	63.5	74.2	53.0	68.7	74.7	18.6	78.0	16.8	79.5	0.6	170	0.244

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
2	15.7	87.4	67.6	85.9	68.1	84.6	68.5	72.7	81.4	72.0	80.7	71.6	80.3	8.6	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
70.1	127.6	76.8	69.6	125.4	76.4	68.8	121.8	75.8	39.2	81.7	38.4	80.9	37.9	80.4	80.6

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 17.5	15.2	13.6	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	74.7	74.9	76.0	75.7	75.0	74.6	73.8	73.4	74.2	75.1	75.5	74.3	73.7
	DBStd	2.07	1.92	2.19	2.41	1.94	1.53	1.62	1.61	1.86	1.98	2.02	1.83	1.95
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0
	CDD50	9004	773	727	798	749	761	715	724	751	752	790	729	735
	CDD65	3529	308	307	333	299	296	265	259	286	302	325	279	270
	CDH74	19818	1814	2055	2157	1662	1578	1430	1460	1545	1680	1832	1363	1242
	CDH80	3550	340	506	541	321	242	197	187	234	292	356	192	142
(14) Wind	WSAvg	4.6	4.2	4.8	5.0	4.1	3.9	4.1	4.8	5.2	5.5	5.1	4.4	3.9
(15) Precipitation	PrecAvg	35.0	2.4	3.1	4.6	7.4	4.3	1.0	0.6	0.6	1.2	2.4	4.3	3.1
	PrecMax	56.3	7.0	9.8	15.7	12.7	8.8	3.9	3.9	2.1	4.8	8.7	19.7	10.6
	PrecMin	20.0	0.0	0.3	0.7	2.9	1.2	0.0	0.0	0.0	0.1	0.4	0.7	0.3
	PrecStd	7.6	1.7	2.4	3.2	2.8	2.0	1.0	0.8	0.6	1.1	1.8	3.4	2.3
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	87.4	88.4	89.2	87.4	86.0	85.0	85.1	86.3	86.4	88.1	86.1	85.4
		MCWB	67.4	67.4	67.6	69.0	69.0	67.3	65.6	65.6	66.9	66.2	67.8	68.0
	2%	DB	84.8	86.2	86.3	84.6	84.2	83.8	83.1	84.2	84.4	85.4	83.9	82.8
		MCWB	68.3	68.3	69.1	70.0	69.2	67.5	66.6	66.2	67.3	67.5	68.8	68.8
	5%	DB	83.7	84.6	84.6	83.3	82.6	82.3	82.2	82.5	82.8	83.8	82.3	81.9
		MCWB	68.8	68.9	69.5	70.1	69.7	68.4	66.9	67.3	67.9	68.2	69.2	68.9
	10%	DB	82.1	83.2	83.2	82.0	81.0	80.8	80.7	80.8	81.5	82.1	80.7	80.5
		MCWB	69.2	69.3	69.8	70.1	69.4	68.4	67.1	67.5	68.2	68.7	69.2	69.3
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	72.9	73.4	73.4	73.2	72.8	71.8	71.1	71.7	71.9	72.4	72.4	72.2
		MCDB	81.2	81.8	83.0	82.0	81.6	80.6	79.7	80.6	80.9	80.7	80.2	80.2
	2%	WB	71.8	72.2	72.2	72.0	71.6	70.9	70.0	70.2	70.9	71.4	71.5	71.3
		MCDB	80.3	81.0	81.5	81.0	80.7	79.5	78.9	78.9	79.8	79.7	79.3	79.1
	5%	WB	71.0	71.4	71.5	71.4	70.8	70.1	69.3	69.6	70.2	70.7	70.7	70.6
		MCDB	79.4	80.4	80.6	80.3	79.5	78.5	78.1	78.2	78.8	78.9	78.5	78.2
	10%	WB	70.2	70.6	70.8	70.6	70.1	69.3	68.6	69.0	69.6	70.0	70.0	70.0
		MCDB	78.5	79.5	79.7	79.2	78.4	77.5	77.3	77.4	78.1	78.2	77.7	77.3
(35) Mean Daily Temperature Range	5% DB	MDBR	15.0	15.7	15.7	15.1	15.5	15.8	17.1	16.3	15.3	15.4	14.4	13.3
		MCDBR	17.2	17.7	17.9	17.5	17.1	17.8	18.7	18.1	16.9	17.8	16.6	15.6
	5% WB	MCWBR	7.1	8.0	7.8	7.3	7.1	8.3	8.8	9.0	8.2	7.4	6.8	6.4
		MCDWR	15.3	15.7	16.5	15.5	16.0	15.9	16.9	16.4	15.6	15.6	14.9	14.1
(40) Clear-Sky Solar Irradiance	taub	taub	0.419	0.435	0.422	0.370	0.366	0.418	0.437	0.428	0.396	0.389	0.384	0.410
		taud	2.367	2.314	2.388	2.555	2.555	2.358	2.264	2.304	2.402	2.426	2.476	2.397
	Ebn at Noon	Ebn at Noon	290	286	287	295	289	269	265	274	290	295	298	291
		Edh at Noon	41	43	40	33	32	38	42	42	39	38	36	39
(44) All-Sky Solar Radiation	RadAvg	RadAvg	1864	2002	1987	1869	1828	1748	1765	1801	1902	1907	1801	1797
	RadStd	RadStd	157	104	142	124	81	112	106	91	100	96	99	125

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (2 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page