

DODOMA, Tanzania, United Republic ofWMO: **638620**Lat: **6.170S**Lon: **35.753E**Elev: **1120**StdP: **88.58**Time Zone: **3.00 (E03)**Period: **02-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	14.2	15.0	6.4	6.8	26.0	7.6	7.4	24.8	11.2	22.0	10.4	22.1	1.8	90	0.405

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
11	11.5	32.2	19.1	31.8	19.1	31.0	19.1	22.2	27.8	21.7	27.3	21.4	26.9	4.3	90

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
20.7	17.7	24.0	20.2	17.1	23.5	19.9	16.8	23.3	71.2	28.1	69.4	27.4	68.0	26.9	26.8

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 10.2	9.4	8.6	DB	11.9	33.9	1.1	0.6	11.1	34.3	10.4	34.7	9.8	35.1	9.0	35.5	(4)
(5)			WB	10.0	24.9	1.1	1.5	9.2	26.0	8.5	26.9	7.9	27.8	7.1	28.9	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec	
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)	
Temperatures, Degree-Days and Degree-Hours	DBAvg	23.3	24.5	24.5	24.2	23.4	22.5	21.4	20.7	21.5	22.7	24.3	25.2	24.9	
	DBStd	1.84	1.38	1.33	1.19	0.91	0.81	1.08	0.98	0.87	0.97	1.00	1.02	1.50	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	
	CDD10.0	4857	450	407	439	403	388	341	331	357	380	442	457	463	
	CDD18.3	1815	192	173	181	153	129	91	72	98	130	183	207	205	
	CDH23.3	12885	1341	1239	1179	877	723	554	441	626	1002	1543	1781	1579	
	CDH26.7	3672	427	407	339	171	92	56	28	78	255	551	703	565	
Wind	WSAvg	4.3	2.5	2.8	3.0	3.9	4.7	4.4	4.8	5.4	5.8	5.9	5.2	3.5	
Precipitation	PrecAvg	533	130	108	97	65	3	0	0	0	0	0	28	113	
	PrecMax	780	249	273	220	178	25	5	1	1	0	3	96	264	
	PrecMin	252	38	28	22	0	0	0	0	0	0	0	0	0	
	PrecStd	145	59	72	55	58	6	1	0	0	0	1	34	67	
Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	32.9	32.8	32.1	30.2	29.2	29.2	28.5	29.9	31.1	32.7	33.0	33.0	
		MCWB	19.3	19.9	20.7	20.1	18.9	18.4	17.4	17.5	17.6	18.1	19.0	19.0	
	2%	DB	31.5	31.3	30.9	29.2	28.4	28.0	27.3	28.2	30.0	31.4	32.1	32.0	
		MCWB	19.6	20.0	20.5	20.2	18.8	17.9	16.9	17.2	17.3	18.0	18.8	19.2	
	5%	DB	30.4	30.5	29.9	28.6	27.8	27.1	26.8	27.6	29.1	30.8	31.2	31.1	
		MCWB	19.9	20.3	20.4	20.1	18.7	17.5	16.6	17.0	17.2	18.1	18.7	19.2	
	10%	DB	29.1	29.3	28.9	27.8	27.0	26.4	25.9	26.8	28.2	29.8	30.7	30.0	
		MCWB	20.3	20.4	20.6	20.0	18.5	17.0	16.2	16.7	17.2	18.0	18.7	19.4	
	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	22.6	23.1	22.7	22.0	20.8	19.6	19.1	19.4	19.7	20.7	21.4	22.1
			MCDB	28.2	29.1	29.2	27.4	26.6	27.0	26.2	26.3	28.0	28.9	27.9	26.7
2%		WB	21.9	22.2	21.9	21.4	20.2	18.7	17.8	18.4	18.7	19.8	20.6	21.4	
		MCDB	27.3	27.8	28.0	26.9	26.0	26.1	25.8	26.3	27.2	27.5	27.4	26.5	
5%		WB	21.5	21.7	21.4	20.9	19.7	18.2	17.2	17.7	18.1	19.2	20.1	21.0	
		MCDB	26.8	27.2	27.3	26.4	25.3	25.4	24.9	25.6	26.6	26.8	26.6	26.4	
10%		WB	21.1	21.2	21.0	20.6	19.2	17.7	16.8	17.2	17.6	18.8	19.7	20.6	
		MCDB	26.3	26.6	26.7	25.7	24.6	24.5	24.1	24.9	25.9	26.3	26.2	25.8	
Mean Daily Temperature Range	5% DB	MDBR	9.5	10.1	9.7	9.3	9.9	11.3	11.4	11.5	12.3	12.1	11.5	10.1	
		MCDBR	11.2	11.5	11.0	10.3	10.9	11.7	12.1	12.4	13.0	13.0	12.4	11.6	
		MCWBR	2.9	3.2	3.1	2.9	3.1	3.7	3.8	3.6	3.4	3.1	2.7	2.5	
	5% WB	MCDBR	9.3	10.0	9.7	9.3	9.5	11.1	11.3	11.6	12.1	11.8	11.2	9.6	
		MCWBR	3.3	3.7	3.4	3.0	3.1	3.8	3.9	3.7	3.6	3.3	3.0	2.9	
Clear-Sky Solar Irradiance	taub		0.401	0.404	0.374	0.328	0.327	0.331	0.348	0.366	0.362	0.361	0.349	0.371	
	taud		2.385	2.382	2.481	2.687	2.608	2.515	2.409	2.338	2.351	2.362	2.460	2.461	
	Ebn at Noon		937	931	947	965	939	920	909	915	944	961	981	963	
	Edh at Noon		128	129	115	90	93	99	112	125	129	130	118	118	
All-Sky Solar Radiation	RadAvg		6.05	6.30	6.06	5.52	5.20	5.46	5.70	6.10	6.84	6.93	6.59	6.14	
	RadStd		0.49	0.36	0.31	0.27	0.33	0.20	0.26	0.21	0.23	0.23	0.34	0.37	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page