

VICTORIA-SEYCHELLES, Seychelles

WMO: 639800

Lat: 4.674S

Lon: 55.522E

Elev: 10

StdP: 14.69

Time Zone: 4.00 (E04)

Period: 94-19

WBAN: 99999

Annual Heating, Humidification, and Ventilation Design Conditions

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	74.8	75.2	67.7	101.8	79.4	68.4	104.2	79.5	25.9	79.5	23.7	79.7	6.6	150	0.442

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
4	9.5	89.8	79.5	89.0	79.4	88.1	79.2	81.2	87.1	80.7	86.8	80.1	86.1	9.6	330

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
79.2	151.7	85.3	79.0	150.5	85.2	78.6	148.5	84.8	44.9	88.2	44.5	87.1	43.9	86.4	84.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 22.0	19.9	18.2	71.1	91.5	3.0	1.3	69.0	92.4	67.2	93.2	65.5	93.9	63.4	94.8		
(5)			67.9	82.8	2.8	1.1	65.9	83.5	64.3	84.2	62.7	84.8	60.7	85.5		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec			
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)			
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	81.8	81.3	82.4	83.2	83.8	83.5	81.5	80.0	80.1	81.0	81.7	81.7	81.7			
	DBStd	1.88	1.64	1.69	1.62	1.49	1.44	1.52	1.19	1.18	1.46	1.44	1.48	1.48			
	HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0			
	HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0			
	CDD50	11616	969	908	1030	1015	1038	945	931	935	929	983	951	982			
	CDD65	6141	504	488	565	565	573	495	466	470	479	518	501	517			
	CDH74	65161	5186	5473	6655	6819	6787	5077	4150	4152	4701	5427	5301	5433			
(13)	CDH80	18170	1349	1737	2420	2666	2440	1123	562	573	897	1377	1485	1541			
(14)	Wind	WSAvg	8.8	6.8	7.2	6.1	5.5	8.5	11.3	12.1	13.7	13.0	8.6	6.2	6.5		
(15) Precipitation	PrecAvg	91.4	16.0	10.6	7.7	7.4	5.8	3.0	2.8	3.5	6.0	7.5	8.3	11.5			
	PrecMax	135.7	34.3	24.1	20.5	18.2	22.0	12.8	10.9	11.0	18.0	22.2	17.4	23.9			
	PrecMin	65.2	2.4	0.4	2.2	1.5	0.3	0.4	0.7	0.0	0.4	0.4	1.2	2.3			
	PrecStd	16.0	6.6	5.9	3.7	3.2	4.9	2.3	2.0	2.7	4.3	4.8	4.1	4.9			
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	88.1	89.5	90.1	91.5	89.9	87.9	85.8	85.9	87.1	88.1	88.7	89.2			
		MCWB	79.4	79.7	79.6	80.0	79.9	79.1	76.0	77.0	77.9	77.5	77.4	77.6			
	2%	DB	87.1	88.1	89.5	89.9	88.8	86.3	84.4	84.5	86.1	86.8	87.8	87.9			
		MCWB	79.1	79.6	79.7	79.7	79.6	78.0	76.2	76.2	77.5	77.6	77.7	78.2			
	5%	DB	86.1	87.5	88.2	89.2	88.0	85.7	83.8	84.0	84.9	86.1	86.4	86.8			
		MCWB	78.6	79.4	79.5	79.7	79.5	77.7	76.1	75.9	76.9	77.5	77.8	78.2			
	10%	DB	85.3	86.2	87.6	88.0	87.5	84.4	82.7	82.7	84.2	85.5	85.9	85.9			
		MCWB	78.2	78.6	79.4	79.6	79.3	77.0	75.6	75.5	76.6	77.3	77.7	78.1			
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	80.8	81.3	81.7	82.2	81.9	80.5	78.9	78.8	79.7	80.0	80.5	80.2			
		MCDB	86.1	86.9	87.6	88.2	87.2	85.8	82.8	83.0	84.3	85.1	86.3	86.0			
	2%	WB	79.9	80.4	80.8	81.2	80.9	79.4	78.0	77.9	78.8	79.2	79.6	79.6			
		MCDB	85.2	86.5	87.2	87.5	86.6	84.2	82.2	82.1	83.7	84.4	85.2	85.4			
	5%	WB	79.2	79.8	80.1	80.6	80.2	78.8	77.3	77.2	78.1	78.7	78.9	79.0			
		MCDB	84.4	85.7	86.4	87.1	85.9	83.4	81.6	81.4	82.9	84.0	84.4	84.7			
	10%	WB	78.8	79.2	79.7	80.0	79.7	78.2	76.7	76.6	77.5	78.1	78.3	78.5			
		MCDB	83.9	84.8	85.8	86.2	85.3	82.8	81.1	80.9	82.1	83.3	83.8	84.0			
(35) Mean Daily Temperature Range	5% DB	MDBR	8.3	8.3	9.1	9.5	7.9	6.7	6.6	6.6	6.9	7.9	8.8	9.1			
		MCDBR	8.9	8.9	9.7	10.2	8.7	7.3	7.2	7.3	7.5	8.5	9.5	10.0			
		MCWBR	4.5	4.3	4.6	4.5	4.3	3.9	3.9	3.8	3.9	4.2	4.4	4.6			
	5% WB	MCDBR	8.5	8.6	9.1	9.5	8.2	6.9	6.6	6.7	7.1	8.0	8.8	9.3			
		MCWBR	4.6	4.5	4.7	4.7	4.5	4.1	4.0	3.9	4.2	4.4	4.6	4.7			
(40) Clear-Sky Solar Irradiance	taub	0.399	0.409	0.396	0.374	0.388	0.433	0.427	0.426	0.433	0.407	0.385	0.387				
	taud	2.587	2.540	2.600	2.679	2.614	2.436	2.440	2.453	2.443	2.539	2.618	2.625				
	Ebn at Noon	298	294	294	293	280	262	266	274	279	291	299	300				
	Edh at Noon	33	35	32	29	30	35	35	36	37	35	32	32				
(44) All-Sky Solar Radiation	RadAvg	1773	1983	2009	1966	1784	1646	1697	1822	1888	2025	2040	1882				
	RadStd	116	111	89	104	103	113	102	116	121	161	98	105				

Historical Trends

	DBAvg	Heating			Cooling			Degree-Days			
		99% DB		99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page