

BRAZZAVILLE MAYA MAYA INTL, CongoWMO: **644500**Lat: **4.252S**Lon: **15.253E**Elev: **319**StdP: **97.55**Time Zone: **1.00 (E01)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
7	18.1	19.0	16.0	11.8	22.9	16.8	12.4	23.2	5.5	25.2	5.3	25.2	1.3	260	0.268

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	9.3	34.2	24.6	33.7	24.6	33.0	24.5	26.1	31.2	25.7	30.7	25.5	30.4	2.4	240

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
24.9	20.8	28.1	24.2	19.9	27.6	24.1	19.8	27.5	83.2	31.5	81.5	31.1	80.2	30.7	31.2

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max		
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 5.8	5.0	4.4	DB	16.5	36.1	1.0	0.7	15.8	36.5	15.2	36.9	14.7	37.3	14.0	37.7	(4)
(5)			WB	15.9	27.2	0.7	1.1	15.4	28.0	15.0	28.6	14.6	29.3	14.1	30.1	(5)

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6) Temperatures, Degree-Days and Degree-Hours	DBAvg	26.2	26.8	27.1	27.6	27.6	26.9	24.6	23.7	24.6	26.2	26.6	26.6	26.4	(6)	
	DBStd	1.82	1.25	1.54	1.36	1.27	1.24	1.36	1.32	1.47	1.40	1.45	1.35	1.30	(7)	
	HDD10.0	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)	
	HDD18.3	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)	
	CDD10.0	5918	521	478	544	528	524	437	423	453	487	516	498	509	(10)	
	CDD18.3	2876	262	244	286	278	266	187	165	195	237	257	248	251	(11)	
	CDH23.3	23376	2266	2210	2676	2549	2232	1122	892	1327	1980	2193	1982	1945	(12)	
	CDH26.7	8315	797	854	1108	1046	802	270	194	392	714	799	707	630	(13)	
(14) Wind	WSAvg	2.0	1.7	1.9	1.8	1.8	1.8	1.9	2.1	2.5	2.6	2.1	1.8	1.7	(14)	
(15) Precipitation	PrecAvg	1385	157	133	175	188	124	8	2	5	36	140	257	192	(15)	
	PrecMax	1930	324	392	353	416	384	62	27	42	102	357	490	359	(16)	
	PrecMin	903	27	15	6	39	1	0	0	0	0	0	0	71	(17)	
	PrecStd	252	67	70	81	83	69	14	5	10	25	65	93	78	(18)	
(19) Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	34.0	34.9	35.2	35.1	34.2	32.1	31.2	32.8	34.2	34.2	33.9	33.2	(19)	
		MCWB	24.8	24.8	24.5	24.8	24.8	22.9	22.6	22.7	23.4	23.9	24.3	24.5	(20)	
	2%	DB	32.8	33.2	34.0	34.0	33.0	30.8	29.9	31.2	33.0	33.0	32.8	32.1	(21)	
		MCWB	24.8	24.9	24.9	25.0	25.0	23.2	22.3	22.3	23.3	23.9	24.3	24.6	(22)	
	5%	DB	31.8	32.2	33.0	32.9	32.0	29.2	28.9	30.2	31.9	32.0	31.9	31.1	(23)	
		MCWB	24.6	24.8	24.9	25.0	24.8	23.1	22.0	22.1	23.0	23.8	24.3	24.5	(24)	
	10%	DB	30.8	31.2	31.9	31.9	30.8	28.2	27.8	29.0	30.8	30.9	30.8	30.1	(25)	
		MCWB	24.5	24.7	24.7	24.8	24.7	22.8	21.7	21.6	22.9	23.8	24.2	24.5	(26)	
(27) Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	26.1	26.2	26.4	26.3	26.2	24.9	23.6	23.6	24.3	25.3	25.7	25.7	(27)	
		MCDB	30.8	31.4	32.0	31.6	30.9	29.0	29.1	30.5	31.5	31.0	30.6	30.3	(28)	
	2%	WB	25.6	25.7	25.9	25.8	25.7	24.2	22.8	22.9	23.8	24.7	25.2	25.3	(29)	
		MCDB	30.3	30.8	31.3	31.2	30.3	28.3	28.1	30.0	30.7	30.4	30.2	29.9	(30)	
	5%	WB	25.2	25.4	25.5	25.5	25.4	23.8	22.3	22.3	23.4	24.4	24.8	25.0	(31)	
		MCDB	29.8	30.3	30.7	30.7	29.9	27.7	27.2	28.7	30.1	29.8	29.7	29.5	(32)	
	10%	WB	24.8	25.1	25.1	25.1	25.0	23.2	21.9	21.9	23.0	24.0	24.5	24.6	(33)	
		MCDB	29.3	29.8	30.2	30.2	29.5	26.9	26.5	27.8	29.6	29.3	29.1	28.8	(34)	
(35) Mean Daily Temperature Range	5% DB	MDBR	8.1	8.7	9.3	9.4	8.4	8.0	8.4	8.7	8.9	8.7	8.4	7.8	(35)	
		MCDBR	9.7	10.2	10.8	10.7	10.1	9.6	10.3	10.9	11.1	10.6	10.0	9.3	(36)	
	5% WB	MCWBR	3.3	3.4	3.4	3.4	3.4	3.5	3.9	3.8	3.5	3.3	3.2	3.3	(37)	
		MCWBR	8.7	9.4	9.8	9.8	9.1	8.3	9.1	9.8	9.9	9.5	9.1	8.4	(38)	
(40) Clear-Sky Solar Irradiance	taub		0.557	0.547	0.510	0.443	0.550	0.651	0.719	0.747	0.639	0.495	0.457	0.535	(40)	
		taud	1.989	2.030	2.151	2.358	2.008	1.729	1.587	1.545	1.786	2.169	2.288	2.059	(41)	
	Ebn at Noon		795	806	827	860	742	648	611	619	715	839	875	809	(42)	
		Edh at Noon	189	183	160	126	171	221	258	279	227	157	139	175	(43)	
(44) All-Sky Solar Radiation	RadAvg		4.75	4.75	5.08	4.93	4.36	3.94	4.08	4.18	4.29	4.23	4.54	4.40	(44)	
	RadStd		0.21	0.22	0.27	0.25	0.21	0.21	0.18	0.31	0.19	0.19	0.17	0.22	(45)	

Historical Trends

	DBAvg	Heating		Cooling			Degree-Days			
		99% DB	99% DP	1% DB	1% WB	1% DP	HDD10.0	HDD18.3	CDD10.0	CDD18.3
	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)
Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
Regional (1 neighbor)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page