

BANGUI M'POKO INTL, Central African RepublicWMO: **646500**Lat: **4.398N**Lon: **18.519E**Elev: **1208**StdP: **14.07**Time Zone: **1.00 (E01)**Period: **94-19**WBAN: **99999****Annual Heating, Humidification, and Ventilation Design Conditions**

Coldest Month	Heating DB		Humidification DP/MCDB and HR						Coldest Month WS/MCDB				MCWS/PCWD to 99.6% DB		WSF
			99.6%			99%			0.4%		1%				
	99.6%	99%	DP	HR	MCDB	DP	HR	MCDB	WS	MCDB	WS	MCDB	MCWS	PCWD	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
8	60.6	62.8	38.8	36.3	90.4	44.7	45.6	87.1	14.2	77.6	12.1	78.3	1.5	320	0.253

Annual Cooling, Dehumidification, and Enthalpy Design Conditions

Hottest Month	Hottest Month DB Range	Cooling DB/MCWB						Evaporation WB/MCDB						MCWS/PCWD to 0.4% DB	
		0.4%		1%		2%		0.4%		1%		2%			
		DB	MCWB	DB	MCWB	DB	MCWB	WB	MCDB	WB	MCDB	WB	MCDB	MCWS	PCWD
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
3	20.1	97.2	73.4	95.9	73.7	94.8	74.0	80.4	88.8	79.3	88.1	78.7	87.7	5.6	180

Dehumidification DP/MCDB and HR									Enthalpy/MCDB						Extreme Max WB
0.4%			1%			2%			0.4%		1%		2%		
DP	HR	MCDB	DP	HR	MCDB	DP	HR	MCDB	Enth	MCDB	Enth	MCDB	Enth	MCDB	
(a)	(b)	(c)	(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)
78.7	156.1	84.3	77.3	148.4	82.8	76.8	146.0	82.4	45.1	89.8	44.0	88.5	43.3	88.1	88.9

Extreme Annual Design Conditions

Extreme Annual WS			Extreme Annual Temperature				n-Year Return Period Values of Extreme Temperature									
			Mean		Standard Deviation		n=5 years		n=10 years		n=20 years		n=50 years			
1%	2.5%	5%	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	Min	Max	DB	WB
(a)	(b)	(c)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(4) 12.5	10.5	9.1	56.8	101.4	2.3	1.2	55.1	102.3	53.8	103.0	52.4	103.7	50.7	104.6		
(5)			53.9	84.7	3.2	3.1	51.7	86.9	49.8	88.7	48.0	90.4	45.7	92.6		

Monthly Climatic Design Conditions

		Annual	Jan	Feb	Mar	Apr	May	Jun	Jul	Aug	Sep	Oct	Nov	Dec		
		(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)	(n)	(o)	(p)		
(6)	Temperatures, Degree-Days and Degree-Hours	DBAvg	80.1	79.2	82.7	83.0	81.9	81.1	79.7	78.4	78.5	79.2	79.2	79.7	79.2	(6)
(7)		DBStd	3.07	3.23	2.79	3.04	2.82	3.00	2.58	2.54	2.35	2.25	2.33	2.25	2.40	(7)
(8)		HDD50	0	0	0	0	0	0	0	0	0	0	0	0	0	(8)
(9)		HDD65	0	0	0	0	0	0	0	0	0	0	0	0	0	(9)
(10)		CDD50	10997	904	915	1024	957	964	890	880	885	876	906	892	904	(10)
(11)		CDD65	5522	439	495	559	507	499	440	415	420	426	441	442	439	(11)
(12)		CDH74	48584	4596	5436	5886	4971	4617	3526	2918	2874	3067	3091	3492	4110	(12)
(13)		CDH80	21755	2425	2883	2940	2283	2027	1350	998	1000	1175	1203	1489	1982	(13)
(14)	Wind	WSAvg	3.2	3.1	3.6	4.1	3.8	3.5	3.1	2.9	3.1	2.8	2.7	2.6	(14)	
(15)	Precipitation	PrecAvg	59.5	0.6	1.5	4.2	5.2	6.2	6.0	7.4	8.6	7.4	7.7	3.0	1.0	(15)
(16)		PrecMax	72.8	3.4	3.7	13.3	10.3	11.0	10.5	14.7	14.8	13.6	20.3	8.0	3.6	(16)
(17)		PrecMin	50.1	0.0	0.0	0.4	1.0	0.8	2.7	2.9	2.6	3.3	3.2	0.7	0.0	(17)
(18)		PrecStd	6.5	0.8	1.1	2.1	2.2	2.4	2.2	2.2	2.9	2.2	2.9	1.5	0.9	(18)
(19)	Monthly Design Dry Bulb and Mean Coincident Wet Bulb Temperatures	0.4%	DB	97.1	100.3	99.0	97.1	97.0	93.6	91.8	91.6	93.0	93.2	94.7	95.2	(19)
(20)			MCWB	69.5	70.5	74.1	77.4	76.5	77.3	77.2	77.1	77.2	77.4	74.5	71.3	(20)
(21)		2%	DB	95.2	98.0	96.9	95.1	94.7	91.5	89.7	89.7	91.1	91.2	92.1	93.3	(21)
(22)			MCWB	69.4	71.8	75.3	77.3	77.1	77.2	76.6	76.6	76.5	77.1	75.7	71.4	(22)
(23)		5%	DB	93.5	96.4	95.1	93.3	92.1	89.6	87.9	87.9	89.3	89.4	90.7	91.6	(23)
(24)			MCWB	69.3	71.8	75.8	76.9	77.2	76.6	76.4	76.2	76.2	76.7	76.0	71.8	(24)
(25)		10%	DB	91.6	93.6	93.1	91.2	89.9	87.6	85.9	85.9	86.9	87.4	88.2	89.8	(25)
(26)			MCWB	69.4	72.5	76.1	77.0	76.9	76.5	76.2	76.2	76.1	76.3	76.1	71.9	(26)
(27)	Monthly Design Wet Bulb and Mean Coincident Dry Bulb Temperatures	0.4%	WB	79.2	80.8	80.8	81.9	80.7	79.9	79.9	79.9	80.0	80.6	79.3	(27)	
(28)			MCD B	90.1	90.8	90.2	89.9	89.6	87.8	86.5	86.2	86.8	87.9	86.5	87.6	(28)
(29)		2%	WB	77.7	78.6	79.2	79.7	79.0	78.6	78.2	78.3	78.3	78.4	78.8	78.1	(29)
(30)			MCD B	88.1	89.7	90.1	89.4	88.1	86.8	85.6	85.3	85.8	86.6	87.2	86.6	(30)
(31)		5%	WB	76.5	77.5	78.2	78.5	78.2	77.9	77.4	77.4	77.4	77.6	77.9	77.2	(31)
(32)			MCD B	86.2	88.5	89.2	88.2	87.2	85.8	84.7	84.5	85.4	85.8	86.4	85.7	(32)
(33)		10%	WB	75.5	76.6	77.3	77.6	77.5	77.2	76.6	76.5	76.6	76.7	77.0	76.3	(33)
(34)			MCD B	84.6	87.3	88.0	87.3	86.3	84.8	83.5	83.4	84.4	84.8	85.6	84.1	(34)
(35)	Mean Daily Temperature Range	5% DB	MDBR	27.7	23.7	20.1	18.2	17.4	16.0	14.8	15.2	16.6	16.8	18.4	23.8	(35)
(36)			MCDBR	29.5	27.5	22.9	21.6	20.8	19.2	18.3	18.4	19.6	20.1	21.8	26.2	(36)
(37)			MCWBR	9.7	9.2	6.8	7.3	7.3	7.1	7.5	7.7	7.8	8.2	8.5	9.4	(37)
(38)		5% WB	MCDBR	23.1	21.7	20.7	19.5	18.7	17.1	16.6	16.6	17.9	18.3	19.1	20.8	(38)
(39)			MCWBR	9.4	8.6	8.2	8.3	7.7	7.6	7.9	8.0	8.2	8.5	9.0	9.5	(39)
(40)	Clear-Sky Solar Irradiance	taub	0.591	0.633	0.653	0.493	0.449	0.465	0.482	0.456	0.429	0.437	0.518	0.588	(40)	
(41)		taud	1.856	1.785	1.753	2.192	2.346	2.283	2.213	2.276	2.373	2.368	2.103	1.876	(41)	
(42)		Ebn at Noon	237	231	227	262	267	259	256	268	280	279	255	235	(42)	
(43)		Edh at Noon	67	73	75	48	40	42	45	43	40	40	52	64	(43)	
(44)	All-Sky Solar Radiation	RadAvg	1834	1744	1722	1694	1620	1477	1397	1435	1586	1566	1626	1744	(44)	
(45)		RadStd	99	105	93	78	62	57	70	80	57	79	66	77	(45)	

Historical Trends

		DBAvg	Heating		Cooling			Degree-Days			
			99% DB	99% DP	1% DB	1% WB	1% DP	HDD50	HDD65	CDD50	CDD65
(d)	(e)	(f)	(g)	(h)	(i)	(j)	(k)	(l)	(m)		
(46) Station Only	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A
(47) Regional (0 neighbors)	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A	N/A

Nomenclature: See separate page